

| Testing Results – Clatskanie Elementary School Action level is 4 pCi/L (picocuries) | |
|--|---------------------|
| Testing was done over a 3 day period, 10/4 – 10/7/19 | |
| Location: | Test Result (pCi/L) |
| Upper Level: Rm 204 | .5 |
| Upper Level: Rm 204 | .3 |
| Upper Level: Rm 206 | .3 |
| Cardiff: Rm 14 | .8 |
| Cardiff: Rm 15 | 1.1 |
| Cardiff: Rm 16 | .8 |
| Cardiff: Rm 17 | .7 |
| Cardiff: Rm 17 Dup | .9 |
| Cardiff: Staff | 1 |
| Cardiff: Gym | 2.2 |
| Cardiff: Gym | 2.2 |
| Cardiff: Gym | 2.2 |
| Cardiff: Gym | 2.7 |
| Cardiff: Rm 22 | 1.5 |
| Cardiff: Rm 21 | 1.5 |
| Cardiff: Rm 20 | 1.2 |
| Cardiff: Rm 19 | 1.3 |
| Cardiff: Rm 18 | .6 |
| Cardiff: Rm 18 Dup | .5 |
| Lower Level: SPED | 1.9 |
| Lower Level: Speech | 3.1 |
| Lower Level: Art (Main) | 1.1 |
| Lower Level: Art (Rear) | 1.6 |
| Lower Level: Art (Rear) | 1.6 |
| Lower Level: Art Dup | 1.6 |
| Lower Level: Copy | 1.7 |
| Lower Level: Copy Dup | 1.8 |
| Old Gym | 1.4 |
| Old Gym | 1.3 |
| Old Gym | 1.2 |
| Old Gym | 1.6 |
| Kitchen | .6 |
| Cafeteria | .7 |
| Cafeteria | .5 |
| Lower Level: Staff | .7 |
| Lower Level: Rm 121 | .8 |
| Library (Rear) | 1.4 |
| Library (Front) | .9 |
| Library (Front) | 1 |
| Library Dup | .9 |
| Upper Level: Rm 205 | .5 |
| Upper Level: Rm 201 | .6 |
| Upper Level: Rm 207 | .2 |
| Upper Level: Rm 201 | .6 |