

RIVERVIEW GARDENS

SCHOOL DISTRICT

Joylynn Pruitt-Adams, Ed.D.,
Superintendent

March 19, 2024

1370 Northumberland Drive
St. Louis, MO 63137
Office 314.869.2505 x 20102
Fax 314.388.6003
www.rgsd.k12.mo.us

MISSION

Collaboratively educate and empower our scholars to thrive in challenging environments

VISION

RGSD will be a district where:

- *There are high expectations for all.*
- *There will be healthy, loving, empathetic and kind relationships.*
- *Students are at the center of our decisions.*
- *Supports are provided so students become grade-level ready.*
- *There is transparency, accountability, timely, clear communication, and high levels of customer service.*
- *All stakeholders have a voice.*
- *There is a focus on college and career readiness.*

Special Administrative Board

Veronica Morrow-Reel
President, Master C.B.M.

Niketia Coleman, Ed.D.
Vice-President, C.B.M.

Wanda Lane,
Treasurer, C.B.M.

Tommie Harsley, III,
Director, C.B.M.

Miranda Avant-Elliott, Ed.D.,
Director, C.B.M.

Jacqueline Jackson,
Director, C.B.M.

Sharon Titsworth,
Director, C.B.M.

Secretary
Sha S. Fields,
Coordinator of Board
Governance/Custodian of Records

Dear Danforth Elementary School parents and staff,

On February 2, 2024, I shared information regarding the Get the Lead Out of School Drinking Water Act and its requirements for school districts.

The Environmental Protection Agency (EPA) currently has a lead drinking water standard limit of 15 micrograms per liter (ug/L) of lead in water. However, Missouri law requires that all Missouri schools achieve a 5 ug/L limit of lead in water.

During February 2024, all RGSD schools and buildings were tested for lead concentration in school drinking water outlets.

We are pleased to report that at Danforth Elementary School, all drinking water outlets were found to be in compliance and met the 5 ug/L Missouri standard limit of lead in water. Therefore, there is no additional action required at this time.

If you have questions about lead sample testing results, or if you have concerns, please email karl.scheidt@rgsd.k12.mo.us.

To view reports for all schools/buildings throughout Riverview Gardens School District, please visit <https://www.rgsdmo.org/facilities/gettheleadout>.

Sincerely,



Joylynn Pruitt-Adams, Ed.D.
Superintendent