



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arch Bishop Damiano School
1145 Delsea Drive
Westville, NJ 08093

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U122434	Field Blank	08/25/2022 06:30	09/2/2022 10:13	<2.00	15.5	SM3113B
U122435	Sink - Rm1	08/25/2022 06:31	09/13/2022 11:24	<2.00	15.5	SM3113B
U122436	Sink - Rm1 Bath	08/25/2022 06:32	09/13/2022 11:27	<2.00	15.5	SM3113B
U122437	Sink - Rm3 Bath	08/25/2022 06:33	09/2/2022 10:14	<2.00	15.5	SM3113B
U122438	Sink - Rm2	08/25/2022 06:34	09/2/2022 10:29	<2.00	15.5	SM3113B
U122439	Sink - Rm2 Bath	08/25/2022 06:35	09/2/2022 10:30	<2.00	15.5	SM3113B
U122440	Sink - Rm2 Bath	08/25/2022 06:36	09/1/2022 13:28	<2.00	15.5	SM3113B
U122441	Sink - Rm2 Bath	08/25/2022 06:37	09/1/2022 13:32	<2.00	15.5	SM3113B
U122442	Sink - Rm3	08/25/2022 06:38	09/1/2022 13:33	<2.00	15.5	SM3113B
U122443	Sink - Rm4 Nurses	08/25/2022 06:39	09/1/2022 13:34	<2.00	15.5	SM3113B
U122444	Sink - Rm4 N Bath	08/25/2022 06:40	09/1/2022 13:35	<2.00	15.5	SM3113B
U122445	Sink - Rm5	08/25/2022 06:41	09/1/2022 13:36	<2.00	15.5	SM3113B
U122446	Sink - Rm6	08/25/2022 06:42	09/13/2022 11:31	<2.00	15.5	SM3113B
U122447	Sink - Rm6 Bath	08/25/2022 06:43	09/1/2022 13:41	<2.00	15.5	SM3113B
U122448	Sink - Rm7	08/25/2022 06:44	09/1/2022 13:43	<2.00	15.5	SM3113B
U122449	Sink - Rm7 Bath	08/25/2022 06:45	09/13/2022 11:34	<2.00	15.5	SM3113B
U122450	Sink - Rm8	08/25/2022 06:46	09/13/2022 11:38	<2.00	15.5	SM3113B
U122451	Sink - Rm8 Bath	08/25/2022 06:47	09/1/2022 13:44	<2.00	15.5	SM3113B
U122452	Sink - Adm Bath	08/25/2022 06:48	09/1/2022 13:45	<2.00	15.5	SM3113B
U122453	Sink - Adm Bath	08/25/2022 06:49	09/1/2022 13:46	<2.00	15.5	SM3113B
U122454	Sink - Hall Bath B4	08/25/2022 06:50	09/1/2022 13:49	<2.00	15.5	SM3113B
U122455	Sink - Hall Bath B4	08/25/2022 06:51	09/1/2022 13:50	<2.00	15.5	SM3113B
U122456	Sink - Hall Bath G	08/25/2022 06:52	09/13/2022 11:41	<2.00	15.5	SM3113B
U122457	Sink - Hall Bath G	08/25/2022 06:53	09/1/2022 13:51	<2.00	15.5	SM3113B
U122458	Sink - Hall Bath G	08/25/2022 06:54	09/1/2022 13:55	<2.00	15.5	SM3113B
U122459	Sink - Rm27	08/25/2022 06:55	09/1/2022 13:56	<2.00	15.5	SM3113B
U122460	Sink - Rm14	08/25/2022 06:56	09/1/2022 13:57	<2.00	15.5	SM3113B
U122461	Sink - Rm14 Bath	08/25/2022 06:57	09/1/2022 13:58	<2.00	15.5	SM3113B
U122462	Sink - Rm15	08/25/2022 06:58	09/1/2022 13:59	<2.00	15.5	SM3113B
U122463	Sink - Rm15 Bath	08/25/2022 06:59	09/13/2022 11:45	<2.00	15.5	SM3113B
U122464	Sink - Rm16	08/25/2022 07:00	09/1/2022 14:00	<2.00	15.5	SM3113B
U122465	Sink - Rm16 Bath	08/25/2022 07:01	09/1/2022 14:08	<2.00	15.5	SM3113B
U122466	Sink - Rm28	08/25/2022 07:02	09/13/2022 11:48	<2.00	15.5	SM3113B
U122467	Sink - Rm17A	08/25/2022 07:06	09/1/2022 14:11	<2.00	15.5	SM3113B
U122468	Sink - Rm17A Bath	08/25/2022 07:07	09/1/2022 14:13	<2.00	15.5	SM3113B
U122469	Sink - Rm17B	08/25/2022 07:08	09/1/2022 14:14	<2.00	15.5	SM3113B
U122470	Sink - Rm18 Frpmt	08/25/2022 07:03	09/1/2022 14:15	<2.00	15.5	SM3113B

Units - ug/L = ppb




**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arch Bishop Damiano School
1145 Delsea Drive
Westville, NJ 08093

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U122471	Sink - Rm18 Bath	08/25/2022 07:04	09/1/2022 14:16	<2.00	15.5	SM3113B
U122472	Sink - Rm18 Rear	08/25/2022 07:05	09/1/2022 14:21	<2.00	15.5	SM3113B
U122473	Sink - Rm20	08/25/2022 07:09	09/1/2022 14:22	<2.00	15.5	SM3113B
U122474	Sink - Rm20 Bath	08/25/2022 07:10	09/1/2022 14:23	<2.00	15.5	SM3113B
U122475	Sink - Rm9	08/25/2022 07:15	09/13/2022 11:52	<2.00	15.5	SM3113B
U122476	Sink - Rm10 Library Bath	08/25/2022 07:16	09/1/2022 14:24	<2.00	15.5	SM3113B
U122477	Sink - Rm10 Library	08/25/2022 07:17	09/1/2022 14:25	<2.00	15.5	SM3113B
U122478	Sink - Ramp Bath	08/25/2022 07:18	09/1/2022 14:28	<2.00	15.5	SM3113B
U122479	Sink - Ramp Bath	08/25/2022 07:19	09/1/2022 14:30	<2.00	15.5	SM3113B
U122480	Sink - Dish Washer	08/25/2022 07:34	09/1/2022 14:31	<2.00	15.5	SM3113B
U122481	Sink - Kitchen Hand Wash	08/25/2022 07:35	09/1/2022 14:39	<2.00	15.5	SM3113B
U122482	Sink - Kitchen Food Prep	08/25/2022 07:36	09/1/2022 14:40	<2.00	15.5	SM3113B
U122483	Sink - Kitchen Food Prep	08/25/2022 07:37	09/1/2022 14:41	<2.00	15.5	SM3113B
U122484	Sink - Kitchen Bath	08/25/2022 07:38	09/1/2022 14:43	<2.00	15.5	SM3113B
U122485	Sink - Girls Bath Gym	08/25/2022 07:23	09/1/2022 14:44	<2.00	15.5	SM3113B
U122486	Sink - Girls Bath Gym	08/25/2022 07:24	09/1/2022 14:45	<2.00	15.5	SM3113B
U122487	Sink - Boys Bath Gym	08/25/2022 07:25	09/2/2022 08:20	<2.00	15.5	SM3113B
U122488	Sink - Boys Bath Gym	08/25/2022 07:26	09/2/2022 08:23	<2.00	15.5	SM3113B
U122489	Sink - Rm21 Office	08/25/2022 07:22	09/2/2022 08:24	<2.00	15.5	SM3113B
U122490	Sink - Rm22 Office Bath	08/25/2022 07:21	09/2/2022 08:26	<2.00	15.5	SM3113B
U122491	Sink - Staff Lounge	08/25/2022 07:20	09/2/2022 08:27	<2.00	15.5	SM3113B
U122492	Water Fountain - Hall	08/25/2022 07:12	09/2/2022 08:28	<2.00	15.5	SM3113B
U122493	Water Fountain - Hall	08/25/2022 07:13	09/2/2022 08:35	<2.00	15.5	SM3113B
U122494	Water Fountain - Hall	08/25/2022 07:14	09/2/2022 08:36	<2.00	15.5	SM3113B
U122495	Water Fountain - Hall	08/25/2022 07:31	09/2/2022 08:37	<2.00	15.5	SM3113B


Mark J. Riether, Lab Director

09/19/2022

Date

Units - ug/L = ppb

Page 2