



49 Woodside Street Stamford, CT 06902

December 22, 2016

New Milford Schools  
Attn. Kevin Munrett

Re: Radon Re-evaluation  
Sarah Noble Intermediate School

To Whom It May Concern:

Enclosed with this letter are the results of radon testing conducted at the above mentioned site. The radon testing was conducted in accordance with Connecticut Department of Public Health radon re-evaluation protocols. The testing was conducted over a three day period – December 12-15, 2016. The radon kits were sent via FedEx to Air Chek, Inc. in Mills River, NC for radon analysis. Listed below is a summary of the testing results:

<u>Kit Number</u>	<u>Location</u>	<u>Results</u>
• Kit # 7824255	Room 108	<0.3 pCi/L
• Kit # 7824256	QA/QC	0.5 pCi/L
• Kit # 7824257	Room 113	<0.3 pCi/L
• Kit # 7824258	Room 117 (116)	0.8 pCi/L
• Kit # 7824259	Room 120 (119)	<0.3 pCi/L
• Kit # 7824260	Room 127	<0.3 pCi/L
• Kit # 7824261	Room 133	<0.3 pCi/L
• Kit # 7824254	Room 142	<0.3 pCi/L
• Kit # 7824262	QA/QC	<0.3 pCi/L
• Kit # 7824247	Room 146	<0.3 pCi/L
• Kit # 7824248	Room 152	0.6 pCi/L
• Kit # 7824249	Room 153	<0.3 pCi/L
• Kit # 7824250	Room 167	0.8 pCi/L
• Kit # 7824251	Room 188	<0.3 pCi/L
• Kit # 7824252	Room 194	<0.3 pCi/L
• Kit # 7824253	QA/QC	0.7 pCi/L

As shown on the attached analysis report, none of the test kits deployed during this round of testing returned results that exceeded the EPA action level of 4 pCi/L.

**For further information, please refer to the following websites:**

<https://www.epa.gov/radon>

[http://www.ct.gov/dph/cwp/view.asp?a=3140&q=387592&dphNav\\_GID=1828&dphPNa\\_vCtr=#47072](http://www.ct.gov/dph/cwp/view.asp?a=3140&q=387592&dphNav_GID=1828&dphPNa_vCtr=#47072)

I am certified by the National Radon Safety Board (Certification Number 7SS0001), and listed on the Connecticut Department of Public Health list of "Radon Measurement Professionals". If you have questions or would like to discuss the radon testing, please call me at 203-324-2222 or e-mail me at [rebenhack@hygenix.com](mailto:rebenhack@hygenix.com).

Sincerely,



Ryan Ebenhack MS CIEC  
Hygenix, Inc.


*Attachments: Laboratory Results  
Site Layout with sample locations*

Radon test result report for:**NEW MILFORD SCHOOLS  
SNIS**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7824255	108	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824256	108D	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	0.5 ± 0.2	2016-12-17
7824257	113	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824258	117 / 116	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	0.8 ± 0.2	2016-12-17
7824259	120 / 119	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824260	127	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824261	133	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824254	142	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824262	142B	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824247	146	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824248	152	2016-12-12 @ 11:00 am	2016-12-15 @ 8:00 am	0.6 ± 0.2	2016-12-17
7824249	153	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824250	167	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.8 ± 0.2	2016-12-17
7824251	188	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824252	194	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	< 0.3	2016-12-17
7824253	194D	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.7 ± 0.2	2016-12-17

SNIS 1st FL.

# SNIS



(13)

11/15-11/17/11

Rooms TESTED:

- 136A
- 136
- 131
- 131A
- Main office
- Main office/DUP
- 123B
- 123F
- 123G
- 123A
- 124
- 195
- 195/BLANK
- 193
- 179
- 179/DUP

12/12/16



Rooms Tested 12/12-12/15/16