



# Garden State Laboratories, Inc.

Report Date: 03/04/2024

## Bacteriological and Chemical Testing

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gslabs.com  
Internet: www.gslabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A. Laboratory Manager

For: Elsinboro Board of Education - JM  
631 Salem-Fort Elfsborg Rd

Salem, NJ 08079

Attention: Melanie Allen

Client Number: ELS05

Laboratory Director:

Sample ID: Lab Sample ID: 240220059-01 PWSID Number: NJ1703306  
Site: Grade 1 Hand Sink Collection Date/Time: 02/16/2024 09:57 Facility ID: DS  
Matrix: Potable water Sample Type: Grab Site Code: PBCU6

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.125 mg/l    | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 13:57     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00296 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:11     |            |

Sample ID: Lab Sample ID: 240220059-02 PWSID Number: NJ1703306  
Site: 2nd Grade Sink Collection Date/Time: 02/16/2024 09:59 Facility ID: DS  
Matrix: Potable water Sample Type: Grab Site Code: PBCU10

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.108 mg/l    | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:00     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00269 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:14     |            |

Sample ID: Lab Sample ID: 240220059-03 PWSID Number: NJ1703306  
Site: WC by Nurses Rm Collection Date/Time: 02/16/2024 10:06 Facility ID: DS  
Matrix: Potable water Sample Type: Grab Site Code: PBCU3

| Analyte                   | Method    | SM YR | DF | Sample Result  | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|----------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | < 0.0100 mg/l  | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:03     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | < 0.00100 mg/l | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:17     |            |



Sample ID: Lab Sample ID: 240220059-04 PWSID Number: NJ1703306  
 Site: Nurses RR Sink Collection Date/Time: 02/16/2024 10:04 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU7

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0388 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:16     |            |
| Lead, Total Recoverable   | EPA 200.8 |       | 1  | 0.00135 mg/l  | 0.015 | 0.00100    | 0.00032 | 20044        | 02/29/24 14:04     |            |

Sample ID: Lab Sample ID: 240220059-05 PWSID Number: NJ1703306  
 Site: Girls BR Left Sink Collection Date/Time: 02/16/2024 10:01 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU9

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0839 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:19     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.0107 mg/l   | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:22     |            |

Sample ID: Lab Sample ID: 240220059-06 PWSID Number: NJ1703306  
 Site: Boys BR Left Sink Collection Date/Time: 02/16/2024 10:08 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU8

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.262 mg/l    | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:22     |            |
| Lead, Total Recoverable   | EPA 200.8 |       | 1  | 0.00314 mg/l  | 0.015 | 0.00100    | 0.00032 | 20044        | 02/29/24 14:08     |            |

Sample ID: Lab Sample ID: 240220059-07 PWSID Number: NJ1703306  
 Site: WC by Kindergarten Collection Date/Time: 02/16/2024 10:11 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU5

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0662 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:26     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00599 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:47     |            |

Sample ID: Lab Sample ID: 240220059-08 PWSID Number: NJ1703306  
 Site: K1st Hand Sink Collection Date/Time: 02/16/2024 10:14 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU2

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0270 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:29     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00172 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:50     |            |

Sample ID: Lab Sample ID: 240220059-09 PWSID Number: NJ1703306  
 Site: WC by All Purpose Collection Date/Time: 02/16/2024 10:17 Facility ID: DS  
 M Potable water Sample Type: Grab Site Code: PBCU4

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0465 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:32     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00184 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:53     |            |

Sample ID: Lab Sample ID: 240220059-10 PWSID Number: NJ1703306  
 Site: All Purpose Café Sink Collection Date/Time: 02/16/2024 10:19 Facility ID: DS  
 Matrix: Potable water Sample Type: Grab Site Code: PBCU1

| Analyte                   | Method    | SM YR | DF | Sample Result | MCL   | Rep. Limit | MDL     | Lab Cert No. | Analysis Date/Time | Qualifiers |
|---------------------------|-----------|-------|----|---------------|-------|------------|---------|--------------|--------------------|------------|
| Copper, Total Recoverable | EPA 200.7 |       | 1  | 0.0649 mg/l   | 1.3   | 0.0100     | 0.0048  | 20044        | 02/21/24 14:35     |            |
| Lead, Total Recoverable   | EPA 200.9 |       | 1  | 0.00157 mg/l  | 0.015 | 0.00100    | 0.00055 | 20044        | 02/23/24 14:56     |            |

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,  
 MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.  
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

