

HORIZON ENVIRONMENTAL GROUP, INC.

P.O. Box 316
Thorofare, NJ 08086

Phone: 856-848-0800
Fax: 856-848-0838

January 15, 2022

Mr. John Swanson
Paulsboro Board of Education
662 North Delaware Street
Paulsboro, NJ 08066

Reference: Lead in Water Testing at Paulsboro High School (First Draw Samples - 211031)

Dear Mr. Swanson:

Pursuant to your request, collection and analysis of sixty-eight (68) first draw water samples from the domestic water supply system at the Paulsboro High School facility have been completed. In accordance with applicable New Jersey guidelines, the samples were collected in the morning on Sunday, October 31, 2021, by personnel from Horizon Environmental Group, Inc., and submitted for analysis for the presence of lead using inductively coupled plasma mass spectrometry (ICP-MS) in accordance with USEPA Method 200.8. The results of the analyses of the samples are as follows:

Sample No.	Location	Lead Concentration ($\mu\text{g/L}$)	Reporting Limit ($\mu\text{g/L}$)
P-DW-35A	Hall near Principal's Office (Filler)	1.23	1.00
P-DW-35B	Hall near Principal's Office (Cooler)	1.09	1.00
P-DW-33	Nurse's Office - Near Hall Wall	2.02	1.00
P-DW-01	Boiler Room	ND	1.00
P-DW-34	Nurse's Office	ND	1.00
P-DW-08A	Hall near Room 5 (Filler)	17.1	1.00
P-DW-08B	Hall near Room 5 (Cooler)	13.3	1.00
P-DW-36A	Hall near Room 105 (Filler)	ND	1.00
P-DW-36B	Hall near Room 105 (Cooler)	1.14	1.00
P-DW-37A	Hall near Room 205 (Filler)	ND	1.00
P-DW-37B	Hall near Room 205 (Cooler)	ND	1.00
P-DW-62	Room 210 - Teacher's Sink	7.67	1.00
P-DW-07A	Hall near Trainer's Office (Filler)	ND	1.00
P-DW-07B	Hall near Trainer's Office (Cooler)	ND	1.00
P-DW-31A	Hall near Room 112 (Filler)	ND	1.00
P-DW-31B	Hall near Room 112 (Cooler)	1.32	1.00
P-DW-38A	Hall near Room 211 (Filler)	ND	1.00
P-DW-38B	Hall near Room 211 (Cooler)	ND	1.00
P-DW-70	Trainer's Office - Sink	ND	1.00
P-DW-06	Trainer's Office - Ice Machine	ND	1.00
P-DW-04	School Store - Sink	4.09	1.00
P-DW-42	Girls PE Office - Sink	2.08	1.00

Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
P-DW-10A	Girls Locker Room (Filler)	3.17	1.00
P-DW-10B	Girls Locker Room (Cooler)	2.70	1.00
P-DW-44	Boys PE Office - Sink	1.58	1.00
P-DW-09A	Boys Locker Room (Filler)	6.31	1.00
P-DW-09B	Boys Locker Room (Cooler)	3.48	1.00
P-DW-29	Kitchen - Ice Machine	ND	1.00
P-DW-30	Kitchen - Steam Kettle	10.3	1.00
P-DW-20	Kitchen - Sink #1	1.90	1.00
P-DW-22	Kitchen - Sink #2	1.01	1.00
P-DW-24	Kitchen - Sink #3	1.34	1.00
P-DW-26	Kitchen - Sink #4	1.25	1.00
P-DW-28	Kitchen - Sink #5	11.5	1.00
P-DW-18A	Cafeteria (Filler)	2.01	1.00
P-DW-18B	Cafeteria (Cooler)	1.56	1.00
P-DW-11A	Hall near Gym (Filler)	ND	1.00
P-DW-11B	Hall near Gym (Cooler)	ND	1.00
P-DW-39A	Hall near Jr High Boys Bathroom (Filler)	ND	1.00
P-DW-39B	Hall near Jr High Boys Bathroom (Cooler)	1.17	1.00
P-DW-12A	Hall near Room 13 (Filler)	1.11	1.00
P-DW-12B	Hall near Room 13 (Cooler)	1.17	1.00
P-DW-17A	Hall near Cafeteria (Filler)	3.34	1.00
P-DW-17B	Hall near Cafeteria (Cooler)	3.50	1.00
P-DW-49	Room 113 - Sink #1	63.3	1.00
P-DW-51	Room 113 - Sink #2	30.4	1.00
P-DW-53	Room 113 - Sink #3	19.2	1.00
P-DW-55	Room 113 - Sink #4	38.9	1.00
P-DW-57	Room 113 - Sink #5	1.22	1.00
P-DW-59	Room 113 - Sink #6	22.0	1.00
P-DW-61	Room 113 - Sink #7	20.7	1.00
P-DW-46	Teacher's Lounge - Sink	6.78	1.00
P-DW-47	Teacher's Lounge - Next to Refrigerator	41.9	1.00
P-DW-13A	Hall near Room 116 (Filler)	11.9	1.00
P-DW-13B	Hall near Room 116 (Cooler)	15.4	1.00
P-DW-14A	Hall near Room 117 (Filler)	4.57	1.00
P-DW-14B	Hall near Room 117 (Cooler)	4.59	1.00
P-DW-40A	Hall near Room 217 (Filler)	3.31	1.00
P-DW-40B	Hall near Room 217 (Cooler)	3.46	1.00
P-DW-63	Library - Utility/Alarm Room	417	1.00
P-DW-65	Librarian's Office - Faucet	4.33	1.00
P-DW-64A	Library - Near Girls Bathroom (Filler)	4.87	1.00
P-DW-64B	Library - Near Girls Bathroom (Cooler)	6.34	1.00
P-DW-68	Library - Exam Room #1	5.48	1.00
P-DW-69	Library - Exam Room #2	7.16	1.00
P-DW-66	Parenting Center - Sink	ND	1.00
P-DW-67	Parenting Center - Large Conference Room	5.04	1.00
211031-P-BLANK	BLANK	ND	1.00

Note: "ND" equals none detected; "µg/L" equals micrograms per liter which is equivalent to parts per billion (ppb)

The following samples exceeded the "action level" of 15 µg/L (ppb) established by the United States Environmental Protection Agency and adopted by the State of New Jersey.

Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
P-DW-08A	Hall near Room 5 (Filler)	17.1	1.00
P-DW-49	Room 113 - Sink #1	63.3	1.00
P-DW-51	Room 113 - Sink #2	30.4	1.00
P-DW-53	Room 113 - Sink #3	19.2	1.00
P-DW-55	Room 113 - Sink #4	38.9	1.00
P-DW-59	Room 113 - Sink #6	22.0	1.00
P-DW-61	Room 113 - Sink #7	20.7	1.00
P-DW-47	Teacher's Lounge - Next to Refrigerator	41.9	1.00
P-DW-13B	Hall near Room 116 (Cooler)	15.4	1.00
P-DW-63	Library - Utility/Alarm Room	417	1.00

The "action level" of 15 µg/L (ppb) does not necessarily signal a violation, but would trigger additional monitoring, maintenance, treatment and/or mitigation requirements. It is our understanding that the fixture in the library utility/alarm room will no longer be allowed to be used for potable water. In addition, it is our understanding that the other fixtures were taken out of service and not used until "flush" samples were collected from them or repairs were made. Regarding the fixtures where lead was detected, but at a level below the action level, it is recommended that those fixtures be flushed periodically.

All laboratory analysis was performed by the trained staff at EMSL Analytical, Inc. in Cinnaminson, New Jersey and a copy of the analysis document is attached. If you have any questions or need more information, please do not hesitate to contact us at (856) 848-0800.

Sincerely,
HORIZON ENVIRONMENTAL GROUP, INC.



Steven J. Flanigan
Vice President



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

11/8/2021

Phone: (609) 221-4660
Fax: (856) 848-0838

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/1/2021. The results are tabulated on the attached data pages for the following client designated project:

94015-65/ Paulsboro High School

The reference number for these samples is EMSL Order #012112496. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-35A
 Hall Near Principal's Office (Filler)
Collected: 10/31/2021
 7:24:00 AM
Lab ID: 012112496-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.23	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:27

Client Sample Description P-DW-35B
 Hall Near Principal's Office (Cooler)
Collected: 10/31/2021
 7:24:00 AM
Lab ID: 012112496-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.09	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:31

Client Sample Description P-DW-33
 Nurse's Office- Near Hall Way
Collected: 10/31/2021
 7:28:00 AM
Lab ID: 012112496-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.02	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:33

Client Sample Description P-DW-01
 Boiler Room
Collected: 10/31/2021
 7:28:00 AM
Lab ID: 012112496-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:37

Client Sample Description P-DW-34
 Nurse Office
Collected: 10/31/2021
 7:30:00 AM
Lab ID: 012112496-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-08A
 Hall Near Room 5 (Filler) **Collected:** 10/31/2021 7:32:00 AM **Lab ID:** 012112496-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.1	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:40

Client Sample Description P-DW-08B
 Hall Near Room 5 (Cooler) **Collected:** 10/31/2021 7:35:00 AM **Lab ID:** 012112496-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.3	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:42

Client Sample Description P-DW-36A
 Hall Near Room 105 (Filler) **Collected:** 10/31/2021 7:35:00 AM **Lab ID:** 012112496-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:43

Client Sample Description P-DW-36B
 Hall Near Room 105 (Cooler) **Collected:** 10/31/2021 7:38:00 AM **Lab ID:** 012112496-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.14	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:45

Client Sample Description P-DW-37A
 Hall Near Room 205 (Filler) **Collected:** 10/31/2021 7:38:00 AM **Lab ID:** 012112496-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-37B
 Hall Near Room 205 (Cooler) **Collected:** 10/31/2021 7:40:00 AM **Lab ID:** 012112496-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:48

Client Sample Description P-DW-62
 Room 210- Teacher's Sink **Collected:** 10/31/2021 7:40:00 AM **Lab ID:** 012112496-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.67	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:55

Client Sample Description P-DW-07A
 Hall Near Trainer's Office (Filler) **Collected:** 10/31/2021 7:45:00 AM **Lab ID:** 012112496-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:56

Client Sample Description P-DW-07B
 Hall Near Trainer's Office (Cooler) **Collected:** 10/31/2021 7:47:00 AM **Lab ID:** 012112496-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:58

Client Sample Description P-DW-31A
 Hall Near Room 112 (Filler) **Collected:** 10/31/2021 7:47:00 AM **Lab ID:** 012112496-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 19:59

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-31B **Collected:** 10/31/2021 **Lab ID:** 012112496-0016
 Hall Near Room 112 (Cooler) 7:51:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.32	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:01

Client Sample Description P-DW-38A **Collected:** 10/31/2021 **Lab ID:** 012112496-0017
 Hall Near Room 211 (Filler) 7:51:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:02

Client Sample Description P-DW-38B **Collected:** 10/31/2021 **Lab ID:** 012112496-0018
 Hall Near Room 211 (Cooler) 7:53:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:04

Client Sample Description P-DW-70 **Collected:** 10/31/2021 **Lab ID:** 012112496-0019
 Trainer's Office - Sink 7:53:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:05

Client Sample Description P-DW-06 **Collected:** 10/31/2021 **Lab ID:** 012112496-0020
 Trainer's Office - Ice Machine 7:56:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:07

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-04 School Store - Sink		Collected: 10/31/2021 7:57:00 AM		Lab ID: 012112496-0021	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.09	1.00 µg/L	11/4/2021 KB	11/5/2021 JW 15:49
Client Sample Description P-DW-42 Girls PE Office - Sink		Collected: 10/31/2021 7:59:00 AM		Lab ID: 012112496-0022	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:15
Client Sample Description P-DW-10A Girls Locker Room (Filler)		Collected: 10/31/2021 8:02:00 AM		Lab ID: 012112496-0023	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.17	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:20
Client Sample Description P-DW-10B Girls Locker Room (Cooler)		Collected: 10/31/2021 8:03:00 AM		Lab ID: 012112496-0024	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:21
Client Sample Description P-DW-44 Boys PE Office- Sink		Collected: 10/31/2021 8:03:00 AM		Lab ID: 012112496-0025	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.58	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description		P-DW-09A Boys Locker Room (Filler)	Collected:		10/31/2021 8:06:00 AM	Lab ID:		012112496-0026
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	6.31	1.00 µg/L	11/4/2021	KB	11/4/2021 20:24	KB	
Client Sample Description		P-DW-09B Boys Locker Room (Cooler)	Collected:		10/31/2021 8:07:00 AM	Lab ID:		012112496-0027
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	3.48	1.00 µg/L	11/4/2021	KB	11/4/2021 20:26	KB	
Client Sample Description		P-DW-29 Kitchen - Ice Machine	Collected:		10/31/2021 8:07:00 AM	Lab ID:		012112496-0028
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	11/4/2021	KG	11/5/2021 15:51	JW	
Client Sample Description		P-DW-30 Kitchen - Steam Kettle	Collected:		10/31/2021 8:14:00 AM	Lab ID:		012112496-0029
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	10.3	1.00 µg/L	11/4/2021	KB	11/4/2021 20:30	KB	
Client Sample Description		P-DW-20 Kitchen - Sink #1	Collected:		10/31/2021 8:17:00 AM	Lab ID:		012112496-0030
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.90	1.00 µg/L	11/4/2021	KB	11/4/2021 20:31	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-22
 Kitchen - Sink #2
Collected: 10/31/2021
 8:18:00 AM
Lab ID: 012112496-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:33

Client Sample Description P-DW-24
 Kitchen - Sink #3
Collected: 10/31/2021
 8:18:00 AM
Lab ID: 012112496-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.34	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:34

Client Sample Description P-DW-26
 Kitchen - Sink #4
Collected: 10/31/2021
 8:19:00 AM
Lab ID: 012112496-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.25	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:36

Client Sample Description P-DW-28
 Kitchen - Sink #5
Collected: 10/31/2021
 8:19:00 AM
Lab ID: 012112496-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.5	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:40

Client Sample Description P-DW-18A
 Cafeteria (Filler)
Collected: 10/31/2021
 8:20:00 AM
Lab ID: 012112496-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.01	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description		P-DW-18B Cafeteria (Cooler)	Collected:	10/31/2021 8:23:00 AM	Lab ID:	012112496-0036	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	1.56	1.00 µg/L	11/4/2021	KB	11/4/2021 20:43	KB
Client Sample Description		P-DW-11A Hall Near Gym (Filler)	Collected:	10/31/2021 8:23:00 AM	Lab ID:	012112496-0037	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	11/4/2021	KB	11/4/2021 20:51	KB
Client Sample Description		P-DW-11B Hall Near Gym (Cooler)	Collected:	10/31/2021 8:26:00 AM	Lab ID:	012112496-0038	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	11/4/2021	KB	11/4/2021 20:52	KB
Client Sample Description		P-DW-39A Hall Near JR High Boys Bathroom (Filler)	Collected:	10/31/2021 8:26:00 AM	Lab ID:	012112496-0039	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	11/4/2021	KB	11/4/2021 20:53	KB
Client Sample Description		P-DW-39B Hall Near JR High Boys Bathroom (Cooler)	Collected:	10/31/2021 8:28:00 AM	Lab ID:	012112496-0040	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	1.17	1.00 µg/L	11/4/2021	KB	11/4/2021 20:55	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-12A
 Hall Near Room 13 (Filler) **Collected:** 10/31/2021
 8:31:00 AM **Lab ID:** 012112496-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.11	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:56

Client Sample Description P-DW-12B
 Hall Near Room 13 (Cooler) **Collected:** 10/31/2021
 8:31:00 AM **Lab ID:** 012112496-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.17	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 20:58

Client Sample Description P-DW-17A
 Hall Near Cafeteria (Filler) **Collected:** 10/31/2021
 8:34:00 AM **Lab ID:** 012112496-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.34	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:52

Client Sample Description P-DW-17B
 Hall Near Cafeteria (Cooler) **Collected:** 10/31/2021
 8:34:00 AM **Lab ID:** 012112496-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.50	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:59

Client Sample Description P-DW-49
 Room 113 Sink #1 **Collected:** 10/31/2021
 8:37:00 AM **Lab ID:** 012112496-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	63.3	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-51
 Room 113 Sink #2
Collected: 10/31/2021
 8:38:00 AM
Lab ID: 012112496-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:02

Client Sample Description P-DW-53
 Room 113 Sink #3
Collected: 10/31/2021
 8:38:00 AM
Lab ID: 012112496-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.2	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:04

Client Sample Description P-DW-55
 Room 113 Sink #4
Collected: 10/31/2021
 8:38:00 AM
Lab ID: 012112496-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	38.9	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:05

Client Sample Description P-DW-57
 Room 113 Sink #5
Collected: 10/31/2021
 8:39:00 AM
Lab ID: 012112496-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:07

Client Sample Description P-DW-59
 Room 113 Sink #6
Collected: 10/31/2021
 8:39:00 AM
Lab ID: 012112496-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.0	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description		P-DW-61 Room 113 Sink #7	Collected:		10/31/2021 8:39:00 AM	Lab ID:		012112496-0051
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	20.7	1.00 µg/L	11/4/2021	KB	11/4/2021 22:10	KB	
Client Sample Description		P-DW-46 Teacher's Lounge- Sink	Collected:		10/31/2021 8:49:00 AM	Lab ID:		012112496-0052
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	6.78	1.00 µg/L	11/4/2021	KB	11/4/2021 22:11	KB	
Client Sample Description		P-DW-47 Teacher's Lounge- Next to Refrigerator	Collected:		10/31/2021 8:57:00 AM	Lab ID:		012112496-0053
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	41.9	1.00 µg/L	11/4/2021	KB	11/4/2021 22:19	KB	
Client Sample Description		P-DW-13A Hall By Room 16 (Filler)	Collected:		10/31/2021 9:01:00 AM	Lab ID:		012112496-0054
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	11.9	1.00 µg/L	11/4/2021	KB	11/4/2021 22:23	KB	
Client Sample Description		P-DW-13B Hall By Room 16 (Cooler)	Collected:		10/31/2021 9:01:00 AM	Lab ID:		012112496-0055
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	15.4	1.00 µg/L	11/4/2021	KB	11/4/2021 22:24	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-14A
 Hall By Room 117 (Filler) **Collected:** 10/31/2021
 9:02:00 AM **Lab ID:** 012112496-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.57	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:26

Client Sample Description P-DW-14B
 Hall By Room 117 (Cooler) **Collected:** 10/31/2021
 9:02:00 AM **Lab ID:** 012112496-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.59	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:27

Client Sample Description P-DW-40A
 Hall By Room 217 (Filler) **Collected:** 10/31/2021
 9:03:00 AM **Lab ID:** 012112496-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.31	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:29

Client Sample Description P-DW-40B
 Hall By Room 217 (Cooler) **Collected:** 10/31/2021
 9:03:00 AM **Lab ID:** 012112496-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 22:33

Client Sample Description P-DW-63
 Library - Utility/ Alarm Room **Collected:** 10/31/2021
 9:10:00 AM **Lab ID:** 012112496-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	417 D	10.0 µg/L	11/4/2021 KB	11/5/2021 KB 14:35

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-65
 Librarians Office - Faucet
Collected: 10/31/2021
 9:13:00 AM
Lab ID: 012112496-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.33	1.00 µg/L	11/4/2021 KG	11/5/2021 JW 15:54

Client Sample Description P-DW-64A
 Library Near Girls Bathrom (filler)
Collected: 10/31/2021
 9:14:00 AM
Lab ID: 012112496-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.87	1.00 µg/L	11/4/2021 KB	11/5/2021 KB 14:36

Client Sample Description P-DW-64B
 Library Near Girls Bathrom (Cooler)
Collected: 10/31/2021
 9:14:00 AM
Lab ID: 012112496-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.34	1.00 µg/L	11/4/2021 KB	11/5/2021 KB 14:37

Client Sample Description P-DW-68
 Library - Exam Room #1
Collected: 10/31/2021
 9:16:00 AM
Lab ID: 012112496-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.48	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:07

Client Sample Description P-DW-69
 Library - Exam Room #2
Collected: 10/31/2021
 9:16:00 AM
Lab ID: 012112496-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.16	1.00 µg/L	11/4/2021 KG	11/5/2021 JW 15:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012112496

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
Fax: (856) 848-0838
Received: 11/1/2021 02:40 PM

Project: 94015-65/ Paulsboro High School

Analytical Results

Client Sample Description P-DW-66
Parenting Center- Sink
Collected: 10/31/2021
9:17:00 AM
Lab ID: 012112496-0066

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:11

Client Sample Description P-DW-67
Parenting Center- Conf Room
Collected: 10/31/2021
9:17:00 AM
Lab ID: 012112496-0067

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.04	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:13

Client Sample Description 211031-P-BLANK
Blank
Collected: 10/31/2021
9:19:00 AM
Lab ID: 012112496-0068

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/4/2021 KB	11/4/2021 KB 21:14

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results



Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

012112496

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Company: Horizon Environmental Group, Inc.		EMSL-Bill to: <input type="checkbox"/> Different <input checked="" type="checkbox"/> Same If Bill to is Different note instructions in Comments**	
Street: P. O. Box 316		Third Party Billing requires written authorization from third party	
City: Thorofare	State/Province: NJ	Zip/Postal Code: 08086	Country: US
Report To (Name): David Flanigan		Telephone #: 856-848-0800	
Email Address: horizonenvgroup@gmail.com		Fax #: 856-848-0838	Purchase Order:
Project Name/Number: 94015-65 / Paulsboro High School		Please Provide Results: <input type="checkbox"/> FAX <input checked="" type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: NJ		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week
*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide			
Matrix	Method	Instrument	Reporting Limit
Chips <input type="checkbox"/> % by wt. <input type="checkbox"/> mg/cm ² <input type="checkbox"/> ppm	SW846-7000B	Flame Atomic Absorption	0.01%
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter
	NIOSH 7300 modified	ICP-AES/ICP-MS	0.5 µg/filter
Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM <input type="checkbox"/> *If no box is checked, non-ASTM Wipe is assumed	SW846-7000B	Flame Atomic Absorption	10 µg/wipe
	SW846-6010B or C	ICP-AES	1.0 µg/wipe
	SW846-7000B/7010	Graphite Furnace AA	0.075 µg/wipe
TCLP	SW846-1311/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW846-1131/SW846-6010B or C	ICP-AES	0.1 mg/L (ppm)
Soil	SW846-7000B	Flame Atomic Absorption	40 mg/kg (ppm)
	SW846-7010	Graphite Furnace AA	0.3 mg/kg (ppm)
	SW846-6010B or C	ICP-AES	2 mg/kg (ppm)
Wastewater Unpreserved <input type="checkbox"/> Preserved with HNO ₃ pH < 2 <input type="checkbox"/>	SM3111B/SW846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.7	ICP-AES	0.020 mg/L (ppm)
Drinking Water Unpreserved <input type="checkbox"/> Preserved with HNO ₃ pH < 2 <input checked="" type="checkbox"/>	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
TSP/SPM Filter	40 CFR Part 50	ICP-AES	12 µg/filter
	40 CFR Part 50	Graphite Furnace AA	3.6 µg/filter
Other:			
Name of Sampler: S FLANIGAN / D FLANIGAN		Signature of Sampler: <i>[Signature]</i>	
Sample #	Location	Volume/Area	Date/Time Sampled
1	P-PW-35A	HALL NEAR PRINCIPAL'S OFFICE (FLOOR)	10/31/21 0724
2	P-DW-35B	HALL NEAR PRINCIPAL'S OFFICE (CORROR)	0724
3	P-DW-33	NURSE'S OFFICE - NEAR HALL WALK	0728
4	P-DW-01	BOILER ROOM	0730
5	P-DW-34	NURSE'S OFFICE	0732
Client Sample #'s		Total # of Samples: 68	
Relinquished (Client): <i>[Signature]</i>	Date: 11/1/2021	Time: 2:40 pm	
Received (Lab): <i>[Signature]</i>	Date: 11-1-21	Time: 2:40 pm	
Comments:			

Eklipson 11/1/21 2:40pm

**LEAD (Pb) CHAIN OF CUSTODY**

EMSL ORDER ID (Lab Use Only):

012112496

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
6	P-DW-08A	HALL NEAR Room 5 (FILLER)	10/31/21 0735
7	P-DW-08B	HALL NEAR Room 5 (COVER)	0735
8	P-DW-36A	HALL NEAR Room 105 (FILLER)	0738
9	P-DW-36B	HALL NEAR Room 105 (COVER)	0738
10	P-DW-37A	HALL NEAR Room 205 (FILLER)	0740
11	P-DW-37B	HALL NEAR Room 205 (COVER)	0740
12	P-DW-62	Room 210 - TEACHER'S SINK	0745
13	P-DW-07A	HALL NEAR TRAINER'S OFFICE (FILLER)	0747
14	P-DW-07B	HALL NEAR TRAINER'S OFFICE (COVER)	0747
15	P-DW-31A	HALL NEAR Room 112 (FILLER)	0751
16	P-DW-31B	HALL NEAR Room 112 (COVER)	0751
17	P-DW-38A	HALL NEAR Room 211 (FILLER)	0753
18	P-DW-38B	HALL NEAR Room 211 (COVER)	0753
19	P-DW-70	TRAINER'S OFFICE - SINK	0756
20	P-DW-06	TRAINER'S OFFICE - ICE MACHINE	0757
21	P-DW-04	SCHOOL STORE - SINK	0759
22	P-DW-42	GIRLS PE OFFICE - SINK	0802
23	P-DW-10A	GIRLS LOCKER ROOM (FILLER)	0803
Comments/Special Instructions:			



LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

012112496

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
24	P-DW-10B	Girls Locker Room (Cooler)	10/31/21 0803
25	P-DW-44 P-DW-44	Boys PE Office - Sink	0806
26	P-DW-09A P-DW-09A	Boys Locker Room (Filler)	0807
27	P-DW-09B P-DW-09B	Boys Locker Room (Cooler)	0807
28	P-DW-29	Kitchen - Ice Machine	0814
29	P-DW-30	Kitchen - Sink Steam Kettle	0817
30	P-DW-20	Kitchen - Sink #1	0818
31	P-DW-22	Kitchen - Sink #2	0818
32	P-DW-24	Kitchen - Sink #3	0819
33	P-DW-26	Kitchen - Sink #4	0819
34	P-DW-28	Kitchen - Sink #5	0820
35	P-DW-18A	Cafeteria (Filler)	0823
36	P-DW-18B	Cafeteria (Cooler)	0823
37	P-DW-11A	Hall near Gym (Filler)	0826
38	P-DW-11B	Hall near Gym (Cooler)	0826
39	P-DW-39A	Hall near Jr High Boys Bathroom (Filler)	0828
40	P-DW-39B	Hall near Jr High Boys Bathroom (Cooler)	0828
41	P-DW-12A	Hall near Room 13 (Filler)	0831
Comments/Special Instructions:			



LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

012112496

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
42	P-DW-12B	HALL NEAR Room 13 (locker)	10/31/21 0831
43	P-DW-17A	HALL NEAR CAFETERIA (FLOOR)	0834
44	P-DW-17B	HALL NEAR CAFETERIA (locker)	0834
45	P-DW-49	Room 113- SINK #1	0837
46	P-DW-51	Room 113- SINK #2	0838
47	P-DW-53	Room 113- SINK #3	0838
48	P-DW-55	Room 113- SINK #4	0838
49	P-DW-57	Room 113- SINK #5	0839
50	P-DW-59	Room 113- SINK #6	0839 0840
51	P-DW-61	Room 113- SINK #7	0839 0840
52	P-DW- 53 46	TEACHER'S LOUNGE - SINK	0849
53	P-DW-47	TEACHER'S LOUNGE - NEXT TO REFRIGERATOR	0857
54	P-DW-13A	HALL BY Room 16 (FLOOR)	0901
55	P-DW-13B	HALL BY Room 16 (locker)	0901
56	P-DW-14A	HALL BY Room 117 (FLOOR)	0902
57	P-DW-14B	HALL BY Room 117 (locker)	0902
58	P-DW-40A	HALL BY Room 217 (FLOOR)	0903
59	P-DW-40B	HALL BY Room 217 (locker)	0903 0904
Comments/Special Instructions:			

012112496

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

