

JIMMY NEIL ANDERSON

Registered Architect Sustainable Design Construction Administrator

1 Anderson Trail Clifton, TN 38425

(731) 394-6565 Jima6565@hotmail.com

21 September 2023

To all Prospective Bidders:

RE: Wayne County Board of Education
FHS-CTE (Dollar General Building) Renovation
TFM# 03387-C Project #2023-07-03-01
506 Main Street
Clifton, TN 38425

Bid Addendum #2

Item 1. The existing wall construction separating the shop from the tool room is of 2x4 construction up to the roof girts. It is not necessary to demolish this wall and re-construct in metal studs. However, the spaces between the top plate of the existing wall framing and the girts must be infilled as shown on detail 2/A1.1, with metal studs, (1) layer 5/8" fire code gypsum board each side and fire caulk to the roof deck to meet the requirements of a 1 hour fire barrier.

Item 2. On the submission of approved Revision #2 on 8/9/23 to the State Fire Marshall, a determination was made that there is no need for 2 hour rated walls on this project. However, on Sheet A1.1 the wall separating the shop from the classroom corridor is still shown as 2 hour rated. This conflicts with its indication of 1 hour rated on Sheet A1.0. Therefore, both this wall and the wall indicated on Item 1 above are 1 hour rated and detail 2/A1.1 applies as indicated with (1) layer of 5/8" fire code gypsum board each side and fire caulked to the metal roof deck.

Item 3. A decision has been made that the Owner will have the existing pavement re-sealed and re-stripped. This work is not in contract. As stated in Addendum #1 the selected Contractor will be responsible for paving the new 12 foot wide driveway.

End of Bid Addendum #2.

