



## CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
500 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Broad Street Elementary, 255 W. Broad Street, Gibbstown, NJ  
**PAS Project ID :** P21-12966

**Matrix :** Drinking Water  
**Report Date :** 12/8/2021

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-12966-01	Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/3/21 05:58	12/6/21 16:02
P21-12966-02	BES-1-Kitchen-FP1-P	Lead	2.11	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/3/21 06:00	12/6/21 16:06
P21-12966-03	BES-1-Kitchen-FP1-F	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/3/21 06:01	12/6/21 16:10

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director



**CHAIN  
OF  
CUSTODY**

PROJECT #: 257-79

Customer: PARS Environmental  
 Address: 500 Horizon Drive, Suite 540  
 Robbinsville, NJ 08691  
 Phone: (609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name: Broad Street Elementary  
 School Address: 255 W. Broad Street, Gibbstown, NJ  
 Sampled By: *Mikulas Ceselka*  
 Print Name: *Mikulas Ceselka*  
 RESULTS TO: [JPerrini@montrose-env.com](mailto:JPerrini@montrose-env.com)

Sample #	Sample ID Location	Date/Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	FIELD BLANK	0558	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-12966-01
2	BES-1-KITCHEN-FPI-P	0600	DW	Grab	N	N	1	250 ml Plastic	Lead	↓ -02
3	BES-1-KITCHEN-FPI-F	0601	DW	Grab	N	N	1	250 ml Plastic	Lead	P21-12966-03
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB

PDF Std.  PDF Reduce  PDF Full  EDD   
 Date/Time Preserved with HNO3: \_\_\_\_\_

Page 1 of 1 Deliverables: X

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	<i>Mikulas Ceselka</i>		PARS	12/3/2021
Received:	<i>Robin Lee</i>		PARS	0916
Relinquished:				
Received:				
Relinquished:				
Received:				