



EAST CARTER COUNTY R-II SCHOOLS

Richard Sullivan, Superintendent
Matt Stahl, HS Principal

**24 SOUTH HERREN AVE
ELLSINORE, MO 63937
PHONE: 573-322-5625
FAX: 573-322-8586**

Corey Jameson, MS Principal
Kacie Kendrick, Elem Principal

Attached are the initial water test results for the school district.

East Carter has received the water test results back from the laboratory. Only 1 sample was out of parameter. Repairs are being made and will be retested.



Laboratory Results

<http://www.teklabinc.com/>

Client: Semo Compliance & Remediation

Report Date: 28-Jun-24

Client Project: DW Lead Analysis East Carter

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24061706-001A	A-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 11:28	06/15/2024 9:14
24061706-002A	A-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 11:31	06/15/2024 9:15
24061706-003A	A-3	NELAP		1.0	1.3	µg/L	1	06/24/2024 11:35	06/15/2024 9:17
24061706-004A	A-4	NELAP		1.0	3.1	µg/L	1	06/24/2024 11:38	06/15/2024 9:18
24061706-005A	A-5	NELAP		1.0	1.0	µg/L	1	06/24/2024 11:41	06/15/2024 9:19
24061706-006A	A-6	NELAP		1.0	1.7	µg/L	1	06/24/2024 11:45	06/15/2024 9:20
24061706-007A	A-7 ice	NELAP		1.0	3.3	µg/L	1	06/24/2024 11:48	06/15/2024 9:20
24061706-008A	B-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:12	06/15/2024 9:07
24061706-009A	B-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:15	06/15/2024 9:08
24061706-010A	B-3	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 11:51	06/15/2024 9:10
24061706-011A	B-4	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:19	06/15/2024 9:11
24061706-012A	B-5	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:22	06/15/2024 9:22
24061706-013A	B-6	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:26	06/15/2024 9:23
24061706-014A	B-7	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:29	06/15/2024 9:24
24061706-015A	B-8	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:32	06/15/2024 9:24
24061706-016A	B-9	NELAP		1.0	1.7	µg/L	1	06/24/2024 12:36	06/15/2024 9:27
24061706-017A	B-10	NELAP		1.0	2.2	µg/L	1	06/24/2024 12:39	06/15/2024 9:28
24061706-018A	B-11	NELAP		1.0	1.6	µg/L	1	06/24/2024 12:43	06/15/2024 9:29
24061706-019A	C-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 12:56	06/15/2024 9:46
24061706-020A	C-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:20	06/15/2024 9:47
24061706-021A	C-3	NELAP		1.0	2.0	µg/L	1	06/24/2024 13:00	06/15/2024 9:50
24061706-022A	C-4	NELAP		1.0	2.5	µg/L	1	06/24/2024 13:03	06/15/2024 9:50
24061706-023A	C-5	NELAP		1.0	2.6	µg/L	1	06/24/2024 13:06	06/15/2024 9:51
24061706-024A	C-6	NELAP		1.0	3.6	µg/L	1	06/24/2024 13:10	06/15/2024 9:51
24061706-025A	C-7	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:13	06/15/2024 9:52
24061706-026A	C-8	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:17	06/15/2024 9:53
24061706-027A	D-1	NELAP		1.0	1.6	µg/L	1	06/24/2024 13:40	06/15/2024 9:42
24061706-028A	D-2	NELAP		1.0	1.8	µg/L	1	06/24/2024 13:44	06/15/2024 9:43
24061706-029A	H-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:04	06/15/2024 10:37
24061706-030A	H-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:47	06/15/2024 10:38
24061706-031A	E-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:51	06/15/2024 9:57
24061706-032A	E-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:54	06/15/2024 9:58
24061706-033A	E-3	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 13:57	06/15/2024 9:59
24061706-034A	E-4	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:01	06/15/2024 10:01
24061706-035A	E-5	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:25	06/15/2024 10:02
24061706-036A	E-6	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:28	06/15/2024 10:04
24061706-037A	E-7	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:31	06/15/2024 10:04
24061706-038A	E-8	NELAP		1.0	1.1	µg/L	1	06/24/2024 14:35	06/15/2024 10:07
24061706-039A	E-9	NELAP		1.0	1.1	µg/L	1	06/24/2024 14:48	06/15/2024 10:08
24061706-040A	E-10	NELAP		1.0	2.0	µg/L	1	06/24/2024 14:38	06/15/2024 10:09
24061706-041A	E-11	NELAP		1.0	1.2	µg/L	1	06/24/2024 14:41	06/15/2024 10:09
24061706-042A	E-12	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 14:45	06/15/2024 10:10
24061706-043A	E-13	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 15:09	06/15/2024 10:10
24061706-044A	E-14 ice	NELAP		1.0	2.9	µg/L	1	06/24/2024 15:12	06/15/2024 10:12
24061706-045A	E-15	NELAP		1.0	2.0	µg/L	1	06/24/2024 15:15	06/15/2024 10:16
24061706-046A	E-16	NELAP		1.0	2.2	µg/L	1	06/24/2024 15:19	06/15/2024 10:16
24061706-047A	E-17	NELAP		1.0	1.9	µg/L	1	06/24/2024 15:22	06/15/2024 10:17
24061706-048A	E-18	NELAP		1.0	2.7	µg/L	1	06/24/2024 15:32	06/15/2024 10:17



Laboratory Results

<http://www.teklabinc.com/>

Client: Semo Compliance & Remediation

Report Date: 28-Jun-24

Client Project: DW Lead Analysis East Carter

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24061706-049A	J-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 15:26	06/15/2024 10:28
24061706-050A	J-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 15:29	06/15/2024 10:29
24061706-051A	F-1 ice	NELAP		1.0	3.0	µg/L	1	06/24/2024 15:53	06/15/2024 9:31
24061706-052A	F-2	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 15:56	06/15/2024 9:33
24061706-053A	F-3	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 15:59	06/15/2024 9:33
24061706-054A	F-4	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 16:03	06/15/2024 9:34
24061706-055A	F-5	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 16:06	06/15/2024 9:34
24061706-056A	I-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 16:10	06/15/2024 10:33
24061706-057A	I-2	NELAP		1.0	1.2	µg/L	1	06/24/2024 16:16	06/15/2024 10:34
24061706-058A	I-3	NELAP		1.0	9.8	µg/L	5	06/27/2024 11:00	06/15/2024 10:35
24061706-059A	N-1	NELAP		1.0	< 1.0	µg/L	1	06/24/2024 16:13	06/15/2024 10:24
24061706-060A	N-2	NELAP		1.0	2.9	µg/L	1	06/24/2024 16:37	06/15/2024 10:25
24061706-061A	N-3	NELAP		1.0	3.7	µg/L	1	06/24/2024 16:50	06/15/2024 10:25
24061706-062A	N-4	NELAP		1.0	2.8	µg/L	1	06/24/2024 16:54	06/15/2024 10:26