



**RFP : Intercom and Public Address System Replacement/Expansion
Addendum # 2 - Questions and Answers Not Included on Addendum # 1
Date Issued: 7-7-2026**

This Addendum forms part of the Contract Documents and modifies the original Request for Proposals (RFP) issued on June 15, 2026. All proposers are responsible for reviewing this Addendum and incorporating the information into their proposals.

Question 1:

Can you provide maps with indicators for where you would like speakers and call switches?

Answer:

Maps have been provided- we would like speakers and call switches in every classroom, and speakers in the hallways, restrooms, media center, offices, and cafeteria.

Question 2:

Do you know the number of speakers, call buttons, and paging phone sets that you currently have?

Answer:

There are two paging phones for the current intercom and they are both located in the front office. We currently have speakers in classrooms, media center, and cafeteria. The call buttons are not operational as far as we are aware.

Question 3:

How many zones/paging groups are you looking for at this time?

Answer:

We would like to be able to page each room individually, page only the high school, only the main building, and both buildings simultaneously.

Question 4:

What is your anticipated growth over the next 5 years for capacity?

Answer:

Within the next 5-10 years we anticipate adding more facilities containing classrooms.

Question 5:

What does administrative override capability look like to you? Would you like pre-recorded announcements available?

Answer:

No pre recorded announcements necessary. We would like to be able to override anything else in the case of an emergency.

Question 6:

Will the intercom system be able to cross and interact with the LAN or must it be a self-contained entity?

Answer:

Yes, it should be able to cross and interact with the LAN.

Question 7:

For old equipment removal, will access be given to throw anything away on site, or should all removals be carried offsite by the vendor?

Answer:

All removals should be taken care of by the vendor.

Question 8:

The target installation start date is July 22nd. The project completion requested date is August 31st. School begins on August 4th. What will the building availability be for installation?

Answer:

As long as the vendor is able to abide by our check-in guidelines, work could happen during the school day in the hallways, bathrooms, gym, and media center. Classrooms and the lunchroom would be available after 3:40pm, and on the weekends. We can arrange after hours access to the building.

Question 9:

Are you already in possession of the Centegix interface device? If so, what model is it, and has it been installed?

Answer:

Centegix gateways were installed the week of June 29th. The interface model is CE604L and it has not been installed. We anticipate the vendor installing the interface.

Question 10:

What are your anticipated uses for multi-campus paging? Would it be emergency broadcasting only, or are you looking to make multi-campus announcements regularly?

Answer:

We have daily morning announcements, dismissal, and campus wide announcements regularly.

All other terms and conditions of the RFP remain unchanged.

Acknowledgment of Addendum #2

Proposer Name: _____

Authorized Signature: _____

Date: _____
