

Water Testing Results – Clatskanie Elementary School
Action level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Teacher's Lounge	6168035-06	06/25/16	2.8 ppb
Drinking Fountain	6168035-07	7/1/16	2.2 ppb
Kitchen Sink	6168035-08	6/25/16	ND
Teacher's Lounge – East Wing	6168035-09	6/25/16	ND
Hallway Drinking Fountain	6168035-10	6/25/19	ND
ND = Non Detect – Lead level is below the set detection limits			