Marion County Board of Education

204 Betsy Pack Drive Jasper, Tennessee 37347

Dr. Mark A. Griffith Director of Schools Telephone (423) 942-3434 Brent A. Brown Director of Facilities Fax (423) 942-4210

REQUEST FOR PROPOSALS FOR WHITWELL MIDDLE SCHOOL HVAC UNIT THAT MEETS THE FOLLOWING SPECIFICATIONS

Notice to Bidders: The Board reserves the right to use judgment factors to determine which bid shall be in its best interest. Such judgment by the Board shall be final and binding upon all parties that submit a bid. The Board reserves the right to reject any or all bids and waive any informalities or irregularities in the bidding.

Location: Whitwell Middle School, 1 Butterfly Lane, Whitwell TN 37397

Description: New replacement HVAC unit (See attached specifications)

Bid Specifications: All prospective bidders must be licensed, insured, bonded and be in

compliance with all State bidding requirements. Proof of certificate of

liability insurance must be submitted prior to start.

Project Walk-Thru: If needed, bidders may contact Brent Brown, Director of Facilities, at

423-593-4012 for a project walk-thru at Whitwell Middle School.

Bid Price: Bid price must be fixed and firm.

Bid Deadline: 3:00 p.m. Central time, Wednesday June 25, 2025.

Bid Opening: 8:00 a.m. Central time, Thursday June 26, 2025 at the Marion County Board of

Education, 204 Betsy Pack Drive, Jasper TN 37347.

Required: Send as sealed bids marked "WMS HVAC Replacement" to the attention of:

Director of Finance
Marion County Board of Education
204 Betsy Pack Drive
Jasper, TN 37347

Include Company name, address, license number and expiration, and monetary insurance limits on sealed bid envelope.

Bid Specifications Whitwell Middle School HVAC Unit

14

Unit: 20 Ton package gas electric system (Trane model number YSK240A4S0H or comparable unit)

- Gas electric rooftop unit
- Louvered hail guard
- Custom curb adapter
- Digital thermostat

Pricing must include delivery and include all necessary installation kits, fittings, trim, etc.