



2024 Lead in Drinking Water Testing Summary

Campus: Middle School Gym, 620 SW Bryant St.

Fixture Location Description	CSD Fixture ID #	ODE Fixture ID #	Test Date	Test Result (ppb)
Drinking Fountain	MGYM-01	194500001-001DW	5/6/2024	0.0

All school districts, education service districts, and public charter schools in Oregon must test for and reduce exposure to elevated lead levels in water used for drinking and food preparation, as mandated by OAR 333-061-0400 and OAR 581-022-2223. Clatskanie School District adheres to these regulations by ensuring:

1. Water testing conforms to OAR 333-061-0400 specifications.
2. Samples are analyzed by Oregon Health Authority-accredited laboratories.
3. All mandated water fixtures are tested according to the Oregon Health Authority's scheduled timelines.
4. Any water fixture with lead levels of **15 parts per billion (ppb)** or higher will be immediately taken out of service.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/17/2024
Received: 05/07/2024
Sampled By: Jason Krause
Work Order: 4130024

C **Clatskanie School District**
L Attn: Will Seals
I 660 SW Byrant St
E Clatskanie OR, 97016
N Phone: (503) 734-7010
T

Project:
Project # : -
Sample Type :

Sampling Location: Middle School Gymnasium
Sample Matrix: Water

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4130024-01	Sample Name: MGYM-01						Matrix: Water
	Sampled: 5/6/24 8:38						
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 19:32

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director