Reginald A. Crenshaw, Ph.D., President, District 3 Sherry Dillihay-McDade, Vice President, District 4 Lonnie Parsons, District 1

Don Stringfellow, District 2 Johnny Hatcher, District 5

1 Magnum Pass, P.O. Box 180069, Mobile, Alabama 36618

Superintendent Chresal D. Threadgill

Purchasing Department Phone (251)221-4473 Fax (251)221-4472 purchasing.mcpss.com

Bid No. 25-33

Buyer: Julie Morgan

July 21, 2025

## ADDENDUM #1 INVITATION TO BID CULINARY EQUIPMENT – VARIOUS HIGH SCHOOLS – CAREER TECH

The bid opening date is Wednesday, July 30, 2025 @ 2:00 PM CST.

Please see the attached drawings for the bid. Please be sure to enlarge the drawings as needed. These drawings are to be included as part of the bid package and must be included in your bid proposal.

If you should have any questions, please contact the Purchasing Department.

Sincerely,

Russell Hudson Director of Purchasing

RH/jdm

allred

PROJECT NUMBER:

#2025-10 DRAWING TITLE:

KITCHEN HOOD **SCHEDULES** AND DETAILS

SHEET NUMBER:

MECHANICAL LEGEND CFM CUBIC FEET PER MINUTE MVD MANUAL VOLUME DAMPER PCD PERFORATED CEILING DIFFUSER TYP LARGER IN THE TURNING DIRECTION. DUCT CONNECTION OVER AIR DEVICE LOCKING QUADRANT REGULATOR. RECTANGULAR SUPPLY OR OUTSIDE AIR DUCT IN SECTION RECTANGULAR RETURN AIR DUCT IN SECTION

12"Ø CL 400 CFM AND AIRFLOW AS INDICATED. PROVIDE WITH SQUARE TO ROUND

NECK TRANSITION AS REQUIRED. 1 THERMOSTAT

SEE PLANS FOR DUCT

SIZE AND ROUTING

FACTORY FABRICATED FLEXIBLE ROUND DUCT. MAX LENGTH SHALL SQUARE THROAT ELBOW IN RECTANGULAR DUCTWORK WITH DOUBLE WALL TURNING VANES. PROVIDE FOR ALL DUCTWORK 12" AND BULLHEAD TEE WITH TURNING VANES AND SPLITTER DAMPER RECTANGULAR BRANCH DUCT TAKEOFF FROM RECTANGULAR MAIN DUCT. TAKEOFF SHALL BE MADE WITH A 45° COLLAR. SEE DETAIL. MANUAL VOLUME DAMPER IN RECTANGULAR DUCT. PROVIDE WITH RECTANGULAR EXHAUST AIR DUCT IN SECTION MANUAL VOLUME DAMPER (MVD) FIRE DAMPER WITH ACCESS DOOR (FD/AC) CEILING DIFFUSER WITH THROW INDICATORS. DIFFUSER SHALL BE SUITABLE FOR INSTALLATION IN GYPSUM OR LAY-IN CEILINGS. SIZE

MARK	TOTAL	TSP	MAX	TYPE	TYPE	CONTROL	INTERLOCK	MOTOR	MAX	ELEC	CTRICAL	DATA	DEMARKS
#	CFM	IN WC	RPM	DRIVE	FAN	55,,,,,,	WITH	HP/WATTS	SONES	VOLTS	Hz	PHASE	REMARKS
BRKEF#1	3118	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	BRKSF#1 HT SENSOR	2.0	16.0	208	60	3	1234
BRKSF#1	2580	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD Switch	2.0	25.0	208	60	3	1234
BKKEF#1	4400	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	BKKSF#1 HT SENSOR	1.5	16.0	208	60	1	1234
BKKSF#1	3700	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	1.5	25.0	208	60	1	1234
BLKEF#1	4400	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	BLKSF#1 HT SENSOR	2.0	16.0	208	60	3	1234
BLKSF#1	3700	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	2.0	25.0	208	60	3	1234
DKEF#1	5160	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	DKSF#1 HT SENSOR	2.0	16.0	240	60	1	1234
DKSF#1	4360	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	2.0	25.0	240	60	1	1234
MKEF#1	3118	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	MKSF#1 HT SENSOR	1.5	16.0	208	60	3	1234
MKSF#1	2580	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	1.5	25.0	208	60	3	1234
VKEF#1	4408	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	VKSF#1 HT SENSOR	2.0	16.0	208	60	3	1234
VKSF#1	3710	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	2.0	25.0	208	60	3	1234
WKEF#1	4400	1.5"	1750	BELT	ROOF MOUNTED	INTERM.	WKSF#1 HT SENSOR	2.0	16.0	208	60	3	1234
WKSF#1	3700	0.75"	1750	BELT	ROOF MOUNTED	INTERM.	HOOD SWITCH	2.0	25.0	208	60	3	1234

FAN SCHEDULE

- (1) PROVIDE WITH FAN SPEED CONTROLLER. CONTROLLER SHALL BE MOUNTED TO FAN.
- (2) PROVIDE WITH INTEGRAL DISCONNECT.
- (3) PROVIDE MOTOR WITH THERMAL OVERLOAD.
- (4) EQUIPMENT IS OWNER PROVIDED/CONTRACTOR INSTALLED. CONTRACTOR SHALL BE RESPONSIBLE FOR HANDLING, INSTALLATION AND CONNECTION OF UTILITIES. THIS INFORMATION IS PROVIDED FOR COORDINATION PURPOSES.

COMMERCIAL KITCHEN EXHAUST HOOD SCHEDULE								.E	
SCH00L	HOOD TYPE	MAX COOKING TEMPERATURE	HOOD DIMENSIONS			EXHAUST	SUPPLY	VOLTS	REMARKS
SCHOOL			LENGTH	WIDTH	HEIGHT	RATE	RATE		ILLIMAINS
DAVIDSON	WALL MOUNTED (1 SIDE)	600°F	24'	5'	1.5'	5160	4360	120	12
VIGOR	WALL MOUNTED (1 SIDE)	600°F	20.5'	5'	1.5'	4408	3710	120	12
BAKER BLOUNT WILLIAMSON	ISLAND (2 SIDES)	600°F	11'	5'	1.5'	4400	3700	120	12
BRYANT MONTGOMERY	WALL MOUNTED (1 SIDE)	600°F	14.5'	5'	1.5'	3118	2580	120	12

- 1) PROVIDE WITH INTERNAL FIRE SUPPRESSION CHEMICAL CABINET AND SUPPLY AIR PLENUMS.
- 2 EQUIPMENT IS OWNER PROVIDED/CONTRACTOR INSTALLED. CONTRACTOR SHALL BE RESPONSIBLE FOR HANDLING, INSTALLATION AND CONNECTION OF UTILITIES. THIS INFORMATION IS PROVIDED FOR

## KITCHEN HOOD AIR FLOW BALANCE SCHEDULE

ALMA BRYANT HIGH SCHOOL

BRKEF#1: 3118 CFM

BRKSF#1: 2580 CFM DIFFERENTIAL: 538 CFM

DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 4 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 720 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD, AS 83% OF EXHAUST (538 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

BAKER HIGH SCHOOL BKKEF#1: 4400 CFM

BKKSF#1: 3700 CFM

DIFFERENTIAL: 700 CFM DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 7 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR

FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 1260 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD. AS 85% OF EXHAUST (700 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

**BLOUNT HIGH SCHOOL** BLKEF#1: 4400 CFM

BLKSF#1: 3700 CFM

DIFFERENTIAL: 700 CFM

DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 6 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 1080 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD, AS 85% OF EXHAUST (700 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

DAVIDSON HIGH SCHOOL DKEF#1: 5160 CFM

DKSF#1: 4360 CFM

DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 8 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 1440 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD, AS 85% OF EXHAUST (800 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

MARY G. MONTGOMERY HIGH SCHOOL

MKEF#1: 3118 CFM

MKSF#1: 2580 CFM

DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 6 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 1080 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD, AS 83% OF EXHAUST (538 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

VIGOR HIGH SCHOOL

VKEF#1: 4408 CFM

VKSF#1: 3710 CFM

DIFFERENTIAL: 698 CFM DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 5 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 900 CFM. MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN

WILLIAMSON HIGH SCHOOL

WKEF#1: 4400 CFM

WKSF#1: 3710 CFM DIFFERENTIAL: 700 CFM DETERMINATION OF DIFFERENTIAL AIR FLOW AVAILABILITY: EXISTING CULINARY CLASSROOM HAS 5 EXISTING RANGES WITH INDIVIDUAL RESIDENTIAL STYLE EXHAUST HOODS/FANS. EXHAUST AIR FLOW RATES ARE 180 CFM (LOW SPEED) PER FAN. ACCORDINGLY, AIR FLOW AVAILABLE, AS A MINIMUM, IS 900 CFM, MAINTAINING AN AIR FLOW DIFFERENTIAL THROUGH THE NEW KITCHEN HOOD. AS 85% OF EXHAUST (698 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE

HOOD, AS 84% OF EXHAUST (698 CFM) PROVIDES FOR PROPER HOOD OPERATION WITHOUT IMPACTING OVERALL BUILDING PRESSURIZATION OF THE SCHOOL.

H.M. YONGE & ASSOCIATES, INC. CONSULTING ENGINEERS // EST. 1988 51 EAST GREGORY STREET 253 ST. ANTHONY STREET

PHONE: (850)434-2661

PENSACOLA, FLORIDA 32502 MOBILE, ALABAMA 36603

PHONE: (251)690-7446

TYPICAL FIRE SUPPRESION SYSTEM LAYOUT FOR TYPE 1 HOOD MANUFACTURER'S APPROVAL.

-LIQUID TIGHT EXHAUST DUCT PER NFPA 96.

/—KITCHEN CEILING

3/8"ø STEEL RODS WITH

CEILING HEIGHT.

- HIGH EFFICIENCY 2 STAGE, ALUMINUM, UL

CLASSIFIED, BAFFLE-TYPE GREASE FILTERS

TURNBUCKLES TO ROOF STRUCTURE

ENCLOSURE (ALL 3 SIDES).

COORDINATE WITH ACTUAL

MANUFACTURER PROVIDE CEILING

SEE PLAN FOR SIZE AND ROUTING.

SUPPORT ANGLE

1" FILTER —

FLEXIBLE DUCT

CONNECTION —

FASTEN CURB TO METAL

ROOF INSULATION ON

METAL DECK —

ROOF DECK (SEE ATTACHMENT

DETAILS BY MANUFACTURER) -

-MOUNT AT 78-80" AFF

WITH NFPA 96.

NOTES: 1. WIDTH OF HOOD SHALL BE 6" LARGER THAN LARGEST PIECE OF COOKING EQUIPMENT AND 12" LONGER THAN SUM OF COOKING

4. BOTH HOODS SHALL OPERATE SIMULTANEOUSLY SUCH THAT ALL SUPPLY AND EXHAUST FANS OPERATE AT SAME TIME.

6. PROVIDE HIGH TEMPERATURE SENSOR WITH HOOD CONTROLS TO SHUT-OFF POWER AND GAS SERVICE TO HOODS.

2. KITCHEN HOOD TO BE PROVIDED BY OWNER AND INSTALLED BY MECHANICAL CONTRACTOR.

CHEMICAL SYSTEM SUPPLY FANS SHALL SHUT DOWN AND EXHAUST FANS SHALL OPERATE.

REMOVABLE PITCHED GREASE

- 18 GA. STAINLESS STEEL ON

EXPOSED AND NON-EXPOSED

EQUIPMENT LENGTHS WITH CONSIDERATION GIVEN TO CLEARANCE BETWEEN COOKING EQUIPMENT HOOD SUPPLIER SHALL PROVIDE. AUTOMATIC

SHUT OFF, MANUAL RESET GAS VALVE SHALL NOT BE ELECTRONIC SOLENOID TYPE. GAS VALVE SHALL BE SPRING LOADED, MANUAL RESET

5. PROVIDE AN INTEGRAL THERMAL SENSOR WITH HOOD CONTROLS TO AUTOMATICALLY ACTIVATE FANS AS COOKING EQUIPMENT IS ENERGIZED.

7. PROVIDE ALL INTERCONNECTS AND RELAY CONTROL BOXES REQUIRED FOR HOOD CONTROL AND SPECIFICALLY FOR FIRE SUPPRESSION

TYPICAL TYPE I KITCHEN HOOD DETAIL NOT TO SCALE

-LIQUID TIGHT EXHAUST

DUCT PER N.F.P.A. 96

-3/8"ø STEEL RODS

WITH TURNBUCKLES TO STRUCTURE

←HIGH EFFICIENCY 2

STAGE GREASE FILTERS

3. A CHEMICAL FIRE SUPPRESSION SYSTEM SHALL BE INCLUDED AS AN INTEGRAL PART OF THE HOOD SYSTEM. UPON ACTIVATION OF

SURFACES IN ACCORDANCE

TRAY WITH 1/2 PINT CUP.

## CONSTRUCTED IN ACCORDANCE STEEL ROOF ∠CONTINUOUS SUPPORT WITH N.F.P.A. 96 — ANGLE ∽GREASE CUP SEE PLANS FOR DUCT -VAPOR PROOF LIGHTS SIZE AND ROUTING COORDINATE OPENING - LIQUID TIGHT HOOD IN ROOF WITH THE GENERAL CONTRACTOR — EXHAUST DUCT PER GENERAL CONTRACTOR -NFPA 96 6'-8" ABOVE FINISHED FLOOR — NOTE: ATTACHMENT OF THE FAN TO THE CURB AND ATTACHMENT NOTE: ATTACHMENT OF THE FAN TO THE CURB AND ATTACHMENT OF THE CURB TO THE ROOF DECK SHALL COMPLY WITH THE FAN OF THE CURB TO THE ROOF DECK SHALL COMPLY WITH THE FAN MANUFACTURERS TESTED ATTACHMENT METHODS FOR THE 160 MPH MANUFACTURERS TESTED ATTACHMENT METHODS FOR THE 160 MPH COORDINATE HOOD TYPE AND SIZE WITH OWNER AND KITCHEN EQUIPMENT PROVIDER WIND LOADING CRITERIA. PRIOR TO INSTALLATION. TYPICAL KITCHEN HOOD DETAIL KITCHEN HOOD EXHAUST FAN DETAIL KITCHEN HOOD SUPPLY FAN DETAIL NOT TO SCALE NOT TO SCALE MEDIUM PRESS. PLENUM PROTECTION--3/8" DIA. ALL THREAD INLET DUCT CONN.-STEEL SUPPORT RODS TO BUILDING ROOF STRUCTURE ∠VAV TERMINAL NOZZLE - HOT WATER DETECTORS COIL TWO-WAY PRESSURE DEPENDENT VALVE VENT SUPPLY (THREE-WAY AT END OF Ductwork 🗦 HOT WATER PIPING RUNS)—— AUTOMATIC FLOW APPLIANCE PROTECTION

REMOTE MANUAL PULL STATION

(REFER TO PLANS FOR

REMOVABLE STAINLESS STEEL

LOCATION)

SERVICE DOOR

AGENT TANK -

OEM RELEASE/ BRACKET -

ASSEMBLY

1. THE ENTIRE HOT WATER COIL ASSEMBLY WITH ALL HOT WATER PIPING FROM THE TWO WAY VALVE SHALL BE INSULATED. PROVIDE EXTERIOR DUCT INSULATION ON COIL ASSEMBLY AND 1" THICK FIBERGLASS WITH ALL SERVICE JACKET ON PIPING.

- STRAINER W/ BLOWDOWN, HOSE

CONNECTION AND CAP

— PETE'S PLUG

SEE VAV UNIT SCHEDULE FOR

HOT WATER FLOW IN GPM

VAV BOX WITH REHEAT COIL DETAIL

- 3/8" DIA. ALL THREAD

— HEATING COIL

 $\circ$ 

 $\bigcirc$ 

-24" MAXIMUM

- BLACK IDENTIFICATION TAG WITH

1/4" WHITE LETTERING AFFIXED TO THE NEAREST CEILING GRID

NOTE: SERVICE ACCESS FOR POWER AND

CONTROL PANELS MUST BE COORDINATED

VAV BOX DETAIL

WITH OTHER TRADES.

NOT TO SCALE

FASTEN CURB TO METAL

ROOF INSULATION ON

METAL DECK —

STEEL ROOF

COORDINATE OPENING

CONTROL VALVE -

NOTES:

NOT TO SCALE

IN ROOF WITH THE

JOISTS —

ROOF DECK (SEE ATTACHMENT

DETAILS BY MANUFACTURER)

ABOVE CEILING

MEDIUM PRESSURE

SU<del>PP</del>LY DUCT

STEEL SUPPORT RODS

TO BUILDING ROOF STRUCTURE

LOW PRESSURE

SUPPLY DUCT

MAKE-UP AIR BRANCH DUCT-

MANUAL VOLUME DAMPER -

LAMINAR FLOW SUPPLY AIR

PERFORATED DISCHARGE

100 WATT UL LISTED -

MOUNT LIGHTS ON 3'-0"

INCANDESCENT LIGHTS WITH

PREWIRED JUNCTION BOXES.

6'-8" ABOVE ----

EQUIPMENT CONTROL SYSTEM.

MAKE-UP AIR SUPPLY DUCT

FROM SUPPLY AIR SYSTEM-

MANUAL VOLUME DAMPER-

PERFORATED SUPPLY PLENUM -

STAINLESS STEEL KITCHEN HOOD

KITCHEN CEILING \

FINISHED FLOOR

PLENUM (TYPICAL)

CENTERS.

- SPUN ALUMINUM UPBLAST

EXHAUST FAN

- MANUFACTURER'S

- FACTORY BUILT 18"

TIE-DOWNS

ROOF CURB

PER MECHANICAL PLAN

KITCHEN CEILING-

NOTE: ALTERNATE CHEMICAL SYSTEMS ARE ACCEPTABLE SUBJECT TO UL CERTIFICATION AND


NOZZLE


CONTROL PANEL

OPTIONAL PRE-WIRED ELECTRICAL TERMINAL BOX

OVERLOADS (IF APPLICABLE)

WITH TERMINAL STRIPS, 3-PHASE CONTACTORS AND





1 BAKER - RENO PLAN RK-A1.7 1/4" = 1'-0"

CULINARY RENOVATION NOTES:

SEE EQUIPMENT LIST SHEET FOR INFORMATION ON EQUIPMENT. EXISTING EQUIPMENT

NEW EQUIPMENT

2. CONTRACTOR IS TO PROVIDE TEMPORARY WALL BETWEEN WORK AREA AND ADJACENT CLASSROOM WHERE NOT SEPARATED BY A WALL I.E. MGM & DAVIDSON

3. STAINLESS STEEL SHEETS 48" HIGH ABOVE SINK AND THE WIDTH OF THE SINK ARE TO BE MOUNTED TO THE WALL(S) AT MOP SINKS.

4. STAINLESS STEEL SHEETS ARE TO BE MOUNTED TO THE WALLS BEHIND RANGES. HEIGHT TO BE FROM FLOOR TO HOOD AND THE FULL WIDTH OF THE HOODS.

5. CONTRACTOR IS RESPONSIBLE FOR THE DEMOLITION OF THE EXISTING CASEWORK AND HOODS.

6. EXISTING LIGHTS/SMOKE DETECTORS/SPRINKLERHEADS/ETC. ARE TO BE REMOVED, PROTECTED AND INTO NEW CEILINGS. SEE MEP SHEETS FOR ADDITIONAL INFO.

7. IN AREAS WHERE WALLS/CASEWORK/FURRING/ETC. ARE REMOVED - REMAINING SURFACES ARE TO BE REPAIRED AND PREPARED TO RECEIVE NEW FINISHES.

8. WALL PAINT - BOTTOM CMU COURSE AT THE ENTIRE ROOM AND DOOR FRAME PAINT ARE TO BE AN ACCENT COLOR (COLOR-TBD PER SCHOOL).

FINISH SCHEDULE EXISTING VCT & SHEET FLOORING
TO BE REMOVED. CLEAN & PREP
FOR NEW FLOORING

NEW VCT FLOORING TO BE PROVIDED & INSTALLED.
NEW VCT FLOORING TO BE PROVIDED & I CLEAN & PREP FOR NEW PAINT. NEW PAINT AT ALL WALLS & DOORS NEW CEILING GRID & TILE TO BE PROVIDED & INSTALLED. REMOVE CEILING TILES & GRID.

EXISTING CHASE AT HOODS REMOVED & REPLACED WALLS TO BE CLEANED, REPAIRED, PREPARED AND PAINTED EXISTING WALL TO BE XISTING BASE CASEWORK EXISTING SHEET FLOORING TO BE REMOVED & REPLACED — EXISTING VCT FLOORING TO BE REMOVED & REPLACED

SEE PLANS FOR ADDITIONAL NOTES



PROJECT NUMBER:

SCHOOL

REVI

MOBI

ARCHITECT OF RECORD:

711 CHURCH STREET

OCEAN SPRINGS, MS 39564

ISSUE DATE:

6-23-2025

**REVISIONS:** 


DESCRIPTION


DATE


#2025-10 DRAWING TITLE:

**BAKER PLANS** 

SHEET NUMBER:







3 BR-1.1 ALMA BRYANT - LIFE SAFETY PLAN 1/4" = 1'-0"


	EXISTING	NEW
FLOOR	EXISTING VCT TO BE REMOVED. CLEAN & PREP FOR NEW FLOORING.	NEW VCT FLOORING TO BE PROVIDED & INSTALLED. NEW VCT FLOORING IS TO HAVE 3 COATS OF WAX.
WALLS	CLEAN & PREP FOR NEW PAINT.	NEW PAINT AT ALL WALLS & DOORS
CEILING	REMOVE CEILING TILES & GRID.	NEW CEILING GRID & TILE TO BE PROVIDED & INSTALLED.


CULINARY RENOVATION NOTES:
SEE EQUIPMENT LIST SHEET FOR INFORMATION ON EQUIPMENT.
EXISTING EQUIPMENT
NEW EQUIPMENT
2. CONTRACTOR IS TO PROVIDE TEMPORARY WALL BETWEEN WORK AREA AND ADJACENT CLASSROOM WHERE NOT SEPARATED BY A WALL I.E. MGM & DAVIDSON
3. STAINLESS STEEL SHEETS 48" HIGH ABOVE SINK AND THE WIDTH OF THE SINK ARE TO BE MOUNTED TO THE WALL (S) AT MOP SINKS.
4. STAINLESS STEEL SHEETS ARE TO BE MOUNTED TO THE WALLS BEHIND RANGES. HEIGHT TO BE FROM FLOOR TO HOOD AND THE FULL WIDTH OF THE HOODS.
5. CONTRACTOR IS RESPONSIBLE FOR THE DEMOLITION OF THE EXISTING CASEWORK AND HOODS.
6. EXISTING LIGHTS/SMOKE DETECTORS/SPRINKLERHEADS/ETC. ARE TO BE REMOVED, PROTECTED AND INTO NEW CEILINGS. SEE MEP SHEETS FOR ADDITIONAL INFO.
7. IN AREAS WHERE WALLS/CASEWORK/FURRING/ETC. ARE REMOVED - REMAINING SURFACES ARE TO BE REPAIRED AND PREPARED TO RECEIVE NEW FINISHES.
8. WALL PAINT - BOTTOM CMU COURSE AT THE ENTIRE ROOM AND DOOR FRAME PAINT ARE TO BE AN ACCENT COLOR (COLOR-TBD PER SCHOOL).

CULINARY DEMOLITION KEY NOTES:	A
A. EXISTING CASEWORK TO BE REMOVED BY CONTRACTOR. B. EXISTING FURRING TO BE REMOVED.	
C. EXISTING CEILING TO BE REMOVED. LIGHTS ARE TO BE PROTECTED AND REINSTAL	
D. EXISTING WALL IS TO BE REMOVED. ADJACENT WALLS ARE TO BE CLEANED & PREI E. EXISTING FLOORING IS TO BE REMOVED AND SUBSURFACE CLEANED & PREPARED	
CIII INARY GENERAL NOTES:	
CULINARY GENERAL NOTES:	
CULINARY GENERAL NOTES:  • ALL EXISTING FIXTURES & EQUIPMENT TO REMAIN AND/OR TO BE REUSED IS TO BE	REMOVED BY THE
ALL EXISTING FIXTURES & EQUIPMENT TO REMAIN AND/OR TO BE REUSED IS TO BE CONTRACTOR, PROTECTED & REINSTALLED. I.E. PHONES, STROBES, SOAP DISPEN	SERS, ETC.
ALL EXISTING FIXTURES & EQUIPMENT TO REMAIN AND/OR TO BE REUSED IS TO BE	SERS, ETC. E CABINETS/ MOVABLE

RANGES. SEE NOTES FOR EACH SCHOOL TO INDICATE DEMO OR REUSE OF RANGES.

HOODS - EXISTING HOODS ARE TO BE REMOVED. EXISTING ROOF OPENINGS ARE TO BE COVERED WITH





ALABAMA DEPARTMENT OF FINANCE, REAL PROPERTY MANAGEMENT DIVISION OF CONSTRUCTION MANAGMENT STATE BUILDING CODES (ADOPTED) 2021 INTERNATIONAL EXISTING BUILDING CODE 2021 INTERNATIONAL PLUMBING CODE 2021 INTERNATIONAL FUEL GAS CODE 2021 INTERNATIONAL MECHANICAL CODE 2020 NATIONAL ELECTRICAL CODE (NFPA 70) 2021 INTERNATIONAL FIRE CODE ANSI/ASHRAE/IES STANDARD 90.1-2013 ENERGY STANDARD FOR BUILDINGS EXCEPT LOW-RISE RESIDENTIAL BUILDINGS, WITH EXCEPTIONS PERMITTED 6.5.1 - ECONOMIZERS 8.4.2 - AUTOMATIC RECEPTACLE CONTROL 8.4.3 - ELECTRICAL ENERGY MONITORING 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN (THESE REQUIREMENTS SUPERSEDE THE ACCESSIBILITY REQUIREMENTS CONTAINED IN THE INTERNATIONAL BUILDING CODE AND ANSI A117.1.) ANSI/ASHRAE/IESNA STANDARD 90.1-2013 ENERGY STANDARD FOR BUILDINGS EXCEPT LOW-RISE RESIDENTIAL

EXISTING FURRING
TO BE REMOVED

EXISTING WALL &
BASE CASEWORK
TO BE REMOVED


WALLS TO BE CLEANED,
REPARED,
AND PAINTED

EXISTING FLOORING TO
BE REMOVED & REPLACED


OCCUPANT LOAD: SHOPS AND OTHER VOCATIONAL AREAS 50 NET





OCCUPANCY TYPE: E- EDUCATION



2 ALMA BRYANT - RENO PLAN BR-1.1 1/4" = 1'-0"







MCPSS CULINARY ARTS RENOVATIONS
MOBILE COUNTY PUBLIC SCHOOL SYSTEM

allred stolarski architects

711 CHURCH STREET OCEAN SPRINGS, MS 39564

15SUE DATE: 6-23-2025

REVISIONS :

NO. DATE DESCRIPTION


#2025-10


DRAWING TITLE:

ALMA BRYANT PLANS

SHEET NUMBER:

BR-I.





FINISH SCHEDULE					
	EXISTING	NEW			
FLOOR	EXISTING LVT & SHEET FLOORING TO BE REMOVED. CLEAN & PREP FOR NEW FLOORING.	NEW LVT FLOORING TO BE PROVIDED & INSTALLED. NEW LVT FLOORING IS TO HAVE 3 COATS OF WAX.			
WALLS	CLEAN & PREP FOR NEW PAINT.	NEW PAINT AT ALL CULINARY & CLASSROOM WALLS & DOORS			
CEILING	REMOVE CEILING TILES & GRID.	NEW CEILING GRID & TILE TO BE PROVIDED & INSTALLED.			

CULINARY RENOVATION NOTES:

1. SEE EQUIPMENT LIST SHEET FOR INFORMATION ON EQUIPMENT.

EXISTING EQUIPMENT

NEW EQUIPMENT

2. CONTRACTOR IS TO PROVIDE TEMPORARY WALL BETWEEN WORK AREA AND ADJACENT CLASSROOM WHERE NOT SEPARATED BY A WALL I.E. MGM & DAVIDSON

3. STAINLESS STEEL SHEETS 48" HIGH ABOVE SINK AND THE WIDTH OF THE SINK ARE TO BE MOUNTED TO THE WALL(S) AT MOP SINKS.

4. STAINLESS STEEL SHEETS ARE TO BE MOUNTED TO THE WALLS BEHIND RANGES. HEIGHT TO BE FROM FLOOR TO HOOD AND THE FULL WIDTH OF THE HOODS.


5. CONTRACTOR IS RESPONSIBLE FOR THE DEMOLITION OF THE EXISTING CASEWORK AND HOODS.

6. EXISTING LIGHTS/SMOKE DETECTORS/SPRINKLERHEADS/ETC. ARE TO BE REMOVED, PROTECTED AND INTO NEW CEILINGS. SEE MEP SHEETS FOR ADDITIONAL INFO.


7. IN AREAS WHERE WALLS/CASEWORK/FURRING/ETC. ARE REMOVED - REMAINING SURFACES ARE TO BE REPAIRED AND PREPARED TO RECEIVE NEW FINISHES.

8. WALL PAINT - BOTTOM CMU COURSE AT THE ENTIRE ROOM AND DOOR FRAME PAINT ARE TO BE AN ACCENT COLOR (COLOR-TBD PER SCHOOL).

CULINARY DEMOLITION KEY NOTES:	A
A. EXISTING CASEWORK TO BE REMOVED BY CONTRACTOR. B. EXISTING FURRING TO BE REMOVED. C. EXISTING CEILING TO BE REMOVED. LIGHTS ARE TO BE PROTECTED AND REINSTALLED. D. EXISTING WALL IS TO BE REMOVED. ADJACENT WALLS ARE TO BE CLEANED & PREPARED FOR E. EXISTING FLOORING IS TO BE REMOVED AND SUBSURFACE CLEANED & PREPARED FOR NEW F	
CULINARY GENERAL NOTES:	
ALL EXISTING FIXTURES & EQUIPMENT TO REMAIN AND/OR TO BE REUSED IS TO BE REMOVED CONTRACTOR, PROTECTED & REINSTALLED. I.E. PHONES, STROBES, SOAP DISPENSERS, ETC. ALL EXISTING LOOSE EQUIPMENT I.E. COUNTERTOP APPLIANCES/ LOOSE STORAGE CABINETS/ TABLES & CARTS/ DESKS & CHAIRS/ ETC. WILL BE REMOVED FROM THE CLASSROOM BY MCPSS CONSTRUCTION. CONTRACTOR IS RESPONSIBLE FOR THE REMOVAL AND DEMO OR STORAGE/REINSTALLATION RANGES. SEE NOTES FOR EACH SCHOOL TO INDICATE DEMO OR REUSE OF RANGES.	MOVABLE S PRIOR TO OF THE
<ul> <li>HOODS - EXISTING HOODS ARE TO BE REMOVED. EXISTING ROOF OPENINGS ARE TO BE COVER INSULATED ALUMINUM CAP.</li> <li>WHERE EXISTING HOODS ARE REMOVED, THE CHASE/CASEWORK/UTILITIES/ETC. ARE TO BE REBE REMOVED IN ITS ENTIRETY.</li> <li>EXISTING FURRING OVER THE WALL CABINETS ARE TO BE REMOVED. REMAINING WALLS CLEAR PREPARED FOR NEW PAINT.</li> </ul>	EMOVED TO



3 EXISTING CONDITIONS - MGM NGM-1, 1/8" = 1'-0"





PROJECT NUMBER:


#2025-10


DRAWING TITLE:


MGM PLANS

SHEET NUMBER:

Addendum #1








TABLES & CARTS/ DESKS & CHAIRS/ ETC. WILL BE REMOVED FROM THE CLASSROOM BY MCPSS PRIOR TO CONSTRUCTION.
CONTRACTOR IS RESPONSIBLE FOR THE REMOVAL AND DEMO OR STORAGE/REINSTALLATION OF THE RANGES. SEE NOTES FOR EACH SCHOOL TO INDICATE DEMO OR REUSE OF RANGES.
HOODS - EXISTING HOODS ARE TO BE REMOVED. EXISTING ROOF OPENINGS ARE TO BE COVERED WITH INSULATED ALUMINUM CAP. WHERE EXISTING HOODS ARE REMOVED, THE CHASE/CASEWORK/UTILITIES/ETC. ARE TO BE REMOVED TO BE REMOVED IN ITS ENTIRETY. EXISTING FURRING OVER THE WALL CABINETS ARE TO BE REMOVED. REMAINING WALLS CLEANED AND PREPARED FOR NEW PAINT.

FINISH SCHEDULE				
	EXISTING	NEW		
FLOOR	EXISTING VCT	EXISTING VCT FLOORING IS TO BE CLEANED AND HAVE 3 COATS OF WAX APPLIED.		
WALLS	EXISTING FRP	REPLACE AND/OR PROVIDE FRP WHERE HOODS/RANGES ARE REMOVED.		
CEILING	VINYL CLAD ACT	REPLACE FRP WHERE HOODS/RANGES ARE REMOVED. REWORK GRID AT NEW HOOD.		

1. SEE EQUIPMENT LIST SHEET FOR INFORMATION ON EQUIPMENT.

2. CONTRACTOR IS TO PROVIDE TEMPORARY WALL BETWEEN WORK AREA AND ADJACENT CLASSROOM WHERE NOT SEPARATED BY A WALL I.E. MGM & DAVIDSON

3. STAINLESS STEEL SHEETS 48" HIGH ABOVE SINK AND THE WIDTH OF THE SINK ARE TO BE MOUNTED TO THE STAINLESS STEEL SHEETS 48" HIGH ABOVE SINK AND THE WIDTH OF THE SINK ARE TO BE MOUNTED TO THE WALL(S) AT MOP SINKS.
 STAINLESS STEEL SHEETS ARE TO BE MOUNTED TO THE WALLS BEHIND RANGES. HEIGHT TO BE FROM FLOOR TO HOOD AND THE FULL WIDTH OF THE HOODS.
 CONTRACTOR IS RESPONSIBLE FOR THE DEMOLITION OF THE EXISTING CASEWORK AND HOODS.
 EXISTING LIGHTS/SMOKE DETECTORS/SPRINKLERHEADS/ETC. ARE TO BE REMOVED, PROTECTED AND INTO NEW CEILINGS. SEE MEP SHEETS FOR ADDITIONAL INFO.
 IN ADEAS WHEED WALL SCASSWORK (SURPINIC/ETC. ARE DEMOVED. DEMAINING SURPACES ARE TO BE 7. IN AREAS WHERE WALLS/CASEWORK/FURRING/ETC. ARE REMOVED - REMAINING SURFACES ARE TO BE REPAIRED AND PREPARED TO RECEIVE NEW FINISHES. 3. WALL PAINT - BOTTOM CMU COURSE AT THE ENTIRE ROOM AND DOOR FRAME PAINT ARE TO BE AN ACCENCOLOR (COLOR-TBD PER SCHOOL).



## LIFE SAFETY PLAN LEGEND

AREA OCCUPANCY TAG

OCC.## AREA OCCUPANT LOAD

FIRE EXTINGUISHER CABINET MTD W/ HIGHEST OPERABLE PART @ 48" AFF MAX

FE WALL MOUNTED FIRE EXTINGUISHER

PULL STATION - KITCHEN HOOD FIRE PROTECTION SYSTEM

EMERGENCY LIGHTING - SEE ELECTRICAL LIGHTING PLAN, SHEET E100

PATH OF TRAVEL

ALABAMA DEPARTMENT OF FINANCE, REAL PROPERTY MANAGEMENT DIVISION OF CONSTRUCTION MANAGMENT


STATE BUILDING CODES (ADOPTED)

2021 INTERNATIONAL PLUMBING CODE 2021 INTERNATIONAL FUEL GAS CODE 2021 INTERNATIONAL MECHANICAL CODE 2020 NATIONAL ELECTRICAL CODE (NFPA 70) 2021 INTERNATIONAL FIRE CODE ANSI/ASHRAE/IES STANDARD 90.1-2013 ENERGY STANDARD FOR BUILDINGS


8.4.2 - AUTOMATIC RECEPTACLE CONTROL 8.4.3 - ELECTRICAL ENERGY MONITORING 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN (THESE REQUIREMENTS SUPERSEDE THE ACCESSIBILITY REQUIREMENTS


ANSI/ASHRAE/IESNA STANDARD 90.1-2013 ENERGY STANDARD FOR BUILDINGS EXCEPT LOW-RISE RESIDENTIAL


OCCUPANCY TYPE: E- EDUCATION OCCUPANT LOAD: SHOPS AND OTHER VOCATIONAL AREAS 50 NET



3 W-1.1 EXISTING CONDITIONS - WILLAIMSON 1/8" = 1'-0"







S MOBI ARCHITECT OF RECORD:

Addendum #1

711 CHURCH STREET OCEAN SPRINGS, MS 39564 ISSUE DATE: 6-23-2025

allred

**REVISIONS:** 

DATE DESCRIPTION

PROJECT NUMBER: #2025-10 DRAWING TITLE:

WILLIAMSON **PLANS** 

SHEET NUMBER: