



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/06/2016  
Received: 06/15/2016  
Sampled By:  
Work Order: 6168035

**C** Clatskanie, City of  
**L** Attn: Daniel Smith  
**I** 75 S Nehalem Ste D  
**E** Clatskanie OR, 97016  
**N** Phone: (503) 728-2622  
**T**

**Project:** Lead  
Project # : N/A  
PWSID # :

Sampling Location: Clatskanie Mid/High School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6168035-01</b>	<b>Sample Name:</b> 1 CMHS Kitchen		<b>Matrix:</b> Water				
	<b>Sampled:</b> 6/15/16 5:42		<b>Sample Composition:</b> Treated Source Single				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/25/16 15:53
<b>6168035-02</b>	<b>Sample Name:</b> 2 Boys Rest Room		<b>Matrix:</b> Water				
	<b>Sampled:</b> 6/15/16 5:44		<b>Sample Composition:</b> Treated Source Single				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/25/16 15:53
<b>6168035-03</b>	<b>Sample Name:</b> 3 Commons Drinking Fountain		<b>Matrix:</b> Water				
	<b>Sampled:</b> 6/15/16 5:46		<b>Sample Composition:</b> Treated Source Single				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/25/16 15:53
<b>6168035-04</b>	<b>Sample Name:</b> 4 Teachers Lounge		<b>Matrix:</b> Water				
	<b>Sampled:</b> 6/15/16 5:51		<b>Sample Composition:</b> Treated Source Single				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/25/16 15:53
<b>6168035-05</b>	<b>Sample Name:</b> 5 Auditorium Hallway		<b>Matrix:</b> Water				
	<b>Sampled:</b> 6/15/16 5:53		<b>Sample Composition:</b> Treated Source Single				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/25/16 15:53

ND = None detected at the MRL    MRL = Minimum Reporting Limit    MCL = Maximum Contamination Limit  
†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is an action level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.