

BIDDING & CONTRACT REQUIREMENTS

Addendum No. 1

DATE: APRIL 26, 2024

Pope County Community Unit School District #1  
125 State Highway 146 West  
Golconda, IL 62938

Asaturian, Eaton and Associates, Inc.  
1440 Old West Main St.  
Carbondale, IL 62901  
(618) 529-3414

TO: PROSPECTIVE BIDDERS

**SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR**

**Pope County Community Unit School District #1  
Sewage Treatment System**

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, dated April 9, 2024. Acknowledge receipt of this addendum in space provided on Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

\*\*\*\*\*

**PROJECT DRAWINGS:**

**1. Sheet C-4, Detail 1/C-4 Chlorination & Dechlorination Details**

Add the following notes:

- a. The design average flow is 4,000 gallons/day and design peak flow is 10,000 gallons/day. Flow is by gravity.
- b. The tablet chlorinator shall be Norweco Bio-Dynamic Model XT-2000 with adjustable sluice. The tablet dechlorinator shall be Norweco Bio-Dynamic Model L.F. 2000.
- c. Contractor shall provide a start up supply of 25 lbs. of chlorination tablets and 25 lbs. of dechlorination tablets.

**BID DATE:**

- 1. This Addendum does not alter the previously published bid date(s).

Very truly yours,



Armen Asaturian, P.E.

This addendum consists of 1 page.