

SECTION 009113 – ADDENDUM

PART 1 - Addendum 2

1.1 PROJECT INFORMATION

- A. Project Name: RFP 268 Roof, Tuckpointing at FCRC Building
- A. Owner: Riverview Gardens School District.
- B. Date of Addendum: 08/24/2022.

1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.

1.3 ADDITIONAL INFORMATION FOR SCOPE OF WORK

- B. **Change to the scope of work for the “Dome” roof:**
 - 1. Eliminate cover board.
 - 2. Install 60 Mil KEE FB in low rise foam adhesive to a properly prepared concrete deck.
 - 3. Contractor to issue 5-year warranty for workmanship.
 - 4. Manufacturer to issue 20-year material warranty.

END OF SECTION 009113