



2024 Lead in Drinking Water Testing Summary

Campus: **Elementary School**, 815 S. Nehalem St.

Fixture Location Description	CSD Fixture ID #	ODE Fixture ID #	Test Date	Test Result (ppb)
Nurse's Office Sink	CES-01	19450100-001NS	5/3/2024	4.6
Drinking Fountain – Nehalem Hallway	CES-02	19450100-002DW	5/3/2024	0.0
Drinking Fountain – Front of Library	CES-03	19450100-003DW	5/3/2024	0.0
Drinking Fountain – Playground	CES-04	19450100-004DW	5/3/2024	0.0
Kitchen – Three Compartment Sink	CES-05	19450100-005KF	5/3/2024	0.0
Kitchen – Soup Kettle 1	CES-06	19450100-006KF	5/3/2024	5.7
Kitchen – Soup Kettle 2	CES-07	19450100-007KF	5/3/2024	1.4
Cardiff – West Hall Drinking Fountain	CES-08	19450101-008DW	5/3/2024	0.0
Cardiff – Teachers' Work Room	CES-09	19450101-009SF	6/19/2025	0.0
Classroom 121 - Classroom Faucet	CES-10	19450100-010DW	5/3/2024	0.0
Classroom 201 - Classroom Faucet	CES-11	19450100-011CF	9/20/2024	0.0
Classroom 203 - Classroom Faucet	CES-12	19450100-012CF	9/20/2024	2.0
Classroom 204 - Classroom Faucet	CES-13	19450100-013CF	9/20/2024	0.0
Classroom 206 - Classroom Faucet	CES-14	19450100-014CF	9/20/2024	3.0
Classroom 207 - Classroom Faucet	CES-15	19450100-015CF	9/20/2024	2.0
Classroom 209 - Classroom Faucet	CES-16	19450100-016CF	9/20/2024	4.0
Classroom 4 - Classroom Faucet	CES-17	19450100-017CF	9/20/2024	9.0
Classroom 5 - Classroom Faucet	CES-18	19450100-018CF	6/19/2025	0.0
Classroom 6 - Classroom Faucet	CES-19	19450100-019CF	9/20/2024	5.0
Classroom 7 - Classroom Faucet	CES-20	19450100-020CF	9/20/2024	5.0
Classroom 9 - Classroom Faucet	CES-21	19450100-021CF	9/20/2024	5.0
Classroom 10 - Classroom Faucet	CES-22	19450100-022CF	9/20/2024	3.0
Classroom 11 - Classroom Faucet	CES-23	19450100-023CF	9/20/2024	4.0
Room 111 - Staff Lunchroom	CES-24	19450100-024SF	9/20/2024	2.0
Library Faucet	CES-25	19450100-025SF	9/20/2024	2.0
Classroom 121 - Classroom Faucet	CES-26	19450100-026CF	9/20/2024	0.0
Classroom 121 - Restroom Faucet	CES-27	19450100-027BF	9/20/2024	0.0
Classroom 18 - Cardiff	CES-28	19450101-028CF	6/19/2025	0.0
East Hallway Girls' Restroom - Left Sink	CES-29	19450101-029BF	9/20/2024	0.0
East Hallway Girls' Restroom - Right Sink	CES-30	19450101-030BF	9/20/2024	0.0
East Hallway Boys' Restroom - Left Sink	CES-31	19450101-031BF	9/20/2024	0.0
East Hallway Boys' Restroom - Right Sink	CES-32	19450101-032BF	9/20/2024	0.0
Classroom 19 - Cardiff	CES-33	19450101-033CF	9/20/2024	1.0
Classroom 20 - Cardiff	CES-34	19450101-034CF	9/20/2024	4.0
Classroom 21 - Cardiff	CES-35	19450101-035CF	9/20/2024	9.0
Classroom 22 - Cardiff	CES-36	19450101-036CF	9/20/2024	9.0
Classroom 14 - Cardiff	CES-37	19450101-037CF	9/20/2024	5.0
Classroom 15 - Cardiff	CES-38	19450101-038CF	9/20/2024	6.0
Classroom 16 - Cardiff	CES-39	19450101-039CF	9/20/2024	14.0
Classroom 17 - Cardiff	CES-40	19450101-040CF	9/20/2024	8.0
West Hallway Girls' Restroom - Left Sink	CES-41	19450101-041BF	9/20/2024	0.0
West Hallway Girls' Restroom - Right Sink	CES-42	19450101-042BF	9/20/2024	0.0



2024 Lead in Drinking Water Testing Summary

Campus: Elementary School, 815 S. Nehalem St.

Fixture Location Description	CSD Fixture ID #	ODE Fixture ID #	Test Date	Test Result (ppb)
West Hallway Boys' Restroom - Left Sink	CES-43	19450101-043BF	9/20/2024	0.0
West Hallway Boys' Restroom - Right Sink	CES-44	19450101-044BF	9/20/2024	0.0
Stage Drinking Fountain	CES-45	19450101-045DW	6/19/2025	Fixture Removed
Staff Restroom - Nehalem Building	CES-46	19450100-046BF	9/20/2024	0.0

All school districts, education service districts, and public charter schools in Oregon must test for and reduce exposure to elevated lead levels in water used for drinking and food preparation, as mandated by OAR 333-061-0400 and OAR 581-022-2223. Clatskanie School District adheres to these regulations by ensuring:

1. Water testing conforms to OAR 333-061-0400 specifications.
2. Samples are analyzed by Oregon Health Authority-accredited laboratories.
3. All mandated water fixtures are tested according to the Oregon Health Authority's scheduled timelines.
4. Any water fixture with lead levels of **15 parts per billion (ppb)** or higher will be immediately taken out of service.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/17/2024
Received: 05/07/2024
Sampled By: Jason Krause
Work Order: 4130023

C
L
I
E
N
T
Clatskanie School District
Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:
Project # : -
Sample Type :

Sampling Location: Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4130023-01	Sample Name: CES-01 Sampled: 5/3/24 6:14						Matrix: Water
†Lead	1030	EPA 200.8	4.59	ppb	1.00	15 ppb	06/13/24 18:43
4130023-02	Sample Name: CES-02 Sampled: 5/3/24 6:13						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 18:46
4130023-03	Sample Name: CES-03 Sampled: 5/3/24 6:12						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 18:50
4130023-04	Sample Name: CES-04 Sampled: 5/3/24 6:12						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 18:54
4130023-05	Sample Name: CES-05 Sampled: 5/3/24 6:10						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 18:58
4130023-06	Sample Name: CES-06 Sampled: 5/3/24 6:10						Matrix: Water
†Lead	1030	EPA 200.8	5.74	ppb	1.00	15 ppb	06/13/24 19:01
4130023-07	Sample Name: CES-07 Sampled: 5/3/24 6:10						Matrix: Water
†Lead	1030	EPA 200.8	1.42	ppb	1.00	15 ppb	06/13/24 19:05
4130023-08	Sample Name: CES-08 Sampled: 5/3/24 6:15						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 19:09
4130023-09	Sample Name: CES-09 Sampled: 5/3/24 6:15						Matrix: Water
†Lead	1030	EPA 200.8	19.0	ppb	1.00	15 ppb	06/13/24 19:13 MCLE
4130023-10	Sample Name: CES-10 Sampled: 5/3/24 6:11						Matrix: Water
†Lead	1030	EPA 200.8	ND	ppb	1.00	15 ppb	06/13/24 19:16



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/17/2024
Received: 05/07/2024
Sampled By: Jason Krause
Work Order: 4130023

C L I E N T **Clatskanie School District**

Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:

Project # : -
Sample Type :

Sampling Location: Elementary School

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/04/2024
Received: 09/26/2024
Sampled By: Will Seals
Work Order: 4270019

C
L
I
E
N
T
Clatskanie School District
Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:
Project # : -
Sample Type :

Sampling Location: Clatskanie Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4270019-01	Sample Name: CES-11 Sampled: 9/20/24 7:19						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-02	Sample Name: CES-12 Sampled: 9/20/24 7:19						Matrix: Water
†Lead		EPA 200.9	2	ppb	1	15 ppb	10/02/24 14:43
4270019-03	Sample Name: CES-13 Sampled: 9/20/24 7:19						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-04	Sample Name: CES-14 Sampled: 9/20/24 7:21						Matrix: Water
†Lead		EPA 200.9	3	ppb	1	15 ppb	10/02/24 14:43
4270019-05	Sample Name: CES-15 Sampled: 9/20/24 7:19						Matrix: Water
†Lead		EPA 200.9	2	ppb	1	15 ppb	10/02/24 14:43
4270019-06	Sample Name: CES-16 Sampled: 9/20/24 7:13						Matrix: Water
†Lead		EPA 200.9	4	ppb	1	15 ppb	10/02/24 14:43
4270019-07	Sample Name: CES-17 Sampled: 9/20/24 7:13						Matrix: Water
†Lead		EPA 200.9	9	ppb	1	15 ppb	10/02/24 14:43
4270019-08	Sample Name: CES-18 Sampled: 9/20/24 7:13						Matrix: Water
†Lead		EPA 200.9	24	ppb	2	15 ppb	10/02/24 14:43 MCLE
4270019-09	Sample Name: CES-19 Sampled: 9/20/24 7:11						Matrix: Water
†Lead		EPA 200.9	5	ppb	1	15 ppb	10/02/24 14:43
4270019-10	Sample Name: CES-20 Sampled: 9/20/24 7:11						Matrix: Water
†Lead		EPA 200.9	5	ppb	1	15 ppb	10/02/24 14:43



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/04/2024
Received: 09/26/2024
Sampled By: Will Seals
Work Order: 4270019

C
L
I
E
N
T **Clatskanie School District**
Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:
Project # : -
Sample Type :

Sampling Location: Clatskanie Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4270019-11	Sample Name: CES-21 Sampled: 9/20/24 7:07						Matrix: Water
†Lead		EPA 200.9	5	ppb	1	15 ppb	10/02/24 14:43
4270019-12	Sample Name: CES-22 Sampled: 9/20/24 7:04						Matrix: Water
†Lead		EPA 200.9	3	ppb	1	15 ppb	10/02/24 14:43
4270019-13	Sample Name: CES-23 Sampled: 9/20/24 7:02						Matrix: Water
†Lead		EPA 200.9	4	ppb	1	15 ppb	10/02/24 14:43
4270019-14	Sample Name: CES-24 Sampled: 9/20/24 7:25						Matrix: Water
†Lead		EPA 200.9	2	ppb	1	15 ppb	10/02/24 14:43
4270019-15	Sample Name: CES-25 Sampled: 9/20/24 7:25						Matrix: Water
†Lead		EPA 200.9	2	ppb	1	15 ppb	10/02/24 14:43
4270019-16	Sample Name: CES-26 Sampled: 9/20/24 7:26						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-17	Sample Name: CES-27 Sampled: 9/20/24 7:27						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-18	Sample Name: CES-28 Sampled: 9/20/24 7:27						Matrix: Water
†Lead		EPA 200.9	17	ppb	1	15 ppb	10/02/24 14:43 MCLE
4270019-19	Sample Name: CES-29 Sampled: 9/20/24 7:35						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-20	Sample Name: CES-30 Sampled: 9/20/24 7:25						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/04/2024
Received: 09/26/2024
Sampled By: Will Seals
Work Order: 4270019

C
L
I
E
N
T
Clatskanie School District
Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:
Project # : -
Sample Type :

Sampling Location: Clatskanie Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4270019-21	Sample Name: CES-31 Sampled: 9/20/24 7:37						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-22	Sample Name: CES-32 Sampled: 9/20/24 7:37						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-23	Sample Name: CES-33 Sampled: 9/20/24 7:39						Matrix: Water
†Lead		EPA 200.9	1	ppb	1	15 ppb	10/02/24 14:43
4270019-24	Sample Name: CES-34 Sampled: 9/20/24 7:39						Matrix: Water
†Lead		EPA 200.9	4	ppb	1	15 ppb	10/02/24 14:43
4270019-25	Sample Name: CES-35 Sampled: 9/20/24 7:41						Matrix: Water
†Lead		EPA 200.9	9	ppb	1	15 ppb	10/02/24 14:43
4270019-26	Sample Name: CES-36 Sampled: 9/20/24 7:41						Matrix: Water
†Lead		EPA 200.9	9	ppb	1	15 ppb	10/02/24 14:43
4270019-27	Sample Name: CES-37 Sampled: 9/20/24 7:42						Matrix: Water
†Lead		EPA 200.9	5	ppb	1	15 ppb	10/02/24 14:43
4270019-28	Sample Name: CES-38 Sampled: 9/20/24 7:45						Matrix: Water
†Lead		EPA 200.9	6	ppb	1	15 ppb	10/02/24 14:43
4270019-29	Sample Name: CES-39 Sampled: 9/20/24 7:45						Matrix: Water
†Lead		EPA 200.9	14	ppb	1	15 ppb	10/02/24 14:43
4270019-30	Sample Name: CES-40 Sampled: 9/20/24 7:46						Matrix: Water
†Lead		EPA 200.9	8	ppb	1	15 ppb	10/02/24 14:43



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 10/04/2024
Received: 09/26/2024
Sampled By: Will Seals
Work Order: 4270019

C
L
I
E
N
T
Clatskanie School District
Attn: Will Seals
660 SW Byrant St
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:
Project # : -
Sample Type :

Sampling Location: Clatskanie Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4270019-31	Sample Name: CES-41 Sampled: 9/20/24 7:47						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-32	Sample Name: CES-42 Sampled: 9/20/24 7:47						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-33	Sample Name: CES-43 Sampled: 9/20/24 7:48						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-34	Sample Name: CES-44 Sampled: 9/20/24 7:49						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43
4270019-35	Sample Name: CES-45 Sampled: 9/20/24 7:50						Matrix: Water
†Lead		EPA 200.9	25	ppb	2	15 ppb	10/02/24 14:43 MCLE
4270019-36	Sample Name: CES-46 Sampled: 9/20/24 7:07						Matrix: Water
†Lead		EPA 200.9	ND	ppb	1	15 ppb	10/02/24 14:43

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/07/2025
Received: 06/30/2025
Sampled By: Will Seals
Work Order: 5181011

C L I E N T **Clatskanie School District**

Attn: Will Seals
PO BOX 678
Clatskanie OR, 97016
Phone: (503) 734-7010

Project:

Project # : -
Sample Type :

Sampling Location: Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
5181011-01	Sample Name: CES-09 Sampled: 6/19/25 9:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1.0	15 ppb	07/01/25 14:52
5181011-02	Sample Name: CES-18 Sampled: 6/19/25 9:01						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1.0	15 ppb	07/01/25 14:52
5181011-03	Sample Name: CES-28 Sampled: 6/19/25 8:52						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	1.0	15 ppb	07/01/25 14:52

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director