



ADDENDUM 1

Questions regarding IT24.11.19.2 Firelite Speaker Strobes Add to Classrooms for MHHS East and MHHS West

QUESTIONS

1. Is there any requirement to submit drawings, voltage calculations, scope or data sheets to local or state AHJ?

A. Not at this time.

2. Does either site require plenum cable?

A. No.

3. Can open cable be ran above 8 feet in classrooms and corridors (where no drop ceiling exists) as long as it is secure via j-hooks and or cable tray where it exists?

A. Yes.

4. Reuse of existing sleeves is allowed for new fire alarm cable?

A. Yes.

5. Is there any requirement to meet NFPA 72 code requirements for candela ratings ?

A. No. The district is attempting to improve the current system for evacuation purposes (voice). Additional devices to meet the code may

be added in a future project. The school is currently meeting code with existing devices. This project was not at the request of officials to update the system.