RIVERVIEW GARDENS SCHOOL DISTRICT

March 19, 2024

Joylynn Pruitt-Adams, Ed.D., Superintendent

1370 Northumberland Drive St. Louis, MO 63137 Office 314.869.2505 x 20102 Fax 314.388.6003 www.rgsd.k12.mo.us

MISSION

Collaboratively educate and empower our scholars to thrive in challenging environments

VISION

RGSD will be a district where:

- There are high expectations for all.
- There will be healthy, loving, empathetic and kind relationships.
- Students are at the center of our decisions.
- Supports are provided so students become grade-level ready.
- There is transparency, accountability, timely, clear communication, and high levels of customer service.
- All stakeholders have a voice.
- There is a focus on college and career readiness.

Special Administrative Board

Veronica Morrow-Reel President, Master C.B.M.

Niketia Coleman, Ed.D. Vice-President, C.B.M.

Wanda Lane, Treasurer, C.B.M.

Tommie Harsley, III, Director, C.B.M.

Miranda Avant-Elliott, Ed.D., Director, C.B.M.

Jacqueline Jackson, Director, C.B.M.

Sharon Titsworth, Director, C.B.M

Secretary Sha S. Fields, Coordinator of Board Governance/Custodian of Records Dear Michelle Obama Early Childhood Academic Center staff,

On February 2, 2024, I shared information regarding the <u>Get the Lead Out of School</u> <u>Drinking Water Act</u> and its requirements for school districts.

The Environmental Protection Agency (EPA) currently has a lead drinking water standard limit of 15 micrograms per liter (ug/L) of lead in water. However, Missouri law requires that all Missouri schools achieve a 5 ug/L limit of lead in water.

During February 2024, all RGSD schools and buildings were tested for lead concentration in school drinking water outlets.

At Michelle Obama Early Childhood Academic Center, testing identified two (2) drinking water outlets that did not meet the 5 ug/L Missouri standard limit of lead in water.

Upon receiving the results, each of these water sources was taken out of service by our district facilities team. At this time, we have already begun working with Merlo Plumbing to remediate each source needing attention.

Before being placed back in service, water from each source will be tested to ensure the issue has been resolved. We will communicate additional results after testing takes place.

Meanwhile, all students and staff continue to have access to a variety of water outlets that have met compliance, throughout the school.

If you have questions about a lead sample result at a specific outlet and actions taken, or if you have concerns, please email karl.scheidt@rgsd.k12.mo.us.

To view reports for all schools/buildings throughout Riverview Gardens School District, please visit https://www.rgsdmo.org/facilities/gettheleadout.

Sincerely,

fint al

Joylynn Pruitt-Adams, Ed.D. Superintendent

REPORT OF DRINKING WATER SAMPLING FOR LEAD CONTENT AT:

EARLY CHILDHOOD LEARNING 1111 SAINT CYR RD ST. LOUIS, MISSOURI 63137



PREPARED FOR:

MR. KARL SCHEIDT DIRECTOR OF FACILITIES AND FOOD SERVICES RIVERVIEW GARDEN SCHOOL DISTRICT 10101 LEWIS AND CLARK BLVD ST. LOUIS, MISSOURI 63136

PREPARED BY:

J.S. HELD, LLC #6 MEADOW HEIGHTS PROFESSIONAL PARK COLLINSVILLE, ILLINOIS 62234 (618) 343-3590

MARCH 2024

TABLE OF CONTENTS

231100311-03 Drinking Water Sampling for Lead Riverview Garden School District Early Childhood Learning 1111 Saint Cyr Dr. St. Louis, Missouri 63136

EXECUTIVE SUMMARY

APPENDIX A Sample Locations/Results
APPENDIX B Laboratory Analysis
APPENDIX C Credentials

EXECUTIVE SUMMARY

On the morning of February 9th, 2024, J.S. Held performed lead testing of multiple water sources at Early Childhood Learning, 1111 Saint Cyr Dr, St. Louis, Missouri 63136. The sampling was performed by trained and licensed personnel in accordance with USEPA, HUD and State of Missouri Regulations and Guidelines. Work was performed in accordance with the newly amended Missouri Senate Bill 681.

All inspectors involved with sampling activities had EPA approved training in lead. Certifications for our firm and the inspector collecting the samples are included as Appendix C to this document.

All samples were collected on a "first draw" and "second draw" basis. "First draw" is achieved by allowing the water system to rest for at least eight hours prior to sampling in order to collect any existing debris or settlement within the sample. The intent of this sampling is to replicate "worst case scenario" conditions. JSH proposes to collect a second sample from each source as a "follow-up sample" per the Missouri Senate Bill 681 requirements. As such, J.S. Held inspectors met at the school at 4:00 a.m. to collect water samples before the systems were used by staff or students. The State of Missouri and other regulatory agencies recommend that water sources run for at least thirty seconds and as long as two minutes prior to use to avoid settling within the water system.

Drinking water samples were collected from Fifty-one (51) different locations throughout Early Childhood Learning, 3 locations were inactive during the sampling event. The water samples were collected from drinking fountains and sinks potentially utilized for cooking or drinking activities at the campus. After sample collection, samples were immediately iced down and delivered to Teklab, Inc. located in Collinsville, Illinois following strict chain of custody procedures. Teklab is a NELAP accredited and State of Illinois licensed laboratory specializing in drinking water analysis. Detailed sampling locations and sample results are located in Appendix A of this report.

The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 micrograms per liter (μ g/L). The analytical sensitivity utilized for the analysis of the water samples submitted identified a reporting limit (RL) of 1.0 microgram of lead per liter (μ g/L). This reporting value equates to 1.0 parts per billion (ppb) of lead. The USEPA action level for lead in drinking water is 15.0 ppb for PSW. The USEPA document titled "Lead in Drinking Water at Schools and Childcare Facilities" last updated November 9, 2015 identifies an action level for drinking water collected from a plumbing fixture as 20.0 ppb. Ninety-one (91) samples collected from the selected locations at Early Childhood Learning, reported sample results which were less than the action level. This information can be found under the National Primary Drinking Water Regulations provided by the EPA,

1

CFR 2010 Title 40. (See Appendix A and B for Sample Results) The Missouri Senate Bill 1075 require potable plumbing fixtures to be less than 5.0 ppb, the levels area above 5 ppb, then action shall be necessary to filter the water from the fixture or clean/repair/replace the fixture and retest until the levels are reported below 5 ppb. Two (2) samples collected from the selected locations at the Early Childhood Learning Center, sample results which are above 5 ppb (See Appendix A and B for Sample Results)

The following results are greater than the 5 ppb requirements under Senate Bill 681.

"First Draw" Sampling		
Sample ID 04A	Outside Cafeteria	(5.7 ppb)
"Second Draw" Sampling		
Sample ID 04B	Outside Cafeteria	(5.2 ppb)

Conclusion/Recommendations

At this time all water sources testing at 5 ppb or above should be removed from service until filtration can be added or these sources are repaired/replaced and retested reporting under 5 ppb. These sources are subject to additional maintenance activities and response actions prior to use. Before being put back in service. In addition, all sources will be subject to an ongoing maintenance program and re-testing at appropriate intervals.

Remediation includes decreasing lead concentrations below 5 parts per billion using such methods such as replacement of plumbing, solder, fittings, or fixtures, installations of filters and filter devices, or other effective methods in accordance with the new Missouri SB681 *Get the Lead Out Of Schools Drinking Water Act*

The district will be required to provide notification to parents and staff within 7 days of receiving these sample results and results shall be posted on the district website within 2 weeks. Any samples reported over 5 ppb should be re-sampled on an annual basis at a minimum.

J.S. Held recommends that all water sources be run for at least thirty seconds prior to use as recommended by USEPA.

<u>APPENDIX A</u> SAMPLE LOCATIONS & RESULTS



Early Childho od

Prep Day: 2/8/24		# to Test =	51	l
······································		# Disabled =	3	l
Sample Day: 2/9/24		# of Samples =	93	
		# > 10.0 ppb =	0	l
To Lab> 2/9/24	* Reporting Limit	# > 5.0 ppb =	2	

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
01	(A)				1.0	<1.0
	(B)	S	Kitchen- 3 Bay left		1.0	<1.0
	(C)				1.0	<1.0
02	(A)	S	Kitchen- 3 Bay Left		1.0	<1.0
	(B)	5	Ritchen- 5 bay Leit		1.0	<1.0
03	(A)	S	Kitchen Hand Sink		1.0	<1.0
	(B)				1.0	<1.0
04	(A)	F	Outside Cafeteria		1.0	5.7
	(B)				1.0	5.2
05	(A)	F	Outside Gymnasium High	inactive	1.0	
	(B)		Guiside Gymnasidm High	Indetive	1.0	
06	(A)	F	F Outside of Gym Low		1.0	<1.0
	(B)				1.0	<1.0
07	(A)	S	S Rm 118- 1 Bay Sink		1.0	<1.0
	(B)	5	Kin 110 1 Day Sink		1.0	<1.0
08	(A)	S	Rm 115 Handink		1.0	
	(B)				1.0	
09	(A)	S	Rm 116 Handsink		1.0	<1.0
	(B)	5			1.0	<1.0
10	(A)	F	Fountain- Outside Art Closet (112)	inactive	1.0	<1.0
	(B)			mactive	1.0	<1.0
11	(A)	с	Dm 110 Unner Sink		1.0	<1.0



J

1.0

<1.0

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
12	(A)		Rm 110 Lower Sink		1.0	<1.0
	(B)	S	RITI 110 LOWER SINK		1.0	<1.0
13	(A)	S	Rm 111 Upper Sink		1.0	<1.0
	(B)	5			1.0	<1.0
14	(A)	S	Rm 111 Lower Sink		-	<1.0
	(B)	5			-	<1.0
15	(A)	S	Rm 109 Upper Sink		1.0	4.5
	(B)	5			1.0	<1.0
16	(A)	S	Rm 109 Lower Sink	inactive	1.0	
	(B)	5	KIII 109 LOWEI SIIIK	mactive	1.0	
17	(A)	S	Rm 108 Upper Sink		1.0	<1.0
	(B)	5				<1.0
18	(A)	S	Rm 108 Lower Sink		1.0	<1.0
	(B)	5	RITI 100 LOWEL SILK		1.0	<1.0
19	(A)	F	Fountain Outside Rm 207A		1.0	<1.0
	(B)		Foundain Outside Rin 207A		1.0	<1.0
20	(A)	S	Breakroom Handsink		1.0	<1.0
	(B)	5	DI CARI OUTIT MANUSITIK		1.0	<1.0
21	(A)	S	Dm 204 Linner Sink		1.0	<1.0
	(B)	5	Rm 204 Upper Sink		1.0	<1.0
22	(A)	S	Rm 204 Lower Sink		1.0	<1.0
	(B)	5	RITI 204 LOWEL SITK		1.0	<1.0
23	(A)	S	Dm 202 Linnor Sink		1.0	<1.0
	(B)	3	Rm 203 Upper Sink		1.0	<1.0
24	(A)	S	Rm 203 Lower Sink		1.0	<1.0
	(B)	5			1.0	<1.0
25	(A)	c	Dm 202 LInner Sink		1.0	<1.0



J

(B)

<1.0

(Continuation Sheet)

1.0

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
26	(A)	S	Rm 202 Lower Sink		1.0	<1.0
	(B)	5	RIII 202 LOWER SINK		1.0	<1.0
27	(A)	S	Dm 201 Upper Cink		1.0	<1.0
	(B)	5	Rm 201 Upper Sink		1.0	<1.0
28	(A)	S	Rm 201 Lower Sink		1.0	<1.0
	(B)	5	RIII 201 LOWEI SIIIK		1.0	<1.0
29	(A)	S	Pm 209 Upper Cink		-	<1.0
	(B)	5	Rm 208 Upper Sink		-	<1.0
30	(A)	S	Rm 208 Lower Sink		-	<1.0
	(B)	5	RIII 200 LOWEL SIIIK		-	<1.0
31	(A)	S	Dm 200 Upper Cink		1.0	<1.0
	(B)	5	Rm 209 Upper Sink		1.0	<1.0
32	(A)	S Rm 209 Lower Sink		-	<1.0	
	(B)	5	RIII 209 LOWEI SIIIK		-	<1.0
33	(A)	S	Dm 211 Upper Cink		1.0	<1.0
	(B)	5	Rm 211 Upper Sink		1.0	<1.0
34	(A)	c	Rm 211 Lower Sink		1.0	<1.0
	(B)	S	RIII 211 LOWEI SIIIK		1.0	<1.0
35	(A)	S	Rm 210 Upper Sink		1.0	<1.0
	(B)	5	KIII 210 Opper Sink		1.0	<1.0
36	(A)	S	Rm 210 Lower Sink		1.0	<1.0
	(B)	5	RIII 210 LOWER SINK		1.0	<1.0
37	(A)	S	Dm 212 Upper Cink		1.0	<1.0
	(B)	5	Rm 213 Upper Sink		1.0	<1.0
38	(A)	S			1.0	<1.0
	(B)	3	Rm 213 Lower Sink		1.0	<1.0
39	(A)	F	Fountain Outcide 212		1.0	<1.0



ī

(Continuation Sheet)

1.0

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
40	(A)	S	Dm 214 Linner Cink		1.0	<1.0
	(B)	5	Rm 214 Upper Sink		1.0	<1.0
41	(A)	S	Rm 214 Lower Sink		1.0	<1.0
	(B)	5	KII 214 LOWEI JIIK		1.0	<1.0
42	(A)	S	Rm 215 Upper Sink		1.0	<1.0
	(B)	5			1.0	<1.0
43	(A)	S	Rm 215 Lower Sink		1.0	<1.0
	(B)	5	KII ZIJ LOWEI JIIK		1.0	<1.0
44	(A)	S	Rm 216 Upper Sink		1.0	<1.0
	(B)	5			1.0	<1.0
45	(A)	S	Rm 216 Lower Sink		1.0	<1.0
	(B)	5	KII 210 LOwer Sink		1.0	<1.0
46	(A)	(A) S Rm 217 Upper Sink		1.0	<1.0	
	(B)	5	Rm 217 Upper Sink		1.0	<1.0
47	(A)	S	Rm 217 Lower Sink		1.0	<1.0
	(B)	5	Kii 217 Lower Sink		1.0	<1.0
48	(A)	S	Rm 218 Nurse Sink		1.0	<1.0
	(B)	5			1.0	<1.0
49	(A)	F	Fountain Outside 220 Upper		1.0	<1.0
	(B)	'			1.0	<1.0
50	(A)	F	Fountain Outside 220 Lower		1.0	<1.0
	(B)	'			1.0	<1.0
51	(A)	S	223 Nurse office		1.0	<1.0
	(B)	5			1.0	<1.0
52	(A)				1.0	
	(B)				1.0	
53	(A)				1.0	



Sample ID Coding Key:

- F = Fountain
- S = Sink
- (A) = 1st Sample
- (B) = 2nd Sample (30 Seconds Later)
- (C) = 3rd Sample (3 Minutes Later)

<u>APPENDIX B</u> LABORATORY ANALYSIS



http://www.teklabinc.com/

March 11, 2024

Jeff Faust J.S. Held #6 Meadow Heights Professional Park Collinsville, IL 62234 TEL: (618) 343-3590 FAX: (618) 343-3597

RE: 231100311 / RGDG / Early Childhood



WorkOrder: 24020693

Dear Jeff Faust:

TEKLAB, INC received 55 samples on 2/9/2024 8:15:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marin J. Darling I

Marvin L. Darling Project Manager (618)344-1004 ex 41 mdarling@teklabinc.com



Report Contents

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

Work Order: 24020693 Report Date: 11-Mar-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

Work Order: 24020693

Report Date: 11-Mar-24

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
- DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)

eklab, Inc.

Definitions

Qualifiers

http://www.teklabinc.com/

Work Order: 24020693

Report Date: 11-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Work Order: 24020693 Report Date: 11-Mar-24

Client: J.S. Held Client Project: 231100311 / RGDG / Early Childhood

Cooler Receipt Temp: NA °C

			Locations		
	Collinsville		Springfield		Kansas City
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com
	Collinsville Air		Chicago		
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.		
	Collinsville, IL 62234-7425		Downers Grove, IL 60515		
Phone	(618) 344-1004	Phone	(630) 324-6855		
Fax	(618) 344-1005	Fax			
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com		



Accreditations

http://www.teklabinc.com/

Work Order: 24020693

Report Date: 11-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



http://www.teklabinc.com/

Work Order: 24020693

Report Date: 11-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

Matrix:	DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	I, 200.8 R5.4, META	LS BY ICPMS (TOTAL)						
Lead								
24020693-001	A 01A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:13	02/09/2024 6:00
24020693-002	A 01B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:17	02/09/2024 6:00
24020693-003	A 01C	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:21	02/09/2024 6:00
24020693-004	A 02A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:25	02/09/2024 6:00
24020693-005	A 02B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:30	02/09/2024 6:00
24020693-006	A 03A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:34	02/09/2024 6:00
24020693-007	A 03B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:38	02/09/2024 6:00
24020693-008	A 04A	NELAP	1.0	5.7	µg/L	1	03/08/2024 8:08	02/09/2024 6:00
24020693-009	A 04B	NELAP	1.0	5.2	µg/L	1	03/08/2024 8:13	02/09/2024 6:00
24020693-010	A 06A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 7:42	02/09/2024 6:00
24020693-011	A 06B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:17	02/09/2024 6:00
24020693-012	A 07A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:21	02/09/2024 6:00
24020693-013	A 07B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:26	02/09/2024 6:00
24020693-014	A 08A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:30	02/09/2024 6:00
24020693-015	A 08B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:34	02/09/2024 6:00
24020693-016	A 09A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:38	02/09/2024 6:00
24020693-017	A 09B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:43	02/09/2024 6:00
24020693-018	A 11A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 8:47	02/09/2024 6:00
24020693-019	A 11B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:04	02/09/2024 6:00
24020693-020	A 12A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:34	02/09/2024 6:00
24020693-021	A 12B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:09	02/09/2024 6:00
24020693-022	A 13A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:13	02/09/2024 6:00
24020693-023	A 13B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:17	02/09/2024 6:00
24020693-024	A 14A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:21	02/09/2024 6:00
24020693-025	A 14B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:26	02/09/2024 6:00
24020693-026	A 15A	NELAP	1.0	4.5	µg/L	5	03/02/2024 9:12	02/09/2024 6:00
24020693-027	A 15B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 9:30	02/09/2024 6:00
24020693-028	A 17A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 11:49	02/09/2024 6:00
24020693-029	A 17B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 11:53	02/09/2024 6:00
24020693-030	A 19A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 11:57	02/09/2024 6:00
24020693-031	A 19B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 12:19	02/09/2024 6:00
24020693-032	A 20A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 12:02	02/09/2024 6:00
24020693-033	A 20B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 12:06	02/09/2024 6:00
24020693-034	A 21A	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 12:10	02/09/2024 6:00
24020693-035	A 21B	NELAP	1.0	< 1.0	µg/L	1	03/08/2024 12:14	02/09/2024 6:00
24020693-036	A 22A	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:08	02/09/2024 6:00
24020693-037	A 22B	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:11	02/09/2024 6:00
24020693-038	A 23A	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:15	02/09/2024 6:00
24020693-039	A 23B	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:19	02/09/2024 6:00
24020693-040	A 24A	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:22	02/09/2024 6:00
24020693-041	A 24B	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:44	02/09/2024 6:00
24020693-042	A 25A	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:48	02/09/2024 6:00
24020693-043	A 25B	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:52	02/09/2024 6:00
24020693-044	A 26A	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:55	02/09/2024 6:00
24020693-045	A 26B	NELAP	1.0	< 1.0	µg/L	1	03/05/2024 23:59	02/09/2024 6:00
24020693-046	A 27A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:03	02/09/2024 6:00
24020693-047	A 27B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:06	02/09/2024 6:00
24020693-048	A 28A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:10	02/09/2024 6:00
								Page 7 of 9



http://www.teklabinc.com/

Client: J.S. Held

Work Order: 24020693

Report Date: 11-Mar-24

Client Project: 231100311 / RGDG / Early Childhood

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	l RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	, 200.8 R5.4, META	LS BY ICPMS (TOTA	L)					
Lead								
24020693-0494	A 28B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:25	02/09/2024 6:00
24020693-0504	A 29A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:28	02/09/2024 6:00
24020693-0514	A 29B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:39	02/09/2024 6:00
24020693-0524	A 30A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:43	02/09/2024 6:00
24020693-053A	A 30B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:47	02/09/2024 6:00
24020693-0544	A 31A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:50	02/09/2024 6:00
24020693-055A	A 31B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 0:54	02/09/2024 6:00



Receiving Check List

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGDG / Early Childhood

Work Order: 24020693 Report Date: 11-Mar-24

Carrier: Devon Rathbun	Recei	ved By: EES		
On: 12-Feb-24 Diallo		iewed by: on: eb-24 I	Elled Hopki Ellie Hopkins	nd
Pages to follow: Chain of custody 5	Extra pages included	0		
Shipping container/cooler in good condition?	Yes 🗸	No	Not Present	Temp °C NA
Type of thermal preservation?	None 🗹			Dry Ice
Chain of custody present?	Yes 🗹	No 🗌		
Chain of custody signed when relinquished and received?	Yes 🖌	No 🗌		
Chain of custody agrees with sample labels?	Yes 🖌	No 🗌		
Samples in proper container/bottle?	Yes 🗹	No 🗌		
Sample containers intact?	Yes 🗹	No 🗌		
Sufficient sample volume for indicated test?	Yes 🔽	No 🗌		
All samples received within holding time?	Yes 🔽	No 🗌		
Reported field parameters measured:	Field	Lab	NA 🗹	
Container/Temp Blank temperature in compliance?	Yes 🗹	No 🗌		
When thermal preservation is required, samples are complia 0.1°C - 6.0°C, or when samples are received on ice the sam		between		
Water – at least one vial per sample has zero headspace?	Yes	No	No VOA vials 🖌	
Water - TOX containers have zero headspace?	Yes	No	No TOX containers	
Water - pH acceptable upon receipt?	Yes 🗹	No	NA 🗌	
NPDES/CWA TCN interferences checked/treated in the field?	Yes	No 🗌	NA 🗹	
Any No responses	must be detailed bel	ow or on the	COC.	

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

Pg 1 of 9 Workorder # 24020693

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: J.S. Held L	LC			······································	Sai	mpl	es o	n:	Γ		Æ	Г		BLU	EICE	= [کر ا		CE	N	A	°(2	
Address: #6 Mea	dow Heights Professional Pa	rk			Pre	eser	ved	in:	ŕ	X L	AB	Γ		ELC		1	<u>,</u>	RL			ç. 1		-	
City/State/Zip: Co	llinsville, IL 62234						OTE		7	A -		I					<u> </u>	<u></u>	<u> </u>		<u> </u>	<u></u>		
Contact: Jeff Faus	t	Phone: (6	18) 343-359	90																				
Email: jeffery.fa	ust@jsheld.com	Fax:			Cli	ent	Co	mm	ent	s:									-		******	1		
Are these samples kno	wn to be involved in litigation? If	yes, a surcharge	will apply:	Yes 🕅 No	Ple	ease	e rep	ort i	in pp	b														
Are these samples kno	wn to be hazardous?	Yes 🔀 I	No .		6	Ea	r I Y	. /		hil	dhe	00	(
Are there any required limits in the comment s	reporting limits to be met on the ection:	equested analys	sis?. If yes, pl	ease provide				Ĺ		•														
PROJECT NAME		SAMPLE CO	LLECTOR	S NAME	#	and	d Tv	pe	of C	Conf	aine	rs	Γ	IN	DIC	AT	EAN	JAL	YSI	S RI	EQI	IFS.	TEC)
231100311 / RGSE)/	Dec	ion Ra	thein			Í	İ				Τ	İ.			Τ	T	T	Τ		\square	T		T
R	ESULTS REQUESTED		1	IG INSTRUCTIONS		-	z	Ŧ			5	0		lead drinking water										-
Standard	🗌 1-2 Day (100% S	urcharge)			NP	NO	٥	2SO	힏	MeOH		Other		inking										
Other	3 Day (50% Surc	harge)				ω	-	4	•	Σ C	2 -	Ĩ		water										
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix	1																			
24020693:00	DIA	2/9/24	6:00 AM	Drinking Water				T			Τ			X			Τ	Ť	T					
07	OB		1	Drinking Water			T					T		1				1-	1			1	+	1
<u></u>	010			Drinking Water							Τ							+				\top	十	1
004	02 A			Drinking Water							Τ						Τ	1	\square					
	02B		1	Drinking Water		1	T	T			Τ							\top	\square			\top	T	
<u>v</u>	03A		1.	Drinking Water								Γ			T		T	1	Π	Π		+	Ť	
<u></u>	03B			Drinking Water			T						F				╈	+			-+		十	
308	OYA			Drinking Water					T									+			-	-	+	
	0413			Drinking Water							Τ						+	1	\square		-	-	+	
00	06 A	N/		Drinking Water														+		┢━━╋	1	-	十	
011	06B			Drinking Water										X								Τ		
	Relinquished By			Date/Time		.					;eiv		3y					Γ			ate/1	l'ime) j	
Veron Ron	hhm		2/9/24	8:15 Am	+(~	Y	L	4		La.	M	<u>I</u>					15	19	8	12			
					\downarrow				·									_						
																		+						
			<u> </u>		\vdash													╂		<u></u>				

. .	Workorder #	min	200	00
Pa tof 9	Workorder #	240	(X)	27 S
· 3 ·	wontordor //			

TEKLAB INC. 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: J.S. Held LLC					Sa	mpl	es o	n:	Г		E	Г	٦в	LUE	ICE	Г	N	O IC	E	(*****	12: - 3 13	°C	
	v Heights Professional Par	rk			Samples on: ICE BLUE ICE NO ICE °C Preserved in: LAB FELD FOR LAB USE ONLY																		
City/State/Zip: Collins							OTE		Ļ		_	.				-		<u> </u>	<u> </u>	<u>/</u>	/11.	<u>.</u>	
Contact: Jeff Faust		Phone: (61	18) 343-359	90																			
Email: jeffery.faust@	@jsheld.com	Fax:			С	ient	Co	mm	ent	s:												-	
Are these samples known Are there any required repu limits in the comment secti	orting limits to be met on the n ion: Yes	Yes D No	No is?. If yes, ple	ease provide	Pl	ease E	e rep A /`i	orti 17	in pp	ь СС			>0 ₂										
PROJECT NAME/NU 231100311 / RGSD /	IMBER	SAMPLE CO			#	an	d Ty	rpe	of C	cont:	aine	rs	 	IN					SIS	RE		ESTE	<u>ED</u>
	ULTS REQUESTED		1	G INSTRUCTIONS	- UNP	HNO3	NaOH	H2SO4	HCL	MeOH	TSP	Other		lead drinking water									
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix																			
24020.93.	07A	2/9/24	6:00 AN	Drinking Water										X		Τ	T			Τ			T
017	073			Drinking Water										1		Τ	Τ				Т		
ОЦ	08A			Drinking Water							Τ										T		
015	08B			Drinking Water																T			
Dile	094			Drinking Water										Π		Τ		\square		T	Т		
	09B			Drinking Water										ÌÌ							T	T	
OIF	<u> 11 A</u>			Drinking Water										P		T				+	T		
019	113			Drinking Water										Ħ						Ť	1		
020	12 A			Drinking Water										Π						\top	T	1	
021	12B			Drinking Water							T			Ú							T		
022	(3 A			Drinking Water										乂							Ι		
	Relinquished By			Date/Time					,	Rec			ly .							Daf	te/Ti	me	
Peven Ratury	<u>^</u>		2/9/20	4 8:15 AM		Ĺ	$\gamma\gamma$	ul	4	A	ar	la	th_			•••••••		<u>Z</u> ļ	<u> a</u>]	20	<u>{</u>	<u> </u>	15
						_		6															
					┼──												_						
					+													-					

Pg <u>3</u> of <u>9</u> Workorder # <u>240200</u>93

TEKLAB INC. 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Address: #6 Meadow Heights Professional Park City/State/Zip: Collinsville, IL 62234	
City/State/Zip: Commissing, it 02234	
Contact: Jeff Faust Phone: (618) 343-3590	
Email: jeffery.faust@jsheld.com Fax: Client Comments:	
Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes Yes Yes No Are these samples known to be hazardous? Yes Yes Yes Yes Yes Are there any required reporting limits to be met on the requested analysis?. If yes, please provide Please report in ppb Early Childhood Imits in the comment section: Yes No Yes No PROJECT NAME/NUMBER ISAMPLE COLLECTOR'S NAME # and Type of Containers INDICATE ANALYSIS PEOLING	
" and Type of Containers " INSIGATE ANALTOID REGO	STED
Vevon Rathbur	
RESULTS REQUESTED BILLING INSTRUCTIONS Standard 1-2 Day (100% Surcharge) Other 3 Day (50% Surcharge)	
Image: Standard Image: Standard <th< td=""><td></td></th<>	
Lab Use Only Sample ID Date/Time Sampled Matrix	
Lab use only Sample ID Date/Time Sampled Matrix 24/L0293-023 13 B 2/124 6:00 A# Drinking Water X	
OLU 19A Drinking Water	
025 1413 Drinking Water	
O24 15A Drinking Water	
Drinking Water	
28 17A Drinking Water	
Drinking Water	
C3D 19A Drinking Water	
C31 [9B Drinking Water	
D.32 20A / / Drinking Water	+-+
C33 20B Drinking Water X	
Relinquished By Date/Time Received By Date/Time	me
Devon Rathern 219124 8:15 Am Emily Aarlath 2/9/24	815

Pg <u>4</u> of <u>9</u> Workorder #	24020693
-------------------------------------	----------

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: J.S. Held LLC Samples on: CE BLUE ICE	
Address: #6 Meadow Heights Professional Park Preserved in: LAB FELD	FOR LAB USE ONLY
City/State/Zip: Collinsville, IL 62234	
Contact: Jeff Faust Phone: (618) 343-3590	
Email: jeffery.faust@jsheld.com Fax: Client Comments:	
Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes No Are these samples known to be hazardous? Yes No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: Yes No	
	ANALYSIS REQUESTED
Vevou Kathban	
RESULTS REQUESTED BILLING INSTRUCTIONS Na Y Na Y P Na Y P	
Lab Use Only Sample ID Date/Time Sampled Matrix	
240201093-034 21 A 219124 6 100 AM Drinking Water X	
O35 21B Drinking Water	
O3ic 22A Drinking Water	
Dinking Water	
C38 23A Drinking Water	
039 238 Drinking Water	╋╌┝╌╃╌┾╌┼╌╴
C40 24A Drinking Water	╉╌╄╾╋╼╋╴╋╴╋╼╋╶┼╼
Ctl 24B Drinking Water	
OLL 25A Drinking Water	╋┥┥┥
Cl_3 25 B Drinking Water (
744 26A V J Drinking Water X	
Relinquished By Date/Time Received By	Date/Time
Devon Rathern 219124 8:15 AM Emily Sauthett	2/9/24 815

CHAIN OF CUSTODY

293	3
2	4

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Address: #6 Meadow Heights Professional Park Preserved in: LAB FIELD FOR LAB USE ONLY City/State/Zip: Collinsville, IL 62234 LAB NOTES: LAB NOTES:	Client: J.S. Held LLC		<u> </u>			San	nple	es on	:	Π	ICE		$\overline{\Box}$	BLI	UE I	CE	Π	NO	ICE			<	°C	
Citly/State/Zip: Collinsville, IL 62234			rk			Pre	sen	ved ir	a:	П	LAB	3					ہــــا FF	2						
Email: jeffery.faust@jsheld.com Fax: Client Comments: Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes No Are these samples known to be hazardous? Yes No Are these samples known to be hazardous? Yes No Are these samples known to be hazardous? Yes No Are these samples known to be hazardous? Yes No PROJECT NAME/NUMBER SAMPLE COLLECTOR'S NAME # and Type of Containers INDICATE ANALYSIS REQUESTED 231100311 / RGSD / BILLING INSTRUCTIONS Example 10 Example 10 Example 10 Backgroup BILLING INSTRUCTIONS Example 10 Example 10 Example 10 Abuse Only Sample ID Date/Time Sampled Matrix Image: Example 10 Image: Example 10 CHE 27/A Drinking Water Image: Example 10 Drinking Water Image: Example 10 Image: Example 10 CHE 27/A Drinking Water Image: Example 10 Image: Example 10 Image: Example 10 Image: Example 10 CHE 27/A Drinking Water Image: Example 10 Image: Example 10 Image: Example 10 Image: Example 10	City/State/Zip: Collins	sville, IL 62234				LAE	3 NC	OTES	iz -								_							
Are these samples known to be involved in liftgetion? If yes, a surcharge will apply: Yes No Please report in ppb Are these samples known to be hazardous? Yes No Please provide Fart 12 Day Are these samples known to be hazardous? Yes No Please provide Fart 12 Day PROJECT NAME/NUMBER SAMPLE COLLECTOR'S NAME # and Type of Containers INDICATE ANALYSIS REQUESTED 231100311 / RGSD/ BILLING INSTRUCTIONS # and Type of Containers INDICATE ANALYSIS REQUESTED Islandard 12 Day (100% Surcharge) BILLING INSTRUCTIONS # and Type of Containers INDICATE ANALYSIS REQUESTED Lab Use Only Sample ID Date/Time Sampled Matrix Yes Yes CHE 27/3 Drinking Water I I I CHE 28/A Drinking Water I I I I CHE 27/3 Drinking Water I I I I I CHE 29/8 Drinking Water I I I I I I I I I I I I I I	Contact: Jeff Faust		Phone: (6'	18) 343-35	90																			
Not bescamples known to be hazardous? Yes No Are these samples known to be hazardous? Yes No Are these any required reporting limits to be met on the requested analysis?. If yes, please provide # and Type of Containers INDICATE ANALYSIS REQUESTED PROJECT NAME/NUMBER SAMPLE COLLECTOR'S NAME # and Type of Containers INDICATE ANALYSIS REQUESTED 231100311 / RGSD / BILLING INSTRUCTIONS Extra to the requested analysis?. If yes, please provide # and Type of Containers INDICATE ANALYSIS REQUESTED Standard 12 Day (100% Surcharge) BILLING INSTRUCTIONS Extra to the requested analysis?. If yes, please provide # and Type of Containers INDICATE ANALYSIS REQUESTED Lab Use Only Sample ID Date/Time Sampled Matrix # and Type of Containers X Indicate to the requested analysis?. If yes, please provide Quice Quice 3 Day (50% Surcharge) Billing Water Indicate to the requested analysis?. If yes, please provide Indicate to the requested analysis?. If yes, please provide Quice Sample ID Date/Time Sampled Matrix Indicate to the requested analysis?. If yes, please provide Indicate to the requested analysis?. If yes, please provide Quice Af & B Quice Indicate to t	Email: jeffery.faust@	@jsheld.com	Fax:			Clie	ent	Com	me	nts:		<u></u>												
231100311/RGSD/ Decrem Ratt&cn RESULTS REQUESTED BILLING INSTRUCTIONS E N <t< td=""><td>Are these samples known Are there any required repo limits in the comment section</td><td>to be hazardous?</td><td>Yes X N requested analysi</td><td>No sis?. If yes, pl</td><td>lease provide</td><td></td><td>Ea</td><td>W(Y</td><td>. (</td><td>hi</td><td>idt</td><td>-</td><td></td><td></td><td></td><td></td><td></td><td>-</td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	Are these samples known Are there any required repo limits in the comment section	to be hazardous?	Yes X N requested analysi	No sis?. If yes, pl	lease provide		Ea	W(Y	. (hi	idt	-						-						
Verify / Unr & Crit RESULTS REQUESTED BILLING INSTRUCTIONS I ab use Only Sample ID Date/Time Sampled Matrix		MBER	L _			#	and	I Typ		f Co	ntai	ner	<u>s</u>									UES)
Lab Use Only Sample ID Date/Time Sampled Matrix Matrix 2uO200493045 26B 2/9/24 6:00 AM Drinking Water X	23110031171(0007		Veron	Kaths	cn					Ì				ē										-Constanting
Lab Use Only Sample ID Date/Time Sampled Matrix Matrix 2uO200493045 268 2/9/24 6:00 AM Drinking Water X			÷	BILLIN	IG INSTRUCTIONS	⊆	Ę	Na	;] <u> </u>	s s	NaH	-	ç	id drin									ı l	
Lab Use Only Sample ID Date/Time Sampled Matrix Matrix 2uO200493045 268 2/9/24 6:00 AM Drinking Water X						F	ÍO3	<u>ک</u> ا کے	36	위호	Iso	SP	her	king w										
24020293 cuts 268 2/9/24 6 600 AM Drinking Water X			-	<u> </u>	Т	┛│					4			ater										
OHK 27A Prinking Water Image: Constraint of the second seco	Lab Use Only					╉┽	_		╇		╇	⊢	┯╇	_	╞	╞╾┙	┝─┥	┝┻╋	ᆋ	╇		┢╍┙	ļļ	
040 278 Drinking Water 1			2/9/24	6:00 AM		┞┤	\rightarrow		+	⊥	╇			<u> </u>	1			\square		\bot	<u> </u>		,	_
OHF 2 & 8 A Drinking Water Image: Constraint of the second descent of the second descent d	Cure		<u> </u>		Drinking Water	┛	\dashv		_		\square	\square									<u> </u> _'	\square		
049 A 8 B Drinking Water Image: Constraint of the second se	<u></u>				Drinking Water		\bot		_	<u> </u>	\square	Ц						\square			\bot			
OSD 24A Drinking Water Image: Constraint of the second	OUP	28A			Drinking Water															\bot				
1 298 Drinking Water 1 1 1 052 30A Drinking Water 1 1 1 1 053 30B Drinking Water 1 1 1 1 054 31A Drinking Water 1 1 1 1 055 31B Drinking Water 1 1 1 1 055 31B Drinking Water 1 1 1 1 055 31B Drinking Water 1 1 1 1	049	<u>28B</u>			Drinking Water																			
OS 30 Å Drinking Water OS3 30 B OS3 30 B OS4 31 Å OS5 31 B Drinking Water OS5 31 B Drinking Water Drinking Water Drinking Water OS5 31 B Drinking Water Drinking Water <td>050</td> <td>29A</td> <td></td> <td></td> <td>Drinking Water</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Т</td> <td>T</td> <td></td> <td></td> <td></td> <td></td> <td>Т</td> <td>T</td> <td>\square</td> <td>T</td> <td></td>	050	29A			Drinking Water									Т	T					Т	T	\square	T	
30 A Drinking Water Image: Constraint of the second secon	051	298			Drinking Water					Γ				T	1				T	T		\square		
SS3 SOB Drinking Water O54 31 A O55 31 B Relinquished By Date/Time Received By Date/Time		30A			Drinking Water				Τ	Ι				T	1	\square			1		1-1			
OFH 31 Å Drinking Water OF5 31 B Drinking Water Relinquished By Date/Time Received By Date/Time	53	30B			Drinking Water				T						1				1	1	+1	\square		11
31 B Drinking Water Relinquished By Date/Time Received By Date/Time	· · · ·	31 A			Drinking Water		Τ		Τ				T						T	T				
	055		v					Τ	Ι						į				Τ		\Box			
Veron Rathbun 219124 Sils AM Emily Southet 2/9/24 815										_														
	Veron Rathby	<u>⁄/n</u>		219124	Bils Am	\downarrow_{4}	<u> </u>	m	Å	ý		1_	z lle	đ	¢.			`	<u>z [</u>	<u>at</u>	24	<u>.</u>	8	5
						<u> </u>	<u> </u>			/								+						
			!	<u> </u>	······								<u> </u>											
						┼──						<u> </u>		·····				_	<u></u>					



http://www.teklabinc.com/

March 08, 2024

Jeff Faust J.S. Held #6 Meadow Heights Professional Park Collinsville, IL 62234 TEL: (618) 343-3590 FAX: (618) 343-3597

RE: 231100311 / RGSD / Early Childhood



WorkOrder: 24020823

Dear Jeff Faust:

TEKLAB, INC received 38 samples on 2/9/2024 8:15:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marin J. Darling I

Marvin L. Darling Project Manager (618)344-1004 ex 41 mdarling@teklabinc.com



Report Contents

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

Work Order: 24020823 Report Date: 08-Mar-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

Work Order: 24020823

Report Date: 08-Mar-24

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
- DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)

eklab, Inc.

Definitions

Qualifiers

http://www.teklabinc.com/

Work Order: 24020823

Report Date: 08-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Work Order: 24020823 Report Date: 08-Mar-24

Client: J.S. Held Client Project: 231100311 / RGSD / Early Childhood

Cooler Receipt Temp: N/A °C

linsville Horseshoe Lake Road Isville, IL 62234-7425 344-1004	Address	Springfield 3920 Pintail Dr		Kansas City
asville, IL 62234-7425	Address	3920 Pintail Dr	A didanga	
,			Address	8421 Nieman Road
344-1004		Springfield, IL 62711-9415		Lenexa, KS 66214
344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998
344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998
y@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com
linsville Air		Chicago		
Horseshoe Lake Road	Address	1319 Butterfield Rd.		
sville, IL 62234-7425		Downers Grove, IL 60515		
344-1004	Phone	(630) 324-6855		
344-1005	Fax			
	Email	arenner@teklabinc.com		
H H S	nsville Air forseshoe Lake Road ville, IL 62234-7425 44-1004	nsville Air iorseshoe Lake Road ville, IL 62234-7425 44-1004 44-1005 Fax	Insville AirChicagoiorseshoe Lake RoadAddress1319 Butterfield Rd.ville, IL 62234-7425Downers Grove, IL 6051544-1004Phone(630) 324-6855	Insville AirChicagoiorseshoe Lake RoadAddress1319 Butterfield Rd.ville, IL 62234-7425Downers Grove, IL 6051544-1004Phone(630) 324-6855



Accreditations

http://www.teklabinc.com/

Work Order: 24020823

Report Date: 08-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



http://www.teklabinc.com/

Work Order: 24020823

Report Date: 08-Mar-24

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

Matrix:	DRINKING WATER

Sample ID	Client Sample ID	Certification Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	4, 200.8 R5.4, META	LS BY ICPMS (TOTAL	.)					
Lead		· ·						
24020823-001	A 32A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 15:10	02/09/2024 6:00
24020823-002	A 32B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 15:13	02/09/2024 6:00
24020823-003	A 33A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 15:17	02/09/2024 6:00
24020823-004	A 33B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 15:21	02/09/2024 6:00
24020823-005	A 34A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 18:40	02/09/2024 6:00
24020823-006	A 34B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:02	02/09/2024 6:00
24020823-007	A 35A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:06	02/09/2024 6:00
24020823-008	A 35B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:09	02/09/2024 6:00
24020823-009	A 36A	NELAP	1.0	4.1	µg/L	1	03/07/2024 19:13	02/09/2024 6:00
24020823-010	A 36B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:17	02/09/2024 6:00
24020823-011	A 37A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:20	02/09/2024 6:00
24020823-012	A 37B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:24	02/09/2024 6:00
24020823-013	A 38A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:28	02/09/2024 6:00
24020823-014	A 38B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:31	02/09/2024 6:00
24020823-015	A 39A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:46	02/09/2024 6:00
24020823-016	A 39B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 19:57	02/09/2024 6:00
24020823-017	A 40A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:01	02/09/2024 6:00
24020823-018	A 40B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:04	02/09/2024 6:00
24020823-019	A 41A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:08	02/09/2024 6:00
24020823-020	A 41B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:12	02/09/2024 6:00
24020823-021	A 42A	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:15	02/09/2024 6:00
24020823-022	A 42B	NELAP	1.0	< 1.0	µg/L	1	03/07/2024 20:19	02/09/2024 6:00
24020823-023	A 43A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:25	02/09/2024 6:00
24020823-024	A 43B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:29	02/09/2024 6:00
24020823-025	A 44A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:33	02/09/2024 6:00
24020823-026	A 44B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:44	02/09/2024 6:00
24020823-027	A 45A	NELAP	1.0	3.5	µg/L	1	03/06/2024 17:47	02/09/2024 6:00
24020823-028	A 45B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:51	02/09/2024 6:00
24020823-029	A 46A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:55	02/09/2024 6:00
24020823-030	A 46B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 17:58	02/09/2024 6:00
24020823-031	A 48A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:13	02/09/2024 6:00
24020823-032	A 48B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:16	02/09/2024 6:00
24020823-033	A 49A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:20	02/09/2024 6:00
24020823-034	A 49B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:24	02/09/2024 6:00
24020823-035	A 50A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:27	02/09/2024 6:00
24020823-036	A 50B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:38	02/09/2024 6:00
24020823-037	A 51A	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:42	02/09/2024 6:00
24020823-038	A 51B	NELAP	1.0	< 1.0	µg/L	1	03/06/2024 18:46	02/09/2024 6:00



Receiving Check List

http://www.teklabinc.com/

Client: J.S. Held

Client Project: 231100311 / RGSD / Early Childhood

Work Order: 24020823 Report Date: 08-Mar-24

Carrier: Devon Rathbun	Recei	ved By: EES		
Completed by: On: 12-Feb-24 Dilallo		iewed by: n: eb-24]	Elled Hopke Ellie Hopkins	nD
Pages to follow: Chain of custody 4	Extra pages included	1 0		
Shipping container/cooler in good condition?	Yes 🗸	No	Not Present	Temp °C N/A
Type of thermal preservation?	None 🗸		Blue Ice	Dry Ice
Chain of custody present?	Yes 🔽	No 🗌		
Chain of custody signed when relinquished and received?	Yes 🗹	No 🗌		
Chain of custody agrees with sample labels?	Yes 🖌	No 🗌		
Samples in proper container/bottle?	Yes 🗹	No 🗌		
Sample containers intact?	Yes 🗹	No 🗌		
Sufficient sample volume for indicated test?	Yes 🗹	No 🗌		
All samples received within holding time?	Yes 🗹	No 🗌		
Reported field parameters measured:	Field	Lab	NA 🔽	
Container/Temp Blank temperature in compliance?	Yes 🗹	No 🗌		
When thermal preservation is required, samples are complia 0.1°C - 6.0°C, or when samples are received on ice the sam		between		
Water – at least one vial per sample has zero headspace?	Yes	No	No VOA vials 🖌	
Water - TOX containers have zero headspace?	Yes	No	No TOX containers	
Water - pH acceptable upon receipt?	Yes 🗹	No	NA 🗌	
NPDES/CWA TCN interferences checked/treated in the field?	Yes	No 🗌	NA 🗹	
Any No responses	must be detailed belo	ow or on the	COC.	

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

Print DDE

Print PDF				CHAIN OF C	US'	то	DY	r			Pg	6.	of <u>&</u>	. Wo	rkord	der #	# <u> </u>	<u>4(</u>)7(8 <u>X</u>	23 A2	۔ ير	ie m
TEKLAB INC.	5445 Horseshoe La	ike Road. C	Collinsvill	e. IL 62234 Phon	<u>e (6</u>	18)	34	4-11	004	I Fa	<u>x (</u>	<u>518)</u>	34	4-11	<u>)</u> 05		,					2	m
Client: J.S. Held LLC	· · · · · ·				Sa	mple	es or	ı:	Г		Ξ		BL	UE IO)E	মি	NO	ICE	N	A	°C		
	Heights Professional Pa	rk					ved i		¥	,] LAI	3	П	FIEL			, <u> </u>	i i				- Y		
City/State/Zip: Collins	ville, IL 62234						OTES		<u>م</u>	4											ц <u>.</u>		
Contact: Jeff Faust	· · · · · · · · · · · · · · · · · · ·	Phone: (61	18) 343-35	90																			
Email: jeffery.faust@]jsheld.com	Fax:			СІІ	ent	Con	nme	nts	:													
Are these samples known t	orting limits to be met on the on:	Yes X-N	ło is?. If yes, pl	ease provide	l	Eq	repo VIY	-7	h	ild				IND	<u>C 41</u>		NAT	Vel	e Di		FOT		
231100311 / RGSD /	MDER					and	d Ty _l	peo				rs 									ESTE	<u>-0</u>	
RES	ULTS REQUESTED		ł	NG INSTRUCTIONS	UNP	HNO3	NaOH	H2SO4	MeOH	NaHSO4	TSP	Other	tead drinking water										
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix					_	_	ļ.												
2402-0823-	32A	219/24	6:00 AA	Drinking Water						_	L		1										
02	32 B			Drinking Water																		-	
<u> </u>	33A			Drinking Water																			
004	33 B			Drinking Water																			
05	34 A			Drinking Water																			
ade	345			Drinking Water															Π	Т		Π	
m	35 A			Drinking Water									П	1			Ť	T		Ť			
800	35 F			Drinking Water													\top	Τ	\square	1			
009	364			Drinking Water													T	-	\square	T			
	36B			Drinking Water															\square				
<u> </u>	37 A	•	¥	Drinking Water									X	·		T							
	elinquished By			Date/Time						Rec	eive	d By							Da	ate/T	Time	Conservation of Conservation o	
Ukren Rethbur		••••••••••	219124	8:15 AM	+		<u>~</u>	ili 			42	i <i>d</i>	<u></u>	A				z/9	pu	L	8/	$\sum_{i=1}^{i}$	
www																	-						

Print PDF

CHAIN	OF	CUS	TOD	¥
-------	----	-----	-----	---

Pg <u>7</u> of <u>9</u> Workorder # <u>24020693</u> TE 2/14/14 TEKLAB INC. 5445 Horseshoe Lake Road. Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: J.S. Held LLC					Sai	npl	es o	n:	Г	1 10	Έ	Г		21 1 1	EICE	= [⁻			:F	i and the second second second second second second second second second second second second second second se	,	°C		
1	v Heights Professional Par	'k				-	ved		L	_	AB	L	4	ELD		- L								
City/State/Zip: Collins							veu OTE		L		мD	Ĺ					FU	<u>K L</u> A	<u>B US</u>		DNLY			
Contact: Jeff Faust	,	Phone: (61	8) 343-359	90	LA			э.																
	Disheld com		.,														· · · ·			·			-	
		Fax:					Co																	
	to be involved in litigation? If y			Yes 🗶 No			e rep			-														
Are these samples known Are there any required rep	orting limits to be met on the n	Yes X N equested analysi	io s?, if ves, pl	ease provide		E	ari	4	C	Lil	Jh	00	ł											
limits in the comment sect	ion: Yes	No	-										•											
PROJECT NAME/NU	JMBER	SAMPLE CO			#	and	d Ty	rpe	of (Cont	tain	ers		IN	IDIC	ATE	AN	ALY	'SIS	RE	QUE	STE	D	
231100311 / RGSD /		Teron	Rathbu	n				ŀ														Τ		\square
RES	ULTS REQUESTED		BILLIN	IG INSTRUCTIONS		_	_	ェ			z			lead drinking water										
Standard	1-2 Day (100% Si	urcharge)			NP	HNO3	a	2SC	되			Other		hinkin										
Other	3 Day (50% Surch	÷ .			ľ	ŭ	Ξ	4		MeOH	3 ,	ΊΨ		g wate										
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix	1									4										
WOWPLY On	378	219124 6	OO AM	Drinking Water							-		\square	χ	1						-			300 0 00
03	3 <i>8</i> A		1	Drinking Water				1	-					ĥ			╈				+	+	\vdash	
QИ	38B			Drinking Water							\top	1					\uparrow			+	+			
05	394		1	Drinking Water													1			-				
OILE	39B			Drinking Water												1	\top				+			-
012	YOA		1	Drinking Water					╡			1			+		+			+	+	\square		-
018	YOB		1	Drinking Water			T		1		Τ						+		\square		+	┢━┥	\square	┥
019	41A			Drinking Water													+			+	+	\square	\vdash	-
020	41B			Drinking Water							T						╈			╈	╈		+	
021	42 A			Drinking Water								Τ	Π	$\uparrow \uparrow$	$\neg \uparrow$	\top	1			╈	┿		H	-
022	Ча в	0	U	Drinking Water								Τ	Π	X								\square		
	Relinquished By			Date/Time						Re	ceiv	ed I	Ву							Dat	te/Ti	ne		
Peron Rathburn			2/9/24	giis Am	L	جر	$\overline{\gamma}$	u			Ja	a h	Il	4				21	19/2	34	2	Ś Ś	<u>)</u>	
					(_							-											
																				•••••				
					 												·	 			<u></u>			_
																								1

STODY
STODY

JEm

Print PDF					CHAIN OF CL	JST	ГО	D	Y				Pg	8	of	<u>í</u> n	Vork	ord	er#	2	<u>4c</u>)2	<u>M</u>	8	いみ	びない
TEKLAB INC. 544	<u>5 Horseshoe La</u>	ke R	<u>oad, C</u>	Collinsvill	e, IL 62234 Phone	<u>e (6</u>	18)	34	4-	100)4	Fax	<u>x (C</u>	518) 3/	14-	<u>10</u> 0)5								4
Client: J.S. Held LLC						Sar	nple	es o	n:			ICE			BI	_UE		Ξ [NO I	ICE			°C		
Address: #6 Meadow Heig	hts Professional Par	k				Pre	ser	ved	in:	İ		_AB	;		FIE	LD		-		DR L	.AB U	JSE	ONL	<u>.</u> Y		
City/State/Zip: Collinsville,	IL 62234					LAE	3 N	OTE	S:																	İ
Contact: Jeff Faust		Pho	one: (61	18) 343-359	90																					
Email: jeffery.faust@jshe	ld.com	Fax	c			Clie	ent	Co	mm	ien	ts:							. ,					100007300000	lainten anna		-1994
Are these samples known to be in Are these samples known to be h Are there any required reporting I limits in the comment section:	nazardous?	Yes equeste	۸ ed analysi	lo is?. If yes, pl	ease provide		E	rep QN	У.	Ċ	ĥi												<u> </u>			
PROJECT NAME/NUMBE 231100311 / RGSD /	R	I	-			#	and	d Ty	/pe	of	Cor	ntai	ner	s	- 1	IN						S RI	EQU	IEST		
20110001171(0007			evon	Rathsu	'n											B										
RESULTS ✓ Standard Other	REQUESTED 1-2 Day (100% Si 3 Day (50% Surct)		ge)	BILLIN	IG INSTRUCTIONS	UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other		lead drinking waler										
Lab Use Only	Sample ID	Dat	te/Time	Sampled	Matrix											×										-
	(3A	214	<u>1/14 6</u>	ioo Am	Drinking Water											X										
	<u>13 B</u>				Drinking Water									\square		Ц										
025	<u>44A</u>	L	ļ		Drinking Water																					
Ore	цив		[Drinking Water																					
07	45 A				Drinking Water																					
028	<u>Ч5 в</u>				Drinking Water									[Τ	T		ΓT	T		
029	46A				Drinking Water									[Τ					Τ				Т	Т	
030	<u>468</u>				Drinking Water														Τ						Τ	
031	48A				Drinking Water											Π						\square			Т	
032	ygb				Drinking Water		ł							[T	
N33	49A	L R		<u> </u>	Drinking Water											χŢ										
	quished By				Date/Time						_		ive	d B	у	_				T			ate/"			
Devon Rathbun				2/9/24	8:ISAM		E		n	<u>ıl</u>	Ż		4	ŦĻ		4					2/9	1/7	24		<u> 515</u>	<u>></u>
· · · · · · · · · · · · · · · · · · ·																		•••••								

CHAIN	OF	CUST	ODY
-------	----	------	-----

Print PDF				CHAIN OF CU	JS	тс	D	Y				Pg_	1 of	9	Workc <u>-10</u> 0	order	#	26	10	20	5	13 q 2	, - 5 I	TE Sm
TEKLAB INC,	5445 Horseshoe La	ike Road, C	ollinsvill	e. IL 62234 Phon	e (6	518) 34	44-	100	04	Fax	(6	18) (344	<u>-10</u> 0	5							,	2.m
Client: J.S. Held LLC					Sa	ımpi	les d	on:			ICE			BLU	E ICE	Ī	NC		=			°C		
	Heights Professional Par	rk	·····		Pr	ese	rved	l in:			LAB		Ŭ F	EL)		FOR	LAE	us	EOM	ILY			
City/State/Zip: Collins	ville, IL 62234					B N	IOTE	ES:		-			_			-								ĺ
Contact: Jeff Faust		Phone: (61	8) 343-359	90																				
Email: jeffery.faust@)jsheld.com	Fax:			С	ient	t Co	omm	nen	ts:														-
Are these samples known t	orting limits to be met on the r	Yes 🔀 N	o s?. If yes, pl	ease provide			ar (r	C	opb Lil Cor			-	11	NDICA	ATE	ANA		315	REG		STE		
231100311 / RGSD /		Devon	_		-											T			T		T		T	-
✓ Standard Other	ULTS REQUESTED	urcharge) harge)	BILLIN		UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other	lead drinking water										
Lab Use Only	Sample ID	Date/Time S		Matrix							_	_	_		1 - 11 - 11 - 11 - 11 - 11 - 11 - 11 -		┞┤	_		_	ļ	┝		
24020823 034	<u>49</u> B	2/9/24 6	00 A.M	Drinking Water	4						_	_		X						_	ļ			
035	<u>50A</u>	<u> </u>		Drinking Water								_	_	r			$\left \right $	_+		_	-			_
036	<u>508</u>	<u> </u>		Drinking Water	┫						_	+	+	X		_								_
037	<u>51A</u>	<u>├ </u>		Drinking Water	-						-	_	-	X		_		_	_			┝─┤		_
038	513		•	Drinking Water Drinking Water	╉─							+		x			┢╌┤		_		╞			_
				Drinking Water	-								-				┞┦	\dashv	_	_	-		_	-
				Drinking Water							+	+	+-				┠─┤				-			_
				Drinking Water	╉──						+						╀╌┦		_					_
	···			Drinking Water	╉						+	-					┞╎		+		<u> </u>		+	_
				Drinking Water	╋							+		1					+	+			-+-	-
R	elinquished By			Date/Time						R	eçei	ived	By	- -						Date	/Tir	ne ne		-
Decon Rather	^		2/9/2	4 8:15 Am	(È	m	lý	<u> </u>	/_	1 _a ,	_//	M	1				2/	9/1	24		81	5	
				······································																				

APPENDIX C CREDENTIALS

STATE OF MISSOURI DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Anthony W. Hagerty

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

> Lead Risk Assessor Category of License

Issuance Date: Expiration Date: License Number: 10/17/2022 10/31/2024 161031-300005062



Daven I. Nichels

Paula F. Nickelson Acting Director Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102



SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

Anthony Hagerty

5249 Miami Street, St. Louis, MO 63139

contact hours of training and successfully passed examination for ω has attended

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 32512/11/2023 **193536** Examination Date: 12/11/2023 CEUs: 0.8

Reve Dulle

Rene Dulle, MBA, Director Center for Environmental Education & Training

Center for Environmental Education and Training | 3545 Lafayette Ave., St. Louis, MO 63104 (314) 977-8256 |slu.edu/public-health-social-justice/centers-institutes/ceet.php The training course has been accredited by the Missouri Dept. of Health and Senior Services, and by the Illinois Dept. of Public Health. Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health.

State of Missouri Department of Natural Resources

Certificate of Approval for Chemical Laboratory Service

This is to certify that

Teklab, Incorporated

is hereby approved to perform the analysis of drinking water as specified on the Certified Parameter List, which must accompany this certificate to be valid.


Certification Number 930

Date Issued December 13, 2021

Expiration Date January 31, 2025

Laboratory Certification Authority, Public Drinking Water Branch Missouri Department of Natural Resources

Laboratory Certification Officer, Environmental Services Program Missouri Department of Natural Resources



located at

5445 Horseshoe Lake Road, Collinsville, IL 62234

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

EPA 335.4 Total Cyanide

EPA 353.2 Nitrate, Nitrite, Total Nitrate and Nitrite

EPA 245.1 Mercury

EPA 200.7 Barium, Beryllium, Cadmium, Chromium, Copper, Nickel

EPA 200.8

Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Copper, Lead, Nickel, Selenium, Thallium

SM4500F-C Fluoride

SM4500NO2-B Nitrite

Teklab, Incorporated Expiration Date: January 31, 2025 Missouri Certificate No.: 930 Original Certifying State: Illinois