

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Report Date: 08/14/24**Project:** 208 South Mountain Avenue, Montclair Township, Monclair NJ 07042 – YCS Sawtelle Learning Center**Sample Date/Time:** 08/06/24 09:43-10:44**Sampled By:** Bryan Cartal**Collection Point:** #211 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 16:56

Collection Point: #209 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 17:02

Collection Point: #202 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 17:04

Collection Point: #200 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	1.04	15 ug/L	EPA 200.8	03036	08/12/24 17:06

Collection Point: #212 Tap A**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 17:08

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Collection Point: #212 Tap B
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:37

Collection Point: #216 Tap A
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:42

Collection Point: #214 Tap
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:44

Collection Point: #218 Tap
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	1.16	15 ug/L	EPA 200.8	03036	08/12/24 19:46

Collection Point: #225 Tap
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	3.65	15 ug/L	EPA 200.8	03036	08/12/24 19:52

Collection Point: #226 Tap
Treatment: No Treatment System
Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:54

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Collection Point: #227 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:56

Collection Point: 2nd Floor Water Cooler**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 19:58

Collection Point: #118 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:00

Collection Point: #121 Tap A**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:02

Collection Point: #121 Tap B**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:04

Collection Point: #112 Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:09

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Collection Point: #114 Tap A**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:15

Collection Point: #114 Tap B**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:17

Collection Point: #113 Tap A**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	1.30	15 ug/L	EPA 200.8	03036	08/12/24 20:19

Collection Point: #113 Tap B**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:21

Collection Point: 1st Floor Staff Bathroom A**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:23

Collection Point: 1st Floor Staff Bathroom B**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:25

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510

Laboratory Cert# 21016

Collection Point: 1st Floor Water Cooler**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:26

Collection Point: Basement Office**Treatment:** No Treatment System**Sample Type:** First Draw


Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 20:28

Collection Point: Gymnasium Tap**Treatment:** No Treatment System**Sample Type:** First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	12.6	15 ug/L	EPA 200.8	03036	08/12/24 18:51

Analytical results **ARE below** the Action Level (AL) of 15 ug/L for lead

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.

Harold Blaine
Laboratory Manager

AL – Action Level

ND – Not detected

 Red Bold Result – Parameter has exceeded the action level (AL) for safe drinking water.