

HORIZON ENVIRONMENTAL GROUP, INC.

P.O. Box 316
Thorofare, NJ 08086

Phone: 856-848-0800
Fax: 856-848-0838

January 15, 2022

Mr. John Swanson
Paulsboro Board of Education
662 North Delaware Street
Paulsboro, NJ 08066

Reference: Lead in Water Testing at Billingsport Early Childhood Center (First Draw Samples - 211114)

Dear Mr. Swanson:

Pursuant to your request, collection and analysis of thirty-two (32) first draw water samples from the domestic water supply system at the Billingsport Early Childhood Center facility have been completed. In accordance with applicable New Jersey guidelines, the samples were collected in the morning on Sunday, November 14, 2021, by personnel from Horizon Environmental Group, Inc., and submitted for analysis for the presence of lead using inductively coupled plasma mass spectrometry (ICP-MS) in accordance with USEPA Method 200.8. The results of the analyses of the samples are as follows:

Sample No.	Location	Lead Concentration ($\mu\text{g/L}$)	Reporting Limit ($\mu\text{g/L}$)
B-DW-08	APR - Sink #1	3.25	1.00
B-DW-10	APR - Sink #2	3.15	1.00
B-DW-06	Nurse's Office - Sink	16.7	1.00
B-DW-11	Hall near Room 10	9.06	1.00
B-DW-15	Room 10	ND	1.00
B-DW-12A	Hall near Room 9 (Filler)	53.6	1.00
B-DW-12B	Hall near Room 9 (Cooler)	49.3	1.00
B-DW-16	Room 11	2.57	1.00
B-DW-14	Room 9	ND	1.00
B-DW-13	Room 8	5.13	1.00
B-DW-17	Room 12	ND	1.00
B-DW-21	Teacher's Lounge	9.06	1.00
B-DW-25	Room 35 - Fountain	5.06	1.00
B-DW-27	Room 35 - Sink	11.7	1.00
B-DW-22	Room 34 - Fountain	5.38	1.00
B-DW-24	Room 34 - Sink	5.89	1.00
B-DW-28	Room 36 - Fountain	6.84	1.00
B-DW-30	Room 36 - Sink	4.29	1.00
B-DW-31	Room 37 - Fountain	5.21	1.00
B-DW-33	Room 37 - Sink	9.90	1.00

Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
B-DW-03A	Hall near Room 1 (Filler)	ND	1.00
B-DW-03B	Hall near Room 1 (Cooler)	ND	1.00
B-DW-19A	Hall near Room 21 (Filler)	ND	1.00
B-DW-19B	Hall near Room 21 (Cooler)	ND	1.00
B-DW-02A	Hall near Room 2 (Filler)	1.44	1.00
B-DW-02B	Hall near Room 2 (Cooler)	ND	1.00
B-DW-18A	Hall near Room 22 (Filler)	ND	1.00
B-DW-18B	Hall near Room 22 (Cooler)	ND	1.00
B-DW-35	Librarian's Office - Faucet	21.2	1.00
B-DW-36	Room 7	ND	1.00
B-DW-37	Room 38	1.54	1.00
211114-B-BLANK	BLANK	ND	1.00

Note: "ND" equals none detected; "µg/L" equals micrograms per liter which is equivalent to parts per billion (ppb)

The following samples exceeded the "action level" of 15 µg/L (ppb) established by the United States Environmental Protection Agency and adopted by the State of New Jersey.

Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
B-DW-06	Nurse's Office - Sink	16.7	1.00
B-DW-12A	Hall near Room 9 (Filler)	53.6	1.00
B-DW-12B	Hall near Room 9 (Cooler)	49.3	1.00
B-DW-35	Librarian's Office - Faucet	21.2	1.00

The "action level" of 15 µg/L (ppb) does not necessarily signal a violation, but would trigger additional monitoring, maintenance, treatment and/or mitigation requirements. It is our understanding that these fixtures have been taken out of service and will not be used until "flush" samples are collected from them or repairs are made. Regarding the fixtures where lead was detected, but at a level below the action level, it is recommended that those fixtures be flushed periodically.

All laboratory analysis was performed by the trained staff at EMSL Analytical, Inc. in Cinnaminson, New Jersey and a copy of the analysis document is attached. If you have any questions or need more information, please do not hesitate to contact us at (856) 848-0800.

Sincerely,
HORIZON ENVIRONMENTAL GROUP, INC.



Steven J. Flanigan
Vice President



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

11/30/2021

Phone: (609) 221-4660

Fax: (856) 848-0838

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/15/2021. The results are tabulated on the attached data pages for the following client designated project:

94015-65/ Billingsport ECC

The reference number for these samples is EMSL Order #012113233. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-08
APR Sink #1
Collected: 11/14/2021 7:01:00 AM
Lab ID: 012113233-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.25	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:06

Client Sample Description B-DW-10
APR Sink #2
Collected: 11/14/2021 7:01:00 AM
Lab ID: 012113233-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.15	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:10

Client Sample Description B-DW-06
Nurse's Office - Sink
Collected: 11/14/2021 7:04:00 AM
Lab ID: 012113233-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.7	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:15

Client Sample Description B-DW-11
Hall Near Room 10
Collected: 11/14/2021 7:06:00 AM
Lab ID: 012113233-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.06	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:16

Client Sample Description B-DW-15
Room 10
Collected: 11/14/2021 7:06:00 AM
Lab ID: 012113233-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-12A
 Hall Near Rm 9 (Filler) **Collected:** 11/14/2021 7:07:00 AM **Lab ID:** 012113233-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	53.6	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:19

Client Sample Description B-DW-12B
 Hall Near Rm 9 (Filler) **Collected:** 11/14/2021 7:07:00 AM **Lab ID:** 012113233-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	49.3	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:20

Client Sample Description B-DW-16
 Room 11 **Collected:** 11/14/2021 7:10:00 AM **Lab ID:** 012113233-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.57	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:22

Client Sample Description B-DW-14
 Room 9 **Collected:** 11/14/2021 7:11:00 AM **Lab ID:** 012113233-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:23

Client Sample Description B-DW-13
 Room 8 **Collected:** 11/14/2021 7:12:00 AM **Lab ID:** 012113233-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.13	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 14:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-17
Room 12
Collected: 11/14/2021
7:14:00 AM
Lab ID: 012113233-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:26

Client Sample Description B-DW-21
Teacher's Lounge
Collected: 11/14/2021
7:16:00 AM
Lab ID: 012113233-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.06	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:34

Client Sample Description B-DW-25
Room 35- Fountain
Collected: 11/14/2021
7:16:00 AM
Lab ID: 012113233-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.06	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:35

Client Sample Description B-DW-27
Room 35- Sink
Collected: 11/14/2021
7:17:00 AM
Lab ID: 012113233-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:37

Client Sample Description B-DW-22
Room 34-Fountain
Collected: 11/14/2021
7:17:00 AM
Lab ID: 012113233-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.38	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
Fax: (856) 848-0838
Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-24
Room 34 - Sink
Collected: 11/14/2021
7:19:00 AM
Lab ID: 012113233-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.89	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:40

Client Sample Description B-DW-28
Room 36 - Fountain
Collected: 11/14/2021
7:19:00 AM
Lab ID: 012113233-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.84	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:41

Client Sample Description B-DW-30
Room 36 - Sink
Collected: 11/14/2021
7:20:00 AM
Lab ID: 012113233-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.29	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:42

Client Sample Description B-DW-31
Room 37 - Fountain
Collected: 11/14/2021
7:20:00 AM
Lab ID: 012113233-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.21	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 14:25

Client Sample Description B-DW-33
Room 37 - Sink
Collected: 11/14/2021
7:23:00 AM
Lab ID: 012113233-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.90	1.00 µg/L	11/22/2021 KB	11/23/2021 KB 00:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-03A
 Hall Near Rm 1 (Filler) **Collected:** 11/14/2021 7:23:00 AM **Lab ID:** 012113233-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 19:53

Client Sample Description B-DW-03B
 Hall Near Rm 1 (Cooler) **Collected:** 11/14/2021 7:26:00 AM **Lab ID:** 012113233-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:01

Client Sample Description B-DW-19A
 Hall Near Rm 21 (Filler) **Collected:** 11/14/2021 7:26:00 AM **Lab ID:** 012113233-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:02

Client Sample Description B-DW-19B
 Hall Near Room 21 (Cooler) **Collected:** 11/14/2021 7:26:00 AM **Lab ID:** 012113233-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:04

Client Sample Description B-DW-02A
 Hall Near Room 2 (Filler) **Collected:** 11/14/2021 7:27:00 AM **Lab ID:** 012113233-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.44	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
 Fax: (856) 848-0838
 Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description B-DW-02B
 Hall Near Room 2 (Cooler) **Collected:** 11/14/2021 7:27:00 AM **Lab ID:** 012113233-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:07

Client Sample Description B-DW-18A
 Hall Near Room 22 (Filler) **Collected:** 11/14/2021 7:30:00 AM **Lab ID:** 012113233-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:08

Client Sample Description B-DW-18B
 Hall Near Room 22 (Cooler) **Collected:** 11/14/2021 7:30:00 AM **Lab ID:** 012113233-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:10

Client Sample Description B-DW-35
 Librarian's Office - Faucet **Collected:** 11/14/2021 7:32:00 AM **Lab ID:** 012113233-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.2	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:11

Client Sample Description B-DW-36
 Room 7 **Collected:** 11/14/2021 7:34:00 AM **Lab ID:** 012113233-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113233

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
P.O. Box 316
Thorofare, NJ 08086

Phone: (609) 221-4660
Fax: (856) 848-0838
Received: 11/15/2021 02:05 AM

Project: 94015-65/ Billingsport ECC

Analytical Results

Client Sample Description	B-DW-37 Room 3	Collected:	11/14/2021 7:35:00 AM	Lab ID:	012113233-0031
----------------------------------	-------------------	-------------------	--------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.54	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:17

Client Sample Description	211114-B-BLANK Blank	Collected:	11/14/2021 7:36:00 AM	Lab ID:	012113233-0032
----------------------------------	-------------------------	-------------------	--------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/23/2021 KB	11/23/2021 KB 20:21

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results



Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

012113233

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Company: Horizon Environmental Group, Inc.		EMSL-Bill to: <input type="checkbox"/> Different <input checked="" type="checkbox"/> Same If Bill to is Different note instructions in Comments**	
Street: P. O. Box 316		Third Party Billing requires written authorization from third party	
City: Thorofare	State/Province: NJ	Zip/Postal Code: 08086	Country: US
Report To (Name): David Flanigan		Telephone #: 856-848-0800	
Email Address: horizonenvgroup@gmail.com		Fax #: 856-848-0838	Purchase Order:
Project Name/Number: 94015-65 / Billingsport ECC		Please Provide Results: <input type="checkbox"/> FAX <input checked="" type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: NJ		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week			
*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide			
Matrix	Method	Instrument	Reporting Limit
Chips <input type="checkbox"/> % by wt. <input type="checkbox"/> mg/cm ² <input type="checkbox"/> ppm	SW846-7000B	Flame Atomic Absorption	0.01%
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter
	NIOSH 7300 modified	ICP-AES/ICP-MS	0.5 µg/filter
Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM <input type="checkbox"/> *If no box is checked, non-ASTM Wipe is assumed	SW846-7000B	Flame Atomic Absorption	10 µg/wipe
	SW846-6010B or C	ICP-AES	1.0 µg/wipe
	SW846-7000B/7010	Graphite Furnace AA	0.075 µg/wipe
TCLP	SW846-1311/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW846-1131/7000B/6010B or C	ICP-AES	0.1 mg/L (ppm)
Soil	SW846-7000B	Flame Atomic Absorption	40 mg/kg (ppm)
	SW846-7010	Graphite Furnace AA	0.3 mg/kg (ppm)
	SW846-6010B or C	ICP-AES	2 mg/kg (ppm)
Wastewater Unpreserved <input type="checkbox"/> Preserved with HNO ₃ pH < 2 <input type="checkbox"/>	SM3111B/7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.7	ICP-AES	0.020 mg/L (ppm)
Drinking Water Unpreserved <input type="checkbox"/> Preserved with HNO ₃ pH < 2 <input checked="" type="checkbox"/>	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
TSP/SPM Filter	40 CFR Part 50	ICP-AES	12 µg/filter
	40 CFR Part 50	Graphite Furnace AA	3.6 µg/filter
Other:			
Name of Sampler: S. FLANIGAN / D. FLANIGAN		Signature of Sampler: <i>[Signature]</i>	
Sample #	Location	Volume/Area	Date/Time Sampled
1	B-DW-08	APR SINK #1	11/14/21 0701
2	B-DW-10	APR SINK #2	0701
3	B-DW-06	NURSE'S OFFICE - SINK	0704
4	B-DW-11	HALL NEAR ROOM 10	0706
5	B-DW-15	Room 10	0706
Client Sample #'s		Total # of Samples: 32	
Relinquished (Client): <i>[Signature]</i>	Date: 11/15/21	Time: 2:00 pm	
Received (Lab): <i>[Signature]</i>	Date: 11/15/21	Time: 2:05 pm	
Comments:			

**LEAD (Pb) CHAIN OF CUSTODY**

EMSL ORDER ID (Lab Use Only):

012113233

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
6	B-DW-12A	Hall near Rm 9 (FLOOR)	11/14/21 0707
7	B-DW-12B	Hall near Rm 9 (COOLER)	0707
8	B-DW-16	Room 11	0709
9	B-DW-14	Room 9	0710
10	B-DW-13	Room 8	0711
11	B-DW-17	Room 12	0712
12	B-DW-21	TEACHER'S LOUNGE	0714
13	B-DW-25	Room 35 - FOUNTAIN	0716
14	B-DW-27	Room 35 - SINK	0716
15	B-DW-22	Room 34 - FOUNTAIN	0717
16	B-DW-24	Room 34 - SINK	0717
17	B-DW-28	Room 36 - FOUNTAIN	0719
18	B-DW-30	Room 36 - SINK	0719
19	B-DW-31	Room 37 - FOUNTAIN	0720
20	B-DW-33	Room 37 - SINK	0720
21	B-DW-03A	Hall near Rm 1 (FLOOR)	0723
22	B-DW-03B	Hall near Rm 1 (COOLER)	0723
23	B-DW-19A	Hall near Rm 21 (FLOOR)	✓ 0726
Comments/Special Instructions:			



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

0/2/13233

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

