

SECTION 009113 – ADDENDUM

PART 1 - Addendum 1

1.1 PROJECT INFORMATION

- A. Project Name: RFP 266 Roof Replacement Building 3 & 4; RFP 269 Roof Replacement Building 7
- B. Owner: Riverview Gardens School District.
- C. Date of Addendum: 08/24/2022.

1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.

1.3 ADDITIONAL INFORMATION FOR SCOPE OF WORK

- A. **Building 7 Scope of work change in insulation:**
  - 1. Install 2 layers of 2.6 inch polyisocyanurate insulation instead of tapered insulation.
  - 2. The attachment of the insulation remains the same.
- B. **Building 3, 4, and 7 Scope of work addition:**
  - 1. Paint all gas lines with rust inhibiting yellow paint.
  - 2. Install all new wood supports under conduits and glycol lines.
  - 3. Install wood blocking under glycol lines every 8 feet, with protection pad. This must be completed prior to installing the aggregate surfacing.

END OF SECTION 009113