## **ALL-STATE WELL TESTING SERVICES, LLC**

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510 Laboratory Cert# 21016

**Report Date:** 08/15/24

Project: 386 Hudson Street, Hackensack City, Hackensack NJ 07601 - GW School (George Washington School)

**Sample Date/Time:** 08/06/24 11:20 – 11:56

Sampled By: Bryan Cartal

Collection Point: Room #117 Tap A Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	
Lead	1.65 ug/L	15 ug/L.	EPA 200.8	03036	08/13/24 17:52

**Collection Point:** Room #117 Tap B **Treatment:** No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	
Lead	3.97 ug/L	15 ug/L	EPA 200.8	03036	08/13/24 17:54

**Collection Point**: Main Office Tap **Treatment**: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert#	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 16:23

Collection Point: Room #118 Tap A Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	2.84 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:29

Collection Point: Room #118 Tap B
Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	2.45 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:31

## **ALL-STATE WELL TESTING SERVICES, LLC**

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510 Laboratory Cert# 21016

**Collection Point:** 2<sup>nd</sup> Floor Staff Bathroom Tap **Treatment:** No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	3.65 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:33

Collection Point: Room #204 Tap Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	2.28 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:38

Collection Point: 2nd Floor Janitor's Closet

Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 16:40

Collection Point: 2nd Floor Girl's Bathroom Tap A

Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert#	Analysis Date/Time
Lead	1.73 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 17:17

Collection Point: 2nd Floor Girl's Bathroom Tap B

**Treatment:** No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert#	Analysis Date/Time
Lead	1.70 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:44

Collection Point: 3rd Floor Boy's Bathroom Tap A

Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert#	Analysis Date/Time
Lead	1.76 ug/L	15 ug/L	EPA 200.8	03036	08/12/24 16:46

## **ALL-STATE WELL TESTING SERVICES, LLC**

11-13 BROAD STREET, WASHINGTON, NEW JERSEY 07882, (908) 835-2510 Laboratory Cert# 21016

Collection Point: 3rd Floor Boys Bathroom Tap B

Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert#	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 16:48

Collection Point: 3rd Floor Staff Bathroom

Treatment: No treatment systems

Sample Type: First Draw

Parameter	Result	AL	Method	NJ Cert #	Analysis Date/Time
Lead	ND	15 ug/L	EPA 200.8	03036	08/12/24 16:50

Analytical results ARE below the Action Level (AL) of 15 ug/L for Lead

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.

Harold Blaine

Laboratory Manager

AL - Action Level ND - Not detected