

Environmental Consultants
And Laboratory Services

(203) 324-2222
Fax(203) 324-9857



49 Woodside Street Stamford, CT 06902

December 22, 2016

New Milford Schools
Attn. Kevin Munrett

Re: Radon Re-evaluation
Northville Elementary School

To Whom It May Concern:

Enclosed with this letter are the results of radon testing conducted at the above mentioned site. The radon testing was conducted in accordance with Connecticut Department of Public Health radon re-evaluation protocols. The testing was conducted over a three day period – December 12-15, 2016. The radon kits were sent via FedEx to Air Chek, Inc. in Mills River, NC for radon analysis. Listed below is a summary of the testing results:

<u>Kit Number</u>	<u>Location</u>	<u>Results</u>
• Kit # 7824235	Room 12	0.6 pCi/L
• Kit # 7824236	Room 18	<0.3 pCi/L
• Kit # 7824243	Room 20	0.5 pCi/L
• Kit # 7824240	Room 27	0.7 pCi/L
• Kit # 7824239	Room 32	<0.3 pCi/L
• Kit # 7824234	Room 6	<0.3 pCi/L
• Kit # 7824237	Library Office	<0.3 pCi/L
• Kit # 7824238	QA/QC	<0.3 pCi/L
• Kit # 7824241	Music Office	<0.3 pCi/L
• Kit # 7824242	QA/QC	<0.3 pCi/L

As shown on the attached analysis report, none of the test kits deployed during this round of testing returned results that exceeded the **EPA action level of 4 pCi/L**.

For further information, please refer to the following websites:

<https://www.epa.gov/radon>

http://www.ct.gov/dph/cwp/view.asp?a=3140&q=387592&dphNav_GID=1828&dphPNa_vCtr=#47072

I am certified by the National Radon Safety Board (Certification Number 7SS0001), and listed on the Connecticut Department of Public Health list of "Radon Measurement Professionals". If you have questions or would like to discuss the radon testing, please call me at 203-324-2222 or e-mail me at rebenhack@hygenix.com.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ryan Ebenhack", with a long, sweeping flourish extending to the right.

Ryan Ebenhack MS CIEC
Hygenix, Inc.

*Attachments: Laboratory Results
Site Layout with sample locations*


December 21, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
NEW MILFORD SCHOOLS
NES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824235	12	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	0.6 ± 0.2	2016-12-17
7824236	18	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824243	20	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	0.5 ± 0.2	2016-12-17
7824240	27	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	0.7 ± 0.2	2016-12-17
7824239	32	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824234	6	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824237	LIBRARY OFFICE	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824238	LIBRARY OFFICEB	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824241	MUSIC	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824242	MUSICD	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



NES

(8)

11/15 - 11/17/11

ROOMS TESTED :

- MAIN OFFICE
- PRINCIPAL OFFICE
- 30
- 21
- 10
- 8
- 5
- 5 office



Test locations 12/12 - 12/15/16