


# Structural Calculations

## Grant Union HS HVAC

911 S. Canyon Blvd.  
John Day, Oregon 97845

**Prepared for:**

Grant County School District  
401 N. Canyon City Blvd.  
Canyon City, OR 97820



EXPIRES: 06-30-24



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# DESIGN CRITERIA

<b>Project</b>	Project Number	P-2869-23
	Project Name	Grant Union HS HVAC
<b>Address</b>	Legal Description of Property	
	Street Address	911 S. Canyon Blvd.
	City, State Zip-Code	John Day, Oregon 97845
<b>Client</b>	Client	Grant County School District
	Address	401 N. Canyon City Blvd. Canyon City, OR 97820
<b>Contact</b>	Contact	Mark Witty
	Phone	541-575-1799
	Fax	
	Email	<a href="mailto:markwitty@grantesd.org">markwitty@grantesd.org</a>
<b>Billing</b>	Bill to	Grant County School District
	Billing Address	401 N. Canyon City Blvd. Canyon City, OR 97820

# BUILDING DEPARTMENT INTERVIEW

<b>Governing Body &amp; Building Type</b>	Building Department	Grant County	
	Governing Codes	Building: 2022 OSSC	ASCE: ASCE 7-16
	Occupancy & Risk Category	Educational	III
<b>Snow Loading</b>	Ground Snow Load	8.00	psf
	Minimum Roof Snow Load?	Yes	20.00 psf
	Exposure of Roof	Partially Exposed	
	Duration Factor for Wood?	Yes	
<b>Wind Loading</b>	Design Wind Speed	108	mph LRFD
	Enclosure Classification	Enclosed Buildings	
	Exposure Classification	C	
	Roof Angle	0.5/12	2.39°
	Mean Height	20.00 ft	
	Site Elevation	3,140 ft	
<b>Seismic Loading</b>	Topographic Factor ( $K_{zt}$ )	1.000	
	Wind Elevation Factor ( $K_e$ )	0.893	
	Site Soil Classification	Site Class D – Stiff Soil	
	Seismic Design Category	C	
	Acceleration Parameters:	<b>ASCE 7</b>	
	Short-Period	$S_s = 0.310$ g	$S_{DS} = 0.321$
	One Second	$S_1 = 0.123$ g	$S_{D1} = 0.193$
Component Importance Factor	$I_p = 1.00$		
<b>Soil Loading</b>	Geotech Report	No	
	Soil Bearing Pressure	1,500	
	Frost Depth	24.00 in	



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD


# ASCE 7-16 DESIGN WIND SPEED



**Address:**  
911 S Canyon Blvd  
John Day, Oregon  
97845

## ASCE 7 Hazards Report

<b>Standard:</b>	ASCE/SEI 7-16	<b>Latitude:</b>	44.405029
<b>Risk Category:</b>	III	<b>Longitude:</b>	-118.947804
<b>Soil Class:</b>	D - Default (see Section 11.4.3)	<b>Elevation:</b>	3144.1274532695556 ft (NAVD 88)



## Wind

### Results:

Wind Speed	107 Vmph	← USE 108 MPH PER OSSC
10-year MRI	69 Vmph	
25-year MRI	76 Vmph	
50-year MRI	80 Vmph	
100-year MRI	86 Vmph	

Data Source: ASCE/SEI 7-16, Fig. 26.5-1C and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Mon Nov 06 2023

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 3% probability of exceedance in 50 years (annual exceedance probability = 0.000588, MRI = 1,700 years).

Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# ASCE 7-16 SEISMIC DESIGN CRITERIA



911 S Canyon Blvd, John Day, OR 97845, USA

Latitude, Longitude: 44.4042044, -118.948402



Date	11/6/2023, 8:51:47 AM
Design Code Reference Document	ASCE7-16
Risk Category	III
Site Class	D - Default (See Section 11.4.3)

Type	Value	Description
S <sub>S</sub>	0.31	MCE <sub>R</sub> ground motion. (for 0.2 second period)
S <sub>1</sub>	0.123	MCE <sub>R</sub> ground motion. (for 1.0s period)
S <sub>MS</sub>	0.481	Site-modified spectral acceleration value
S <sub>M1</sub>	0.289	Site-modified spectral acceleration value
S <sub>DS</sub>	0.321	Numeric seismic design value at 0.2 second SA
S <sub>D1</sub>	0.193	Numeric seismic design value at 1.0 second SA

Type	Value	Description
SDC	C	Seismic design category
F <sub>a</sub>	1.552	Site amplification factor at 0.2 second
F <sub>v</sub>	2.354	Site amplification factor at 1.0 second
PGA	0.139	MCE <sub>G</sub> peak ground acceleration
F <sub>PGA</sub>	1.522	Site amplification factor at PGA
PGA <sub>M</sub>	0.212	Site modified peak ground acceleration
T <sub>L</sub>	16	Long-period transition period in seconds
SsRT	0.31	Probabilistic risk-targeted ground motion. (0.2 second)
SsUH	0.34	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
SsD	1.5	Factored deterministic acceleration value. (0.2 second)
S1RT	0.123	Probabilistic risk-targeted ground motion. (1.0 second)
S1UH	0.137	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
S1D	0.6	Factored deterministic acceleration value. (1.0 second)
PGAd	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# SNOW LOADS

## Site & Building Design Criteria

Ground Snow Load, $p_g$ =	8.00 <i>psf</i>	Exposure of Roof =	Partially Exposed
Snow Density, $\gamma$ =	15.04 <i>pcf</i>	Exposure Category =	C
Importance Factor, $I_s$ =	1.10	Exposure Factor, $C_e$ =	1.00

## Flat & Sloped Roof Snow Loads

Roof	Roof Slope		Obstructe d	Rain on Snow?	Thermal Factor $C_t$	Slope Factor $C_s$	Flat Roof SL $p_f$ ( <i>psf</i> )	Design Roof SL $p_f$ ( <i>psf</i> )	Sloped Roof SL $p_s$ ( <i>psf</i> )
	X:12	$\theta^\circ$							
1	0.5	2.39	Yes	No	1	1.00	6.16	22.00	22.00
2	2.5	11.77	Yes	No	1	1.00	6.16	22.00	22.00



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# SEAO GROUND SNOW LOAD

## Oregon Snow Loading

The design ground snow of any location in the state of Oregon may be determined by entering the latitude and longitude of your site into the boxes below. The tool provides the design ground snow load (pg in ASCE7\*) for your site. The design ground snow load values can also be viewed on the online map. Users are strongly recommended to review the Map Usage Notes.

Ground snow loads are very sensitive to geographic location, and particularly sensitive to elevation. It is recommended that the latitude and longitude values be entered with a precision of 0.001 (about 105 yards).

\* ASCE Standard (ASCE/SEI 7-10) *Minimum Design Loads for Buildings and Other Structures* published by the American Society of Civil Engineers.

### Latitude - Longitude Lookup

#### Results

Latitude: 44.40076460

Longitude: -118.94889190

Snow Load: 8.0 psf

Modeled Elevation: 3307 ft

#### Site Elevation versus Modeled Grid Elevation

Site elevation refers to the elevation (above sea level, in feet) of the location for which the snow load is required. The modeled grid elevation is the average elevation of the 4 km (about 2-1/2 miles) grid cell that was used in the snow load modeling. In relatively flat terrain, the two elevations will likely be the same or very similar. In sloped or mountainous terrain, the two elevations may be quite different.

The design ground snow load may be underreported for some locations where the site elevation is higher than the modeled grid elevation. Consult the Map Usage Notes if your site elevation is more than 100 ft. above the modeled grid elevation shown, or if your site is at or near the top of a hill.

#### Oregon Design Ground Snow Load Look Up Results

It is important that the user of this tool understand the principals and limitations of the modeling used to create it. Ground snow loads can vary dramatically over short distances due to changes in precipitation and elevation. It is critical to use good engineering judgment when interpreting and using the results reported by this tool. The user is recommended to review the online map, to gain a better understanding of the variations and range of magnitudes of the ground snow loads in the vicinity of the site location.

In remote regions at high elevation, reliable snow data was not available during the creation of the map. A site-specific case study is required to determine the design ground snow load in these areas. The ground snow load values on the map are based on extrapolation, and are not recommended for design. See the Map Usage Notes for the regions that require a site-specific case study.

It is recommended that the local building official having jurisdiction at the site be consulted for minimum design ground snow or roof snow loads.

The reported design ground snow loads must be adjusted as required by Chapter 7 of ASCE7\* for site exposure, roof slope, roof configuration, etc. Only the properly adjusted loads can be used to design roof structural elements.

Oregon requires a minimum roof snow load of 20 psf (pm in ASCE7\*) for all roofs, plus a 5 psf rain-on-snow surcharge for many roof types, resulting in a 25 psf minimum roof design load for most roofs. See the Map Usage Notes or *Snow Load Analysis for Oregon, Part II* for further information.

\* ASCE Standard (ASCE/SEI 7-10) *Minimum Design Loads for Buildings and Other Structures* published by the American Society of Civil Engineers.



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# GRAVITY LOADS

<u>Upper Roof Dead Load</u>		<u>Load (psf)</u>	<u>Lower Roof Dead Load</u>		<u>Load (psf)</u>
Roofing Type:	Comp Roofing (2-Layers)	4.5	Roofing Type:	TPO	0.7
Sheathing:	1/2" Plywood Sheathing	1.4	Roofing Type:	1/2" Gyp	2.2
Sheathing:	2x6 T&G Decking	4.3	Sheathing:	5/8" Plywood Sheathing	1.8
Roof Framing:	Engr'd Trusses/Rafters @ 48 OC	1.5	Roof Framing:	2x6 T&G Decking	4.3
Insulation:	12" Batt Insulation	0.5	Insulation:	6" Rigid Insulation	1.5
Ceiling:	NA	0.0	Ceiling:	NA	0.0
Misc:	Misc.	2.0	Misc:		2.0
Total:		14.2 psf	Total:		12.5 psf
<u>Slope Correction</u>		<b>Use Sloped:</b> 14.5 psf	<u>Slope Correction</u>		<b>Use Sloped:</b> 13.0 psf
3/12	0.98	<b>Use Flat:</b> 15.0 psf	1/12	1.00	<b>Use Flat:</b> 13.0 psf

---

<u>Roof Live Load</u>	<u>Load (psf)</u>
Snow	<b>Use: 22.0 psf</b>
Live	<b>Use: 20.0 psf</b>



## SEISMIC DEMANDS ON NONSTRUCTURAL COMPONENTS

### HVAC GROUND UNITS & DUST COLLECTOR

#### Seismic Design Criteria

Building Occupancy Risk Category	Risk Category =	III	Table 1.5-1
Seismic Importance Factor ( $I_p$ )	$I_p =$	1.00	Table 1.5-2
Site Soil Classification	Site Class =	D	11.4.2
Structure Height ( $h_n$ )	$h_n =$	20.00 ft	12.8.2.1
Attachment Height ( $z$ )	$z =$	0.00 ft	
Short-Period Acceleration Parameter ( $S_s$ )	$S_s =$	0.310 g	11.4.1
One Second Acceleration Parameter ( $S_1$ )	$S_1 =$	0.123 g	
Seismic Design Category (SDC)	SDC =	C	11.6
Long-Period Transition Period ( $T_L$ )	$T_L =$	16 sec	12.8.1.1
Regular Structure Less than 5 Stories, w/ Redundancy Factor =1.0 ?		Yes	12.8.1.3
Site Adjusted Short-Period Acceleration ( $S_{MS}$ )	$S_{MS} = F_a S_s$	$S_{MS} = 0.481$ g	11.4.3
Site Adjusted One Second Acceleration ( $S_{M1}$ )	$S_{M1} = F_v S_1$	$S_{M1} = 0.290$ g	
Design Short-Period Acceleration ( $S_{DS}$ )	$S_{DS} = (\frac{2}{3}) S_{MS}$	$S_{DS} = 0.321$ g	11.4.4
Design One Second Acceleration ( $S_{D1}$ )	$S_{D1} = (\frac{2}{3}) S_{M1}$	$S_{D1} = 0.193$ g	
Approximate Fundamental Period, conservative ( $T_a$ )	$T_a = 0.02 * h_n^{0.75}$	$T_a = 0.189$ sec	12.8.2.1
(For All Other Structural Systems)			

#### Seismic Response Coefficient: Nonstructural Component

Architectural Component	Include Overstrength Factor? <span style="color: blue;">Yes</span>			13.3.1 Table 13.5-1
	$a_p^a$	$R_p$	$\Omega_0^c$	
Air-side HVACR, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical components constructed of sheet metal framing	2 1/2	6	2	
Horizontal Seismic Coefficient Minimum ( $C_{c min}$ )		$C_{c min} = 0.096$		13.3-3
Horizontal Seismic Coefficient ( $C_c$ )		$C_c = 0.053$		
Horizontal Seismic Coefficient Maximum ( $C_{c max}$ )		$C_{c max} = 0.513$		13.3-2
<b>Horizontal Seismic Coefficient (<math>C_c</math>)</b>		<b><math>C_c = 0.096</math></b>		13.3-1
<b>Vertical Seismic Coefficient (<math>C_{cv}</math>)</b>	$C_{cv} = 0.2 * S_{DS}$	<b><math>C_{cv} = 0.064</math></b>		13.3.1

$$C_{c min} = 0.3 S_{DS} I_p$$

$$C_{c max} = 1.6 S_{DS} I_p$$

$$C_c = \frac{0.4 a_p S_{DS}}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{Z}{h}\right)$$







## SEISMIC DEMANDS ON NONSTRUCTURAL COMPONENTS

### GENERATOR

#### Seismic Design Criteria

Building Occupancy Risk Category		Risk Category =	III	Table 1.5-1
Seismic Importance Factor ( $I_p$ )		$I_p =$	1.00	Table 1.5-2
Site Soil Classification		Site Class =	D	11.4.2
Structure Height ( $h_n$ )		$h_n =$	20.00 ft	12.8.2.1
Attachment Height ( $z$ )		$z =$	0.00 ft	
Short-Period Acceleration Parameter ( $S_s$ )		$S_s =$	0.310 g	11.4.1
One Second Acceleration Parameter ( $S_1$ )		$S_1 =$	0.123 g	
Seismic Design Category (SDC)		SDC =	D	11.6
Long-Period Transition Period ( $T_L$ )		$T_L =$	16 sec	12.8.1.1
Regular Structure Less than 5 Stories, w/ Redundancy Factor =1.0 ?			Yes	12.8.1.3
Site Adjusted Short-Period Acceleration ( $S_{MS}$ )	$S_{MS} = F_a S_s$	$S_{MS} =$	0.481 g	11.4.3
Site Adjusted One Second Acceleration ( $S_{M1}$ )	$S_{M1} = F_v S_1$	$S_{M1} =$	0.290 g	
Design Short-Period Acceleration ( $S_{DS}$ )	$S_{DS} = (\frac{2}{3}) S_{MS}$	$S_{DS} =$	0.321 g	11.4.4
Design One Second Acceleration ( $S_{D1}$ )	$S_{D1} = (\frac{2}{3}) S_{M1}$	$S_{D1} =$	0.193 g	
Approximate Fundamental Period, conservative ( $T_a$ )	$T_a = 0.02 * h_n^{0.75}$	$T_a =$	0.189 sec	12.8.2.1
(For All Other Structural Systems)				

#### Seismic Response Coefficient: Nonstructural Component

Architectural Component	Include Overstrength Factor? <span style="color: blue;">Yes</span>			13.3.1 Table 13.5-1
	$a_p^a$	$R_p$	$\Omega_0^c$	
Generators, batteries, inverters, motors, transformers, and other electrical components constructed of high-deformability materials	1	2 1/2	2	
Horizontal Seismic Coefficient Minimum ( $C_{c min}$ )			$C_{c min} = 0.096$	13.3-3
Horizontal Seismic Coefficient ( $C_c$ )			$C_c = 0.051$	
Horizontal Seismic Coefficient Maximum ( $C_{c max}$ )			$C_{c max} = 0.513$	13.3-2
<b>Horizontal Seismic Coefficient (<math>C_c</math>)</b>			<b><math>C_c = 0.096</math></b>	13.3-1
<b>Vertical Seismic Coefficient (<math>C_{cv}</math>)</b>	$C_{cv} = 0.2 * S_{DS}$		<b><math>C_{cv} = 0.064</math></b>	13.3.1

$$C_{c min} = 0.3 S_{DS} I_p$$

$$C_{c max} = 1.6 S_{DS} I_p$$

$$C_c = \frac{0.4 a_p S_{DS}}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{Z}{h}\right)$$





PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# GROUND EQUIPMENT SEISMIC DESIGN

## HVAC GROUND UNITS

### Ground Equipment

Length of Equipment ( $L$ )	$L =$	7.39 ft
Depth of Equipment ( $D$ )	$D =$	4.44 ft
Height of Equipment ( $H$ )	$H =$	3.91 ft
Weight of Equipment ( $W$ )	$W =$	1239 lbs

### Seismic Forces on Equipment

Horizontal Seismic Coefficient ( $C_c$ )	$C_c =$	0.096
Vertical Seismic Coefficient ( $C_{cv}$ )	$C_{cv} =$	0.064
Horizontal Seismic Force ( $F_H$ )	$F_H =$	119 lbs
Vertical Seismic Force ( $F_V$ )	$F_V =$	79 lbs

### Overturning Moment

Center of Force	$H_C =$	1.96 ft
Overturning Moment	$M_O =$	233 ft-lbs

### Resistive Moment

Center of Force	$D_C =$	2.22 ft
Resistive Moment	$M_R =$	2751 ft-lbs

 $M_R > M_O$  No Net Overturning

### Net Tension per Anchor

Vertical Seismic Force ( $F_V$ )	$F_V =$	79 lbs
Overstrength Factor	$\Omega =$	2
Vertical Seismic Force ( $F_V$ ) w/ Overstrength	$\Omega * F_V =$	159 lbs
Number of Anchors	$n =$	4
Seismic Vertical Force Per Anchor	$F_V =$	40 lbs
Dead Load Per Anchor	$DL =$	310 lbs
Net Tension Force Per Anchor, $T = F_V - 0.6 * DL$	$T =$	-146 lbs

 $T < 0$  No Net Tension

### Net Shear per Anchor

Horizontal Seismic Force ( $F_H$ )	$F_H =$	119 lbs
Overstrength Factor	$\Omega =$	2
Horizontal Seismic Force ( $F_H$ ) w/ Overstrength	$\Omega * F_H =$	238 lbs
Number of Anchors	$n =$	4
Seismic Shear Per Anchor	$V =$	60 lbs



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# GROUND EQUIPMENT SEISMIC DESIGN

## DUST COLLECTOR

### Ground Equipment

Length of Equipment ( $L$ )	$L =$	5.00 ft
Depth of Equipment ( $D$ )	$D =$	3.67 ft
Height of Equipment ( $H$ )	$H =$	10.50 ft
Weight of Equipment ( $W$ )	$W =$	400 lbs

### Seismic Forces on Equipment

Horizontal Seismic Coefficient ( $C_c$ )	$C_c =$	0.096
Vertical Seismic Coefficient ( $C_{cv}$ )	$C_{cv} =$	0.064
Horizontal Seismic Force ( $F_H$ )	$F_H =$	38 lbs
Vertical Seismic Force ( $F_V$ )	$F_V =$	26 lbs

### Overturning Moment

Center of Force	$H_C =$	7.46 ft
Overturning Moment	$M_O =$	287 ft-lbs

### Resistive Moment

Center of Force	$D_C =$	1.83 ft
Resistive Moment	$M_R =$	733 ft-lbs

 $M_R > M_O$  No Net Overturning

### Net Tension per Anchor

Vertical Seismic Force ( $F_V$ )	$F_V =$	26 lbs
Overstrength Factor	$\Omega =$	2
Vertical Seismic Force ( $F_V$ ) w/ Overstrength	$\Omega * F_V =$	51 lbs
Number of Anchors	$n =$	4
Seismic Vertical Force Per Anchor	$F_V =$	13 lbs
Dead Load Per Anchor	$DL =$	100 lbs
Net Tension Force Per Anchor, $T = F_V - 0.6 * DL$	$T =$	-47 lbs

 $T < 0$  No Net Tension

### Net Shear per Anchor

Horizontal Seismic Force ( $F_H$ )	$F_H =$	38 lbs
Overstrength Factor	$\Omega =$	2
Horizontal Seismic Force ( $F_H$ ) w/ Overstrength	$\Omega * F_H =$	77 lbs
Number of Anchors	$n =$	4
Seismic Shear Per Anchor	$V =$	19 lbs



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

## GROUND EQUIPMENT SEISMIC DESIGN

### GENERATOR

#### Ground Equipment

Length of Equipment ( $L$ )	$L =$	14.42 ft
Depth of Equipment ( $D$ )	$D =$	6.08 ft
Height of Equipment ( $H$ )	$H =$	6.75 ft
Weight of Equipment ( $W$ )	$W =$	29000 lbs

#### Seismic Forces on Equipment

Horizontal Seismic Coefficient ( $C_c$ )	$C_c =$	0.096
Vertical Seismic Coefficient ( $C_{cv}$ )	$C_{cv} =$	0.064
Horizontal Seismic Force ( $F_H$ )	$F_H =$	2790 lbs
Vertical Seismic Force ( $F_V$ )	$F_V =$	1860 lbs

#### Overturning Moment

Center of Force	$H_C =$	3.38 ft
Overturning Moment	$M_O =$	9418 ft-lbs

#### Resistive Moment

Center of Force	$D_C =$	3.04 ft
Resistive Moment	$M_R =$	88208 ft-lbs

 $M_R > M_O$  No Net Overturning

#### Net Tension per Anchor

Vertical Seismic Force ( $F_V$ )	$F_V =$	1860 lbs
Overstrength Factor	$\Omega =$	2
Vertical Seismic Force ( $F_V$ ) w/ Overstrength	$\Omega * F_V =$	3721 lbs
Number of Anchors	$n =$	4
Seismic Vertical Force Per Anchor	$F_V =$	930 lbs
Dead Load Per Anchor	$DL =$	7250 lbs
Net Tension Force Per Anchor, $T = F_V - 0.6 * DL$	$T =$	-3420 lbs

 $T < 0$  No Net Tension

#### Net Shear per Anchor

Horizontal Seismic Force ( $F_H$ )	$F_H =$	2790 lbs
Overstrength Factor	$\Omega =$	2
Horizontal Seismic Force ( $F_H$ ) w/ Overstrength	$\Omega * F_H =$	5581 lbs
Number of Anchors	$n =$	4
Seismic Shear Per Anchor	$V =$	1395 lbs



Company:	ZCS	Date:	2/17/2023
Engineer:	BLD	Page:	1/5
Project:	P-2869-23 - Grant Union HS HVAC		
Address:			
Phone:			
E-mail:			

### 1. Project information

Project description:

Location:

Fastening description:

### 2. Input Data & Anchor Parameters

#### General

Design method: ACI 318-19

Units: Imperial units

#### Anchor Information:

Anchor type: Concrete screw

Material: Carbon Steel

Diameter (inch): 0.375

Nominal Embedment depth (inch): 2.500

Effective Embedment depth,  $h_{ef}$  (inch): 1.770

Code report: ICC-ES ESR-2713

Anchor category: 1

Anchor ductility: No

$h_{min}$  (inch): 4.00

$c_{ac}$  (inch): 2.69

$C_{min}$  (inch): 1.75

$S_{min}$  (inch): 3.00

#### Base Material

Concrete: Normal-weight

Concrete thickness,  $h$  (inch): 4.00

State: Cracked

Compressive strength,  $f'_c$  (psi): 2500

$\Psi_{c,v}$ : 1.0

Reinforcement condition: Supplementary reinforcement not present

Supplemental edge reinforcement: Not applicable

Reinforcement provided at corners: No

Ignore concrete breakout in tension: No

Ignore concrete breakout in shear: No

Ignore  $\phi_{do}$  requirement: Not applicable

Build-up grout pad: No

#### Recommended Anchor

Anchor Name: Titen HD® - 3/8"Ø Titen HD,  $h_{nom}$ : 2.5" (64mm)

Code Report: ICC-ES ESR-2713





Company:	ZCS	Date:	2/17/2023
Engineer:	BLD	Page:	2/5
Project:	P-2869-23 - Grant Union HS HVAC		
Address:			
Phone:			
E-mail:			


**Load and Geometry**

Load factor source: ACI 318 Section 5.3  
Load combination: not set  
Seismic design: Yes  
Anchors subjected to sustained tension: Not applicable  
Ductility section for tension: 17.10.5.2 not applicable  
Ductility section for shear: 17.10.6.2 not applicable  
 $\Omega_0$  factor: not set  
Apply entire shear load at front row: Yes  
Anchors only resisting wind and/or seismic loads: Yes

Strength level loads:

$N_{ua}$  [lb]: 0  
 $V_{uax}$  [lb]: 0  
 $V_{uay}$  [lb]: 60


<Figure 1>





Company:	ZCS	Date:	2/17/2023
Engineer:	BLD	Page:	3/5
Project:	P-2869-23 - Grant Union HS HVAC		
Address:			
Phone:			
E-mail:			

<Figure 2>





Company:	ZCS	Date:	2/17/2023
Engineer:	BLD	Page:	4/5
Project:	P-2869-23 - Grant Union HS HVAC		
Address:			
Phone:			
E-mail:			

### 3. Resulting Anchor Forces

Anchor	Tension load, N <sub>ua</sub> (lb)	Shear load x, V <sub>uax</sub> (lb)	Shear load y, V <sub>uay</sub> (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	0.0	0.0	60.0	60.0
Sum	0.0	0.0	60.0	60.0

Maximum concrete compression strain (%): 0.00  
 Maximum concrete compression stress (psi): 0  
 Resultant tension force (lb): 0  
 Resultant compression force (lb): 0  
 Eccentricity of resultant tension forces in x-axis, e'<sub>Nx</sub> (inch): 0.00  
 Eccentricity of resultant tension forces in y-axis, e'<sub>Ny</sub> (inch): 0.00  
 Eccentricity of resultant shear forces in x-axis, e'<sub>Vx</sub> (inch): 0.00  
 Eccentricity of resultant shear forces in y-axis, e'<sub>Vy</sub> (inch): 0.00

### 8. Steel Strength of Anchor in Shear (Sec. 17.7.1)

V <sub>sa</sub> (lb)	$\phi_{grout}$	$\phi$	$\phi_{grout}\phi V_{sa}$ (lb)
2855	1.0	0.60	1713

### 9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.7.2)

Shear perpendicular to edge in y-direction:

$$V_{by} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a}\lambda_a\sqrt{f'_c}c_{a1}^{1.5}; 9\lambda_a\sqrt{f'_c}c_{a1}^{1.5}] \text{ (Eq. 17.7.2.2.1a \& Eq. 17.7.2.2.1b)}$$

l <sub>e</sub> (in)	d <sub>a</sub> (in)	λ <sub>a</sub>	f' <sub>c</sub> (psi)	c <sub>a1</sub> (in)	V <sub>by</sub> (lb)
1.77	0.375	1.00	2500	5.50	3771

$$\phi V_{cby} = \phi (A_{vc}/A_{vco})\Psi_{ed,v}\Psi_{c,v}\Psi_{h,v}V_{by} \text{ (Sec. 17.5.1.2 \& Eq. 17.7.2.1a)}$$

A <sub>vc</sub> (in <sup>2</sup> )	A <sub>vco</sub> (in <sup>2</sup> )	Ψ <sub>ed,v</sub>	Ψ <sub>c,v</sub>	Ψ <sub>h,v</sub>	V <sub>by</sub> (lb)	φ	φV <sub>cby</sub> (lb)
66.00	136.13	1.000	1.000	1.436	3771	0.70	1838

### 10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.7.3)

$$\phi V_{cp} = \phi K_{cp}N_{cb} = \phi K_{cp}(A_{Nc}/A_{Nco})\Psi_{ed,N}\Psi_{c,N}\Psi_{cp,N}N_b \text{ (Sec. 17.5.1.2 \& Eq. 17.7.3.1a)}$$

K <sub>cp</sub>	A <sub>Nc</sub> (in <sup>2</sup> )	A <sub>Nco</sub> (in <sup>2</sup> )	Ψ <sub>ed,N</sub>	Ψ <sub>c,N</sub>	Ψ <sub>cp,N</sub>	N <sub>b</sub> (lb)	φ	φV <sub>cp</sub> (lb)
1.0	28.20	28.20	1.000	1.000	1.000	2002	0.70	1401

### 11. Results

#### Interaction of Tensile and Shear Forces (Sec. 17.8)

Shear	Factored Load, V <sub>ua</sub> (lb)	Design Strength, φV <sub>n</sub> (lb)	Ratio	Status

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.





Anchor Designer™  
Software  
Version 3.2.2311.2

Company:	ZCS	Date:	2/17/2023
Engineer:	BLD	Page:	5/5
Project:	P-2869-23 - Grant Union HS HVAC		
Address:			
Phone:			
E-mail:			

Steel	60	1713	0.04	Pass
T Concrete breakout y+	60	1838	0.03	Pass
<b>Pryout</b>	<b>60</b>	<b>1401</b>	<b>0.04</b>	<b>Pass (Governs)</b>

**3/8"Ø Titen HD, hnom:2.5" (64mm) meets the selected design criteria.**

## **12. Warnings**

- Minimum spacing and edge distance requirement of 6da per ACI 318 Table 17.9.2(a) for torqued cast-in-place anchor is waived per designer option.\n

- Per designer input, the tensile component of the strength-level earthquake force applied to anchors does not exceed 20 percent of the total factored anchor tensile force associated with the same load combination. Therefore the ductility requirements of ACI 318 17.10.5.2 for tension need not be satisfied – designer to verify.

- Per designer input, the shear component of the strength-level earthquake force applied to anchors does not exceed 20 percent of the total factored anchor shear force associated with the same load combination. Therefore the ductility requirements of ACI 318 17.10.6.2 for shear need not be satisfied – designer to verify.

- Designer must exercise own judgement to determine if this design is suitable.

- Refer to manufacturer's product literature for hole cleaning and installation instructions.



## SEISMIC DEMANDS ON NONSTRUCTURAL COMPONENTS

### HVAC HUNG UNITS

#### Seismic Design Criteria

Building Occupancy Risk Category	Risk Category =	III	Table 1.5-1
Seismic Importance Factor ( $I_p$ )	$I_p =$	1.00	Table 1.5-2
Site Soil Classification	Site Class =	D	11.4.2
Structure Height ( $h_n$ )	$h_n =$	20.00 ft	12.8.2.1
Attachment Height ( $z$ )	$z =$	30.00 ft	
Short-Period Acceleration Parameter ( $S_s$ )	$S_s =$	0.310 g	11.4.1
One Second Acceleration Parameter ( $S_1$ )	$S_1 =$	0.123 g	
Seismic Design Category (SDC)	SDC =	C	11.6
Long-Period Transition Period ( $T_L$ )	$T_L =$	16 sec	12.8.1.1
Regular Structure Less than 5 Stories, w/ Redundancy Factor =1.0 ?		Yes	12.8.1.3
Site Adjusted Short-Period Acceleration ( $S_{MS}$ )	$S_{MS} = F_a S_s$	$S_{MS} = 0.481$ g	11.4.3
Site Adjusted One Second Acceleration ( $S_{M1}$ )	$S_{M1} = F_v S_1$	$S_{M1} = 0.290$ g	
Design Short-Period Acceleration ( $S_{DS}$ )	$S_{DS} = (\frac{2}{3}) S_{MS}$	$S_{DS} = 0.321$ g	11.4.4
Design One Second Acceleration ( $S_{D1}$ )	$S_{D1} = (\frac{2}{3}) S_{M1}$	$S_{D1} = 0.193$ g	
Approximate Fundamental Period, conservative ( $T_a$ ) (For All Other Structural Systems)	$T_a = 0.02 * h_n^{0.75}$	$T_a = 0.189$ sec	12.8.2.1

#### Seismic Response Coefficient: Nonstructural Component

Architectural Component	Include Overstrength Factor?			Reference
	$a_p^a$	$R_p$	$\Omega_0^c$	
Air-side HVACR, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical components constructed of sheet metal framing	2 1/2	6	2	13.3.1 Table 13.5-1
Horizontal Seismic Coefficient Minimum ( $C_{c min}$ )			$C_{c min} = 0.096$	13.3-3
Horizontal Seismic Coefficient ( $C_c$ )			$C_c = 0.214$	
Horizontal Seismic Coefficient Maximum ( $C_{c max}$ )			$C_{c max} = 0.513$	13.3-2
<b>Horizontal Seismic Coefficient (<math>C_c</math>)</b>			<b><math>C_c = 0.214</math></b>	13.3-1
<b>Vertical Seismic Coefficient (<math>C_{cv}</math>)</b>	$C_{cv} = 0.2 * S_{DS}$		<b><math>C_{cv} = 0.064</math></b>	13.3.1

$$C_{c min} = 0.3 S_{DS} I_p$$

$$C_{c max} = 1.6 S_{DS} I_p$$

$$C_c = \frac{0.4 a_p S_{DS}}{(\frac{R_p}{I_p})} \left( 1 + 2 \frac{Z}{h} \right)$$

Equipment Weight ( $W$ )

$W = 500.00$  lbs

Horizontal Seismic Force ( $F_h$ )

$F_h = 106.92$  lbs

Vertical Seismic Force ( $F_v$ )

$F_v = 32.07$  lbs





PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# HUNG EQUIPMENT SEISMIC DESIGN

## HVAC HUNG UNITS

### Hung Equipment

Weight of Equipment ( $W$ )  $W = 500$  lbs

### Seismic Forces on Equipment

Horizontal Seismic Coefficient ( $C_c$ )  $C_c = 0.214$

Vertical Seismic Coefficient ( $C_{cv}$ )  $C_{cv} = 0.064$

Horizontal Seismic Force ( $F_H$ )  $F_H = 107$  lbs

Vertical Seismic Force ( $F_V$ )  $F_V = 32$  lbs

### Force on Cable Brace

Horizontal Seismic Force ( $F_H$ )  $F_H = 107$  lbs

Number of Braces in Each Direction  $n = 2$

Cable Angle  $45$  deg

Tension Force Per Cable  $T = 102$  lbs



## SEISMIC DEMANDS ON NONSTRUCTURAL COMPONENTS

### ROOFTOP UNITS

#### Seismic Design Criteria

Building Occupancy Risk Category	Risk Category =	III	Table 1.5-1
Seismic Importance Factor ( $I_p$ )	$I_p =$	1.00	Table 1.5-2
Site Soil Classification	Site Class =	D	11.4.2
Structure Height ( $h_n$ )	$h_n =$	20.00 ft	12.8.2.1
Attachment Height ( $z$ )	$z =$	30.00 ft	
Short-Period Acceleration Parameter ( $S_S$ )	$S_S =$	0.310 g	11.4.1
One Second Acceleration Parameter ( $S_1$ )	$S_1 =$	0.123 g	
Seismic Design Category (SDC)	SDC =	C	11.6
Long-Period Transition Period ( $T_L$ )	$T_L =$	16 sec	12.8.1.1
Regular Structure Less than 5 Stories, w/ Redundancy Factor =1.0 ?		Yes	12.8.1.3
Site Adjusted Short-Period Acceleration ( $S_{MS}$ )	$S_{MS} = F_a S_S$	$S_{MS} = 0.481$ g	11.4.3
Site Adjusted One Second Acceleration ( $S_{M1}$ )	$S_{M1} = F_v S_1$	$S_{M1} = 0.290$ g	
Design Short-Period Acceleration ( $S_{DS}$ )	$S_{DS} = (\frac{2}{3}) S_{MS}$	$S_{DS} = 0.321$ g	11.4.4
Design One Second Acceleration ( $S_{D1}$ )	$S_{D1} = (\frac{2}{3}) S_{M1}$	$S_{D1} = 0.193$ g	
Approximate Fundamental Period, conservative ( $T_a$ ) (For All Other Structural Systems)	$T_a = 0.02 * h_n^{0.75}$	$T_a = 0.189$ sec	12.8.2.1

#### Seismic Response Coefficient: Nonstructural Component

Architectural Component	Include Overstrength Factor?			Reference
	$a_p^a$	$R_p$	$\Omega_0^c$	
Roof-mounted stacks, cooling and electrical towers laterally braced below their center of mass	2 1/2	3	2	13.3.1 Table 13.5-1
Horizontal Seismic Coefficient Minimum ( $C_{c min}$ )			$C_{c min} = 0.096$	13.3-3
Horizontal Seismic Coefficient ( $C_c$ )			$C_c = 0.428$	
Horizontal Seismic Coefficient Maximum ( $C_{c max}$ )			$C_{c max} = 0.513$	13.3-2
<b>Horizontal Seismic Coefficient (<math>C_c</math>)</b>			<b><math>C_c = 0.428</math></b>	13.3-1
<b>Vertical Seismic Coefficient (<math>C_{cv}</math>)</b>	$C_{cv} = 0.2 * S_{DS}$		<b><math>C_{cv} = 0.064</math></b>	13.3.1

$$C_{c min} = 0.3 S_{DS} I_p$$

$$C_{c max} = 1.6 S_{DS} I_p$$

$$C_c = \frac{0.4 a_p S_{DS}}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{Z}{h}\right)$$

Equipment Weight ( $W$ )

$W = 278.00$  lbs

Horizontal Seismic Force ( $F_h$ )

$F_h = 118.89$  lbs

Vertical Seismic Force ( $F_v$ )

$F_v = 17.83$  lbs

## WIND CONTROLS



# WIND LOADS ON ROOFTOP EQUIPMENT

## TRANSVERS LOADING

### Building Data

Structure Type:	Rooftop Equipment	Table 26.6-1
Exposure Category:	C	
Mean Roof Height:	20.00 ft	
Elevation	3,140 ft	

### Velocity Pressure

Velocity Pressure Exposure Coefficient ( $K_z$ )	$K_z =$ 0.90	Table 26.10-1
Topographic Factor ( $K_{zt}$ )	$K_{zt} =$ 1.00	Figure 26.8-1
Wind Directionality Factor ( $K_d$ )	$K_d =$ 0.85	Table 26.6-1
Ground Elevation Factor ( $K_e$ )	$K_e =$ 0.89	Table 26.9-1
Basic Wind Speed ( $V$ )	$V =$ 108 mph	26.5.1
Velocity Pressure ( $q_z$ )	$q_z =$ 20.39 psf	26.10-1

### Roof Top Equipment

Length of Equipment ( $B$ )	$B =$ 3.50 ft
Height of Equipment ( $L$ )	$L =$ 4.42 ft
Depth of Equipment ( $D$ )	$D =$ 1.08 ft
Height from Ground to Top of Equipment ( $h$ )	$h =$ 27.00 ft
Vertical Projected Area ( $A_f$ )	$A_f =$ 15.46 ft <sup>2</sup>
Horizontal Projected Area ( $A_r$ )	$A_r =$ 3.79 ft <sup>2</sup>

Horizontal Force on Equipment			Vertical Force on Equipment			29.4.1
		$(GC_r)_h$			$(GC_r)_v$	
$0.1*B*h =$	9.45	1.90	$0.1*B*L =$	1.55	1.50	
$B*h =$	94.50	1.00	$B*L =$	15.46	1.00	
$A_f =$	15.46	1.84	$A_r =$	3.79	1.42	

Horizontal Wind Pressure ( $p_h$ )	$p_h =$ 37.44 psf
Vertical Wind Pressure ( $p_v$ )	$p_v =$ 28.94 psf

Horizontal Wind Force ( $F_h$ )	$F_h = q_h(GC_r)_h A_f$	$F_h =$ 579 lbs	29.4-2
Vertical Wind Force ( $F_v$ )	$F_v = q_h(GC_r)_v A_v$	$F_v =$ 110 lbs	29.4-3



# WIND LOADS ON ROOFTOP EQUIPMENT

## LONGITUDINAL LOADING

### Building Data

Structure Type:	Rooftop Equipment	Table 26.6-1
Exposure Category:	C	
Mean Roof Height:	20.00 ft	
Elevation	3,140 ft	

### Velocity Pressure

Velocity Pressure Exposure Coefficient ( $K_z$ )	$K_z = 0.90$	Table 26.10-1
Topographic Factor ( $K_{zt}$ )	$K_{zt} = 1.00$	Figure 26.8-1
Wind Directionality Factor ( $K_d$ )	$K_d = 0.85$	Table 26.6-1
Ground Elevation Factor ( $K_e$ )	$K_e = 0.89$	Table 26.9-1
Basic Wind Speed ( $V$ )	$V = 108$ mph	26.5.1
Velocity Pressure ( $q_z$ )	$q_z = 20.39$ psf	26.10-1

### Roof Top Equipment


Length of Equipment ( $B$ )	$B = 1.08$ ft
Height of Equipment ( $L$ )	$L = 4.42$ ft
Depth of Equipment ( $D$ )	$D = 3.50$ ft
Height from Ground to Top of Equipment ( $h$ )	$h = 27.00$ ft
Vertical Projected Area ( $A_f$ )	$A_f = 4.78$ ft <sup>2</sup>
Horizontal Projected Area ( $A_r$ )	$A_r = 3.79$ ft <sup>2</sup>

Horizontal Force on Equipment			Vertical Force on Equipment			29.4.1
		$(GC_r)_h$			$(GC_r)_v$	
$0.1*B*h =$	2.93	1.90	$0.1*B*L =$	0.48	1.50	
$B*h =$	29.25	1.00	$B*L =$	4.78	1.00	
$A_f =$	4.78	1.84	$A_r =$	3.79	1.12	


Horizontal Wind Pressure ( $p_h$ )	$p_h = 37.44$ psf
Vertical Wind Pressure ( $p_v$ )	$p_v = 22.74$ psf

Horizontal Wind Force ( $F_h$ )	$F_h = q_h(GC_r)_h A_f$	$F_h = 179$ lbs	29.4-2
Vertical Wind Force ( $F_v$ )	$F_v = q_h(GC_r)_v A_v$	$F_v = 86$ lbs	29.4-3

# RTU ROOFTOP RACK DESIGN



PLAN VIEW



ELEVATION VIEW

DIMENSIONS

B = 42"  
L = 53"  
d = 14.5"  
b = 23.5"

LOADS

D = 278 LBS  
Fh = 579 LBS  
Fv = 110 LBS

WIND LOAD REACTIONS

$$T_{wind} = (L/2 * F_h + d/2 * F_v) / d$$

$$T_{wind} = ((53"/2) * (579 \text{ LBS}) + (14.5"/2) * (110 \text{ LBS})) / (14.5")$$

$$T_{wind} = 1113.17 \text{ LBS}$$

**Twind = 556.58 LBS PER ANCHOR**

$$C_{wind} = T_{wind} - F_v$$

$$C_{wind} = (1113.17 \text{ LBS}) - (110 \text{ LBS})$$

$$C_{wind} = 1003.17 \text{ LBS}$$

**Cwind = 501.58 LBS PER ANCHOR**

ASD FACTORED VERTICAL REACTIONS

0.6D+0.6W:

$$T = 0.6 * T_{dead} + 0.6 * T_{wind}$$

$$T = 0.6 * (-139 \text{ LBS}) + 0.6 * (1113.17 \text{ LBS})$$

$$T = 584.50 \text{ LBS}$$

**T = 292.25 LBS PER ANCHOR**

1.0D+0.6W:

$$C = 1.0 * C_{dead} + 0.6 * C_{wind}$$

$$C = 1.0 * (139 \text{ LBS}) + 0.6 * (1003.17 \text{ LBS})$$

$$C = 740.90 \text{ LBS}$$

**C = 370.45 LBS PER ANCHOR**

RISA ROOFTOP RACK VERTICAL REACTIONS:

DL = 154.4 LBS  
SL = 24.0 LBS  
WL+Z = 653.7 LBS  
WL-Z = -715.1 LBS

DEAD LOAD REACTIONS

$$T_{dead} = -((d/2) * D) / d$$

$$T_{dead} = -((14.5"/2) * (278 \text{ LBS})) / (14.5")$$

$$T_{dead} = -139 \text{ LBS}$$

**Tdead = -69.5 LBS PER ANCHOR**

$$C_{dead} = T_{dead} + D$$

$$C_{dead} = (-139 \text{ LBS}) + (278 \text{ LBS})$$

$$C_{dead} = 139 \text{ LBS}$$

**Cdead = 69.5 LBS PER ANCHOR**

ASD FACTORED SHEAR REACTIONS

1.0D+0.6W:

$$V = 0.6 * F_h$$


$$V = 0.6 * (579 \text{ LBS})$$

$$V = 347.4 \text{ LBS}$$


**V = 86.85 LBS PER ANCHOR**

# RISA ROOFTOP RACK DESIGN


## LOADING



**DEAD LOAD**




**SNOW LOAD**




**WIND LOAD**


## FORCES AND REACTIONS



**ENVELOPE DESIGN SHEARS (LBS)**



**ENVELOPE DESIGN MOMENTS (LB-IN)**




**ENVELOPE DESIGN REACTIONS (LBS)**

## DESIGN CHECKS

Load - P1026	Channel Thickness		
	12 ga.	14 ga.	16 ga.
Lbs	1,500	1,000	750
kN	6.67	4.45	3.34

$V_A = 1,500 \text{ LBS}$

**UNISTRUT FITTING P1026**



$M_A = 5,070 \text{ LB-IN}$

W/100 Ft: 189 Lbs (281 kg/100 m)  
 Allowable Moment 5,070 In-Lbs (570 N•m)  
 12 Gauge Nominal Thickness .105" (2.7mm)

**UNISTRUT P1000**



$$V_{MAX} / V_A = (389 \text{ LBS}) / (1,500 \text{ LBS}) = 0.26 < 1.00 \text{ --> OK}$$

$$M_{MAX} / M_A = (4,579 \text{ LB-IN}) / (5,070 \text{ LB-IN}) = 0.90 < 1.00 \text{ --> OK}$$



# S-5 BEARING DESIGN

## CHECK METAL ROOF SEAM BUCKLING CAPACITY



$d = 2 \times 0.025" = 0.050"$   
 $b = 1.625"$   
 $L = 1.25"$   
 $A_g = 0.08125 \text{ IN}^2$   
 $K = 2$   
 $F_y = 47 \text{ KSI}$   
 $E = 29,000 \text{ KSI}$

$$r = \frac{d}{\sqrt{12}} = 0.0144 \text{ IN}$$

$$\frac{KL}{r} = 173.61$$

$$4.71 \sqrt{\frac{E}{F_y}} = 117$$

$$F_e = \frac{\pi^2 E}{\left(\frac{KL}{r}\right)^2} = 9.496 \text{ KSI} \quad (\text{E3-4})$$

$$\text{When } \frac{KL}{r} > 4.71 \sqrt{\frac{E}{F_y}} \quad F_{cr} = 0.877 F_e = 8.328 \text{ KSI} \quad (\text{E3-3})$$

$$P_n = F_{cr} A_g = 0.676 \text{ K} \quad (\text{E3-1})$$

$$\Omega = 1.67 \quad P_a = P_n / \Omega = 0.405 \text{ K}$$

USE  $P_a = 400 \text{ LBS PER CLAMP}$

## ROOFTOP RACK TRANSVERSE LOADING

RISA ROOFTOP RACK VERTICAL REACTIONS:

DL = 154.4 LBS  
 SL = 24.0 LBS  
 WL+Z = 653.7 LBS  
 WL-Z = 715.1 LBS



RACK REACTION AT EACH LEG:

# OF CLAMPS = 1.5  
 $P = (DL + 0.6WL) / (\# \text{ OF CLAMPS})$   
 $P = (154.4 \text{ LBS} + 0.6 \times 653.7 \text{ LBS}) / 1.5$

P = 364 LBS <  $P_a$

# S-5 BEARING DESIGN CONT.

## CHECK METAL ROOF SEAM BENDING CAPACITY



$$M_n = M_p = F_y Z = 0.0477\text{K-IN} \quad (\text{F11-1})$$

$$\Omega_b = 1.67 \quad M_a = M_n / \Omega_b = 28.58\text{LB-IN}$$

$$V_a = M_a / L = 22.87 \text{ LBS}$$

**USE  $V_a = 22 \text{ LBS PER CLAMP}$**

## ROOFTOP RACK LONGITUDINAL LOADING

ROOFTOP RACK SHEAR REACTIONS:

W = 200 LBS

W = 50 LBS PER LEG

RACK REACTION AT EACH LEG:

# OF CLAMPS = 1.5

$V = 0.6 * W / (\# \text{ OF CLAMPS})$

V = 20 LBS

**$V = 20 \text{ LBS} < V_a$**



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:19PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (E) 2x6 RAFTER w/ HALF RTU WL+Z

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	900.0 psi	E : Modulus of Elasticity
Load Combination : ASCE 7-16	Fb -	900.0 psi	Ebend- xx
	Fc - Prll	1,350.0 psi	Eminbend - xx
Wood Species : Douglas Fir - Larch	Fc - Perp	625.0 psi	
Wood Grade : No.2	Fv	180.0 psi	
	Ft	575.0 psi	Density
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			Repetitive Member Stress Increase



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...  
 Uniform Load on ALL spans : D = 0.0150, S = 0.02750 ksf, Tributary Width = 1.330 ft  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 2.0 ft, (HALF RTU WL+Z)  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 6.0 ft, (HALF RTU WL+Z)

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio =	<b>0.661 : 1</b>	Maximum Shear Stress Ratio =	<b>0.261 : 1</b>
Section used for this span	<b>2x6</b>	Section used for this span	<b>2x6</b>
fb: Actual =	1,022.68psi	fv: Actual =	53.95 psi
F'b =	1,547.33psi	F'v =	207.00 psi
Load Combination	+D+S	Load Combination	+D+S
Location of maximum on span =	4.000ft	Location of maximum on span =	7.562 ft
Span # where maximum occurs =	Span # 1	Span # where maximum occurs =	Span # 1
<b>Maximum Deflection</b>			
Max Downward Transient Deflection	0.250 in Ratio =	<b>383</b> >=240	Span: 1 : W Only
Max Upward Transient Deflection	0 in Ratio =	<b>0</b> <240	n/a
Max Downward Total Deflection	0.316 in Ratio =	<b>304</b> >=180	Span: 1 : +D+0.750S+0.450W
Max Upward Total Deflection	0 in Ratio =	<b>0</b> <180	n/a

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values			
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v	
D Only	Length = 8.0 ft	1	0.430	0.173	0.90	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.33	520.3	1,211.0	0.0	0.00	0.0	0.0
+D+S	Length = 8.0 ft	1	0.661	0.261	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.64	1,022.7	1,547.3	0.0	0.00	0.0	0.0
+D+0.750S	Length = 8.0 ft	1	0.580	0.229	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.57	897.1	1,547.3	0.0	0.00	0.0	0.0
+D+0.60W	Length = 8.0 ft	1	0.531	0.221	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.72	1,142.6	2,152.8	0.0	0.00	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:19PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION: (E) 2x6 RAFTER w/ HALF RTU WL+Z**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v
+D+0.450W						1.00	1.00	1.00	1.300	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 8.0 ft	1	0.458	0.190	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.62	987.0	2,152.8	0.30	54.8	288.0	
+D+0.750S+0.450W						1.00	1.00	1.00	1.300	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 8.0 ft	1	0.633	0.258	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.86	1,363.8	2,152.8	0.41	74.2	288.0	
+0.60D+0.60W						1.00	1.00	1.00	1.300	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 8.0 ft	1	0.434	0.182	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.59	934.5	2,152.8	0.29	52.5	288.0	
+0.60D						1.00	1.00	1.00	1.300	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 8.0 ft	1	0.145	0.058	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.15	0.20	312.2	2,152.8	0.09	16.8	288.0	

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+0.750S+0.450W	1	0.3155	4.029		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.430	0.430
Max Upward from Load Combinations	0.430	0.430
Max Upward from Load Cases	0.327	0.327
D Only	0.164	0.164
+D+S	0.322	0.322
+D+0.750S	0.283	0.283
+D+0.60W	0.360	0.360
+D+0.450W	0.311	0.311
+D+0.750S+0.450W	0.430	0.430
+0.60D+0.60W	0.294	0.294
+0.60D	0.098	0.098
S Only	0.158	0.158
W Only	0.327	0.327



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 21 NOV 2023, 2:56PM

**Wood Beam**

Project File: P-2869-23 - Grant Union HS HVAC.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (E) 2x8 RAFTER w/ HALF RTU WL+Z

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	900.0 psi	E : Modulus of Elasticity
Load Combination : ASCE 7-16	Fb -	900.0 psi	Ebend- xx
	Fc - Prll	1,350.0 psi	Eminbend - xx
Wood Species : Douglas Fir - Larch	Fc - Perp	625.0 psi	
Wood Grade : No.2	Fv	180.0 psi	Density
	Ft	575.0 psi	Repetitive Member Stress Increase
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...  
 Uniform Load on ALL spans : D = 0.0150, S = 0.02750 ksf, Tributary Width = 1.330 ft  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 4.0 ft, (HALF RTU WL+Z)  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 8.0 ft, (HALF RTU WL+Z)

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio = <b>0.905</b> : 1	Maximum Shear Stress Ratio = <b>0.272</b> : 1
Section used for this span = <b>2x8</b>	Section used for this span = <b>2x8</b>
fb: Actual = 1,292.98psi	fv: Actual = 56.38 psi
F'b = 1,428.30psi	F'v = 207.00 psi
Load Combination = +D+S	Load Combination = +D+S
Location of maximum on span = 6.000ft	Location of maximum on span = 0.000ft
Span # where maximum occurs = Span # 1	Span # where maximum occurs = Span # 1
<b>Maximum Deflection</b>	
Max Downward Transient Deflection = 0.457 in Ratio = <b>315</b> >=240	Span: 1 : W Only
Max Upward Transient Deflection = 0 in Ratio = <b>0</b> <240	n/a
Max Downward Total Deflection = 0.632 in Ratio = <b>227</b> >=180	Span: 1 : +D+0.750S+0.450W
Max Upward Total Deflection = 0 in Ratio = <b>0</b> <180	n/a

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values			
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v	
D Only	Length = 12.0 ft	1	0.580	0.169	0.90	1.00	1.00	1.00	1.200	1.00	1.00	1.15	0.71	647.9	1,117.8	0.0	0.00	0.0	0.0
+D+S	Length = 12.0 ft	1	0.905	0.272	1.15	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.42	1,293.0	1,428.3	0.41	56.4	207.0	0.0
+D+0.750S	Length = 12.0 ft	1	0.792	0.237	1.15	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.24	1,131.7	1,428.3	0.36	49.1	207.0	0.0
+D+0.60W	Length = 12.0 ft	1	0.686	0.189	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.49	1,364.2	1,987.2	0.39	54.4	288.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 21 NOV 2023, 2:56PM

**Wood Beam**

Project File: P-2869-23 - Grant Union HS HVAC.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION: (E) 2x8 RAFTER w/ HALF RTU WL+Z**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v
+D+0.450W						1.00	1.00	1.00	1.200	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.596	0.165	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.30	1,185.1	1,987.2	0.35	47.6	288.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.200	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.840	0.241	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.83	1,668.9	1,987.2	0.50	69.4	288.0
+0.60D+0.60W						1.00	1.00	1.00	1.200	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.556	0.151	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.15	1.21	1,105.0	1,987.2	0.31	43.4	288.0
+0.60D						1.00	1.00	1.00	1.200	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.196	0.057	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.15	0.43	388.8	1,987.2	0.12	16.4	288.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+0.750S+0.450W	1	0.6322	6.044		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.531	0.531
Max Upward from Load Combinations	0.531	0.531
Max Upward from Load Cases	0.327	0.327
D Only	0.211	0.211
+D+S	0.442	0.442
+D+0.750S	0.384	0.384
+D+0.60W	0.407	0.407
+D+0.450W	0.358	0.358
+D+0.750S+0.450W	0.531	0.531
+0.60D+0.60W	0.323	0.323
+0.60D	0.127	0.127
S Only	0.231	0.231
W Only	0.327	0.327



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:26PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (E) 2x10 RAFTER w/ HALF RTU WL+Z

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	900.0 psi	E : Modulus of Elasticity	
Load Combination : ASCE 7-16	Fb -	900.0 psi	Ebend- xx	1,600.0ksi
	Fc - Prll	1,350.0 psi	Eminbend - xx	580.0ksi
Wood Species : Douglas Fir - Larch	Fc - Perp	625.0 psi		
Wood Grade : No.2	Fv	180.0 psi		
	Ft	575.0 psi	Density	31.210pcf
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			Repetitive Member Stress Increase	



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...  
 Uniform Load on ALL spans : D = 0.0150, S = 0.02750 ksf, Tributary Width = 1.330 ft  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 4.50 ft, (HALF RTU WL+Z)  
 Point Load : D = 0.0770, S = 0.0120, W = 0.3268 k @ 6.50 ft, (HALF RTU WL+Z)

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio = <b>0.558</b> < 1	Maximum Shear Stress Ratio = <b>0.194</b> < 1
Section used for this span: <b>2x10</b>	Section used for this span: <b>2x10</b>
fb: Actual = 1,015.90psi	fv: Actual = 40.11 psi
F'b = 1,821.60psi	F'v = 207.00 psi
Load Combination: +D+0.750S+0.450W	Load Combination: +D+S
Location of maximum on span = 5.500ft	Location of maximum on span = 10.237 ft
Span # where maximum occurs = Span # 1	Span # where maximum occurs = Span # 1
<b>Maximum Deflection</b>	
Max Downward Transient Deflection: 0.190 in Ratio = <b>695</b> >=240	Span: 1 : W Only
Max Upward Transient Deflection: 0 in Ratio = <b>0</b> <240	n/a
Max Downward Total Deflection: 0.241 in Ratio = <b>548</b> >=180	Span: 1 : +D+0.750S+0.450W
Max Upward Total Deflection: 0 in Ratio = <b>0</b> <180	n/a

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios									Moment Values			Shear Values					
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only	Length = 11.0 ft	1	0.380	0.124	0.90	1.00	1.00	1.00	1.100	1.00	1.00	1.15	0.69	389.2	1,024.7	0.00	0.00	0.0	0.0	0.0
+D+S	Length = 11.0 ft	1	0.557	0.194	1.15	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.30	729.8	1,309.3	0.00	0.00	0.0	0.0	0.0
+D+0.750S	Length = 11.0 ft	1	0.492	0.170	1.15	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.15	644.7	1,309.3	0.00	0.00	0.0	0.0	0.0
+D+0.60W	Length = 11.0 ft	1	0.485	0.143	1.60	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.58	884.2	1,821.6	0.00	0.00	0.0	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:26PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION: (E) 2x10 RAFTER w/ HALF RTU WL+Z**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	f <sub>v</sub>	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.100	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 11.0 ft	1		0.417	0.125	1.60	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.36	760.4	1,821.6	0.33	36.0	288.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.100	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 11.0 ft	1		0.558	0.177	1.60	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.81	1,015.9	1,821.6	0.47	51.0	288.0
+0.60D+0.60W						1.00	1.00	1.00	1.100	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 11.0 ft	1		0.400	0.115	1.60	1.00	1.00	1.00	1.100	1.00	1.00	1.15	1.30	728.5	1,821.6	0.31	33.2	288.0
+0.60D						1.00	1.00	1.00	1.100	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 11.0 ft	1		0.128	0.042	1.60	1.00	1.00	1.00	1.100	1.00	1.00	1.15	0.42	233.5	1,821.6	0.11	12.0	288.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+0.750S+0.450W	1	0.2407	5.540		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.510	0.510
Max Upward from Load Combinations	0.510	0.510
Max Upward from Load Cases	0.327	0.327
D Only	0.203	0.203
+D+S	0.416	0.416
+D+0.750S	0.363	0.363
+D+0.60W	0.399	0.399
+D+0.450W	0.350	0.350
+D+0.750S+0.450W	0.510	0.510
+0.60D+0.60W	0.318	0.318
+0.60D	0.122	0.122
S Only	0.213	0.213
W Only	0.327	0.327





Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:37PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (E) 7-1/2x16 GLB w/ RTU WL+Z-Z


**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	1,800.0 psi	E : Modulus of Elasticity
Load Combination : ASCE 7-16	Fb -	1,850.0 psi	Ebend- xx
	Fc - Prll	1,650.0 psi	Eminbend - xx
Wood Species : DF/DF	Fc - Perp	650.0 psi	Ebend- yy
Wood Grade : 24F - V4	Fv	265.0 psi	Eminbend - yy
	Ft	1,100.0 psi	Density
			31.210pcf

Beam Bracing : Beam is Fully Braced against lateral-torsional buckling



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0220 ksf, Tributary Width = 8.50 ft  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 15.0 ft, (RTU WL+Z)  
 Point Load : D = 0.1550, S = 0.0240, W = -0.7151 k @ 17.0 ft, (RTU WL-Z)

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.838</b> < 1	Maximum Shear Stress Ratio	=	<b>0.213</b> < 1
Section used for this span	=	<b>7.50 X 16.0</b>	Section used for this span	=	<b>7.50 X 16.0</b>
fb: Actual	=	1,735.13psi	fv: Actual	=	64.87 psi
F'b	=	2,070.00psi	F'v	=	304.75 psi
Load Combination	=	+D+S	Load Combination	=	+D+S
Location of maximum on span	=	16.000ft	Location of maximum on span	=	30.715 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection	0.975 in	Ratio = 393	>=240	Span: 1 : S Only	
Max Upward Transient Deflection	-0.018 in	Ratio = 21398	>=240	Span: 1 : W Only	
Max Downward Total Deflection	1.845 in	Ratio = 208	>=180	Span: 1 : +D+S	
Max Upward Total Deflection	0 in	Ratio = 0	<180	n/a	

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only	Length = 32.0 ft	1	0.509	0.127	0.90	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	21.97	824.0	1,620.0	0.0	0.00	0.0	0.0
+D+S	Length = 32.0 ft	1	0.838	0.213	1.15	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	46.27	1,735.1	2,070.0	0.0	0.00	0.0	0.0
+D+0.750S	Length = 32.0 ft	1	0.728	0.184	1.15	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	40.20	1,507.4	2,070.0	0.0	0.00	0.0	0.0
+D+0.60W	Length = 32.0 ft	1	0.286	0.071	1.60	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	21.99	824.6	2,880.0	0.0	0.00	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:37PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (E) 7-1/2x16 GLB w/ RTU WL+Z-Z

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	f <sub>v</sub>	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 32.0 ft	1		0.286	0.071	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	21.97	823.9	2,880.0	2.42	30.2	424.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 32.0 ft	1		0.523	0.133	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	40.13	1,504.9	2,880.0	4.50	56.3	424.0
+0.60D+0.60W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 32.0 ft	1		0.172	0.043	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	13.24	496.4	2,880.0	1.46	18.2	424.0
+0.60D						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 32.0 ft	1		0.172	0.043	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	13.18	494.4	2,880.0	1.45	18.1	424.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+S	1	1.8452	16.117		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	5.627	5.627
Max Upward from Load Combinations	5.627	5.627
Max Upward from Load Cases	3.016	3.016
Max Downward from all Load Conditio		-0.073
Max Downward from Load Cases (Resis		-0.073
D Only	2.611	2.611
+D+S	5.627	5.627
+D+0.750S	4.873	4.873
+D+0.60W	2.618	2.567
+D+0.450W	2.617	2.578
+D+0.750S+0.450W	4.879	4.840
+0.60D+0.60W	1.574	1.523
+0.60D	1.567	1.567
S Only	3.016	3.016
W Only	0.012	-0.073



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:38PM

## Wood Beam

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (E) 5-1/4x35-3/8 GLB w/ RTU WL+Z-Z

### CODE REFERENCES

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

### Material Properties

Analysis Method : Allowable Stress Design	Fb +	1,800.0 psi	<i>E : Modulus of Elasticity</i>
Load Combination : ASCE 7-16	Fb -	1,850.0 psi	Ebend- xx
	Fc - Prll	1,650.0 psi	Eminbend - xx
Wood Species : DF/DF	Fc - Perp	650.0 psi	Ebend- yy
Wood Grade : 24F - V4	Fv	265.0 psi	Eminbend - yy
	Ft	1,100.0 psi	Density
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			Repetitive Member Stress Increase



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0220 ksf, Tributary Width = 12.0 ft  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 21.50 ft, ( RTU WL+Z)  
 Point Load : D = 0.1550, S = 0.0240, W = -0.7151 k @ 23.50 ft, (RTU WL-Z)

### DESIGN SUMMARY

**Design OK**

<b>Maximum Bending Stress Ratio</b>	=	<b>0.669</b> : 1	<b>Maximum Shear Stress Ratio</b>	=	<b>0.258</b> : 1
Section used for this span	=	<b>5.250 X 35.375</b>	Section used for this span	=	<b>5.250 X 35.375</b>
fb: Actual	=	1,385.52psi	fv: Actual	=	78.53 psi
F'b	=	2,070.00psi	F'v	=	304.75 psi
Load Combination	=	+D+S	Load Combination	=	+D+S
Location of maximum on span	=	22.500ft	Location of maximum on span	=	42.208 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection	=	0.707 in Ratio = 763 >=240	Span: 1 : S Only		
Max Upward Transient Deflection	=	-0.006 in Ratio = 85913 >=240	Span: 1 : W Only		
Max Downward Total Deflection	=	1.323 in Ratio = 408 >=180	Span: 1 : +D+S		
Max Upward Total Deflection	=	0 in Ratio = 0 <180	n/a		

### Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values			
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v	
D Only	Length = 45.0 ft	1	0.400	0.152	0.90	1.00	1.00	1.00	1.000	1.00	1.00	1.00	59.08	647.5	1,620.0	0.0	0.00	0.0	0.0
+D+S	Length = 45.0 ft	1	0.669	0.258	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.00	126.42	1,385.5	2,070.0	9.72	78.5	304.8	0.0
+D+0.750S	Length = 45.0 ft	1	0.580	0.223	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.00	109.59	1,201.0	2,070.0	8.42	68.0	304.8	0.0
+D+0.60W	Length = 45.0 ft	1	0.224	0.086	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	58.97	646.2	2,880.0	4.50	36.3	424.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:38PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION: (E) 5-1/4x35-3/8 GLB w/ RTU WL+Z-Z**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	fv	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 45.0 ft	1		0.224	0.086	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	58.97	646.3	2,880.0	4.50	36.3	424.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 45.0 ft	1		0.416	0.160	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	109.40	1,198.9	2,880.0	8.42	68.0	424.0
+0.60D+0.60W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 45.0 ft	1		0.135	0.051	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	35.38	387.7	2,880.0	2.70	21.8	424.0
+0.60D						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 45.0 ft	1		0.135	0.051	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	35.45	388.5	2,880.0	2.70	21.8	424.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+S	1	1.3229	22.664		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	11.075	11.075
Max Upward from Load Combinations	11.075	11.075
Max Upward from Load Cases	5.964	5.964
Max Downward from all Load Conditio	-0.000	-0.061
Max Downward from Load Cases (Resis	-0.000	-0.061
D Only	5.111	5.111
+D+S	11.075	11.075
+D+0.750S	9.584	9.584
+D+0.60W	5.110	5.074
+D+0.450W	5.111	5.083
+D+0.750S+0.450W	9.584	9.556
+0.60D+0.60W	3.066	3.030
+0.60D	3.066	3.066
S Only	5.964	5.964
W Only	-0.000	-0.061



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:36PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (E) 5-1/8x21 GLB w/ RTU WL+Z-Z


**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	1,800.0 psi	E : Modulus of Elasticity
Load Combination : ASCE 7-16	Fb -	1,850.0 psi	Ebend- xx
	Fc - Prll	1,650.0 psi	Eminbend - xx
Wood Species : DF/DF	Fc - Perp	650.0 psi	Ebend- yy
Wood Grade : 24F - V4	Fv	265.0 psi	Eminbend - yy
	Ft	1,100.0 psi	Density
			31.210pcf

Beam Bracing : Beam is Fully Braced against lateral-torsional buckling



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0220 ksf, Tributary Width = 8.0 ft  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 14.0 ft, (RTU WL+Z)  
 Point Load : D = 0.1550, S = 0.0240, W = -0.7151 k @ 12.0 ft, (RTU WL-Z)

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.923</b> : 1	Maximum Shear Stress Ratio	=	<b>0.264</b> : 1
Section used for this span		<b>5.125 X 21.0</b>	Section used for this span		<b>5.125 X 21.0</b>
fb: Actual	=	1,911.04psi	fv: Actual	=	80.44 psi
F'b	=	2,070.00psi	F'v	=	304.75 psi
Load Combination		+D+S	Load Combination		+D+S
Location of maximum on span	=	18.584ft	Location of maximum on span	=	0.000ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection		1.178 in Ratio = <b>387</b> >=240	Span: 1 : S Only		
Max Upward Transient Deflection		-0.004 in Ratio = <b>110216</b> >=240	Span: 1 : W Only		
Max Downward Total Deflection		2.203 in Ratio = <b>206</b> >=180	Span: 1 : +D+S		
Max Upward Total Deflection		0 in Ratio = <b>0</b> <180	n/a		

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values						
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v				
D Only	Length = 38.0 ft	1	0.549	0.157	0.90	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	27.92	889.6	1,620.0	0.00	0.00	0.0	0.0	238.5
+D+S	Length = 38.0 ft	1	0.923	0.264	1.15	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	59.99	1,911.0	2,070.0	5.77	80.4	304.8	0.0	0.0
+D+0.750S	Length = 38.0 ft	1	0.800	0.229	1.15	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	51.97	1,655.6	2,070.0	5.00	69.7	304.8	0.0	0.0
+D+0.60W	Length = 38.0 ft	1	0.311	0.087	1.60	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	28.10	895.3	2,880.0	2.64	36.8	424.0	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:36PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (E) 5-1/8x21 GLB w/ RTU WL+Z-Z

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	fv	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 38.0 ft	1		0.310	0.087	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	28.06	893.8	2,880.0	2.65	37.0	424.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 38.0 ft	1		0.576	0.163	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	52.10	1,659.8	2,880.0	4.97	69.2	424.0
+0.60D+0.60W						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 38.0 ft	1		0.187	0.052	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	16.93	539.4	2,880.0	1.57	21.8	424.0
+0.60D						1.00	1.00	1.00	1.000	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 38.0 ft	1		0.185	0.053	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.00	16.75	533.7	2,880.0	1.61	22.5	424.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+S	1	2.2030	19.000		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	6.303	6.190
Max Upward from Load Combinations	6.303	6.190
Max Upward from Load Cases	3.376	3.360
Max Downward from all Load Conditio	-0.076	
Max Downward from Load Cases (Resis	-0.076	
D Only	2.927	2.829
+D+S	6.303	6.190
+D+0.750S	5.459	5.350
+D+0.60W	2.881	2.838
+D+0.450W	2.893	2.836
+D+0.750S+0.450W	5.424	5.356
+0.60D+0.60W	1.710	1.707
+0.60D	1.756	1.698
S Only	3.376	3.360
W Only	-0.076	0.015



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:31PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (N) 6x6 RAFTER w/ RTU WL+Z-Z - PERP

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	900.0 psi	E : Modulus of Elasticity
Load Combination : ASCE 7-16	Fb -	900.0 psi	Ebend- xx
	Fc - Prll	1,350.0 psi	Eminbend - xx
Wood Species : Douglas Fir - Larch	Fc - Perp	625.0 psi	
Wood Grade : No.2	Fv	180.0 psi	
	Ft	575.0 psi	Density
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			Repetitive Member Stress Increase



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0220 ksf, Tributary Width = 2.0 ft  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 5.0 ft, (RTU WL+Z)  
 Point Load : D = 0.1550, S = 0.0240, W = -0.7151 k @ 7.0 ft, (RTU WL-Z)

**DESIGN SUMMARY**

**Design OK**

<b>Maximum Bending Stress Ratio</b>	=	<b>0.853</b> : 1	<b>Maximum Shear Stress Ratio</b>	=	<b>0.150</b> : 1
Section used for this span		<b>6x6</b>	Section used for this span		<b>6x6</b>
fb: Actual	=	1,014.82psi	fv: Actual	=	31.09 psi
F'b	=	1,190.25psi	F'v	=	207.00 psi
Load Combination		+D+S	Load Combination		+D+S
Location of maximum on span	=	6.000ft	Location of maximum on span	=	0.000 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection		0.193 in Ratio = 746 >=240	Span: 1 : S Only		
Max Upward Transient Deflection		-0.046 in Ratio = 3113 >=240	Span: 1 : W Only		
Max Downward Total Deflection		0.486 in Ratio = 296 >=180	Span: 1 : +D+S		
Max Upward Total Deflection		0 in Ratio = 0 <180	n/a		

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only	Length = 12.0 ft	1	0.666	0.110	0.90	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.43	620.1	931.5	0.00	0.00	0.0	0.0	0.0
+D+S	Length = 12.0 ft	1	0.853	0.150	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.35	1,014.8	1,190.3	0.63	31.1	207.0	0.0	0.0
+D+0.750S	Length = 12.0 ft	1	0.770	0.134	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.12	916.2	1,190.3	0.56	27.8	207.0	0.0	0.0
+D+0.60W	Length = 12.0 ft	1	0.435	0.070	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.66	719.7	1,656.0	0.41	20.2	288.0	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:31PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (N) 6x6 RAFTER w/ RTU WL+Z-Z - PERP

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	fv	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.418	0.068	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.60	692.7	1,656.0	0.40	19.6	288.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.593	0.103	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.27	981.4	1,656.0	0.60	29.6	288.0
+0.60D+0.60W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.287	0.063	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.10	475.1	1,656.0	0.36	18.0	288.0
+0.60D						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.225	0.037	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	0.86	372.1	1,656.0	0.21	10.7	288.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+S	1	0.4862	6.044		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.662	0.662
Max Upward from Load Combinations	0.662	0.662
Max Upward from Load Cases	0.374	0.374
Max Downward from all Load Conditio		-0.145
Max Downward from Load Cases (Resis		-0.145
D Only	0.374	0.374
+D+S	0.662	0.662
+D+0.750S	0.590	0.590
+D+0.60W	0.424	0.287
+D+0.450W	0.412	0.309
+D+0.750S+0.450W	0.628	0.525
+0.60D+0.60W	0.275	0.138
+0.60D	0.225	0.225
S Only	0.288	0.288
W Only	0.083	-0.145





Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:32PM

## Wood Beam

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (N) 6x6 RAFTER w/ RTU WL+Z - PARA

### CODE REFERENCES

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

### Material Properties

Analysis Method : Allowable Stress Design	Fb +	900.0 psi	<i>E : Modulus of Elasticity</i>
Load Combination : ASCE 7-16	Fb -	900.0 psi	Ebend- xx 1,600.0ksi
	Fc - Prll	1,350.0 psi	Eminbend - xx 580.0ksi
Wood Species : Douglas Fir - Larch	Fc - Perp	625.0 psi	
Wood Grade : No.2	Fv	180.0 psi	
	Ft	575.0 psi	Density 31.210pcf
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling			Repetitive Member Stress Increase



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0220 ksf, Tributary Width = 2.0 ft  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 4.0 ft, (RTU WL+Z)  
 Point Load : D = 0.1550, S = 0.0240, W = 0.6537 k @ 8.0 ft, (RTU WL+Z)

### DESIGN SUMMARY

**Design OK**

<b>Maximum Bending Stress Ratio</b>	=	<b>0.816</b> < 1	<b>Maximum Shear Stress Ratio</b>	=	<b>0.150</b> < 1
Section used for this span		<b>6x6</b>	Section used for this span		<b>6x6</b>
fb: Actual	=	1,350.49psi	fv: Actual	=	31.09 psi
F'b	=	1,656.00psi	F'v	=	207.00 psi
Load Combination		+D+0.750S+0.450W	Load Combination		+D+S
Location of maximum on span	=	6.000ft	Location of maximum on span	=	0.000ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection		0.571 in Ratio = 252 >=240	Span: 1 : W Only		
Max Upward Transient Deflection		0 in Ratio = 0 <240	n/a		
Max Downward Total Deflection		0.676 in Ratio = 213 >=180	Span: 1 : +D+0.750S+0.450W		
Max Upward Total Deflection		0 in Ratio = 0 <180	n/a		

### Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios									Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v	
D Only	Length = 12.0 ft	1	0.594	0.110	0.90	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.28	553.1	931.5	0.0	0.00	0.0	0.0
+D+S	Length = 12.0 ft	1	0.788	0.150	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.17	937.4	1,190.3	0.0	0.00	0.0	0.0
+D+0.750S	Length = 12.0 ft	1	0.707	0.134	1.15	1.00	1.00	1.00	1.000	1.00	1.00	1.15	1.94	841.3	1,190.3	0.0	0.00	0.0	0.0
+D+0.60W	Length = 12.0 ft	1	0.744	0.129	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.85	1,232.0	1,656.0	0.0	0.00	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 2 MAR 2024, 10:32PM

**Wood Beam**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION: (N) 6x6 RAFTER w/ RTU WL+Z - PARA**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F <sub>b</sub>	V	fv	F <sub>v</sub>
+D+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.641	0.112	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.45	1,062.3	1,656.0	0.65	32.4	288.0
+D+0.750S+0.450W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.816	0.147	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	3.12	1,350.5	1,656.0	0.85	42.3	288.0
+0.60D+0.60W						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.610	0.105	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	2.34	1,010.8	1,656.0	0.61	30.1	288.0
+0.60D						1.00	1.00	1.00	1.000	1.00	1.00	1.15			0.0	0.00	0.0	0.0
Length = 12.0 ft	1		0.200	0.037	1.60	1.00	1.00	1.00	1.000	1.00	1.00	1.15	0.77	331.8	1,656.0	0.21	10.7	288.0

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+0.750S+0.450W	1	0.6757	6.044		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.885	0.885
Max Upward from Load Combinations	0.885	0.885
Max Upward from Load Cases	0.654	0.654
D Only	0.374	0.374
+D+S	0.662	0.662
+D+0.750S	0.590	0.590
+D+0.60W	0.767	0.767
+D+0.450W	0.669	0.669
+D+0.750S+0.450W	0.885	0.885
+0.60D+0.60W	0.617	0.617
+0.60D	0.225	0.225
S Only	0.288	0.288
W Only	0.654	0.654



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 17 AUG 2023, 10:22AM

## Wood Beam

Project File: P-2869-23 - Grant Union HS HVAC.ec6

LIC#: KW-06014690, Build:20.23.05.01

ZCS, INC.

(c) ENERCALC INC 1983-2023


**DESCRIPTION:** (N) 4x8 HDR

### CODE REFERENCES

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combination Set : ASCE 7-16

### Material Properties

Analysis Method : Allowable Stress Design	Fb +	900 psi	<i>E : Modulus of Elasticity</i>	
Load Combination : ASCE 7-16	Fb -	900 psi	Ebend- xx	1600ksi
	Fc - Prll	1350 psi	Eminbend - xx	580ksi
Wood Species : Douglas Fir - Larch	Fc - Perp	625 psi		
Wood Grade : No.2	Fv	180 psi		
	Ft	575 psi	Density	31.21 pcf
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling				



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight NOT internally calculated and added  
 Loads on all spans...

Uniform Load on ALL spans : D = 0.0150, S = 0.0240 ksf, Tributary Width = 10.0 ft  
 Uniform Load on ALL spans : S = 0.050 ksf, Tributary Width = 10.0 ft

### DESIGN SUMMARY

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.518</b>	1	Maximum Shear Stress Ratio	=	<b>0.356</b>	: 1
Section used for this span		<b>4x8</b>		Section used for this span		<b>4x8</b>	
fb: Actual	=	696.64psi		fv: Actual	=	73.73 psi	
F'b	=	1,345.50psi		F'v	=	207.00 psi	
Load Combination		+D+S		Load Combination		+D+S	
Location of maximum on span	=	2.000ft		Location of maximum on span	=	3.401 ft	
Span # where maximum occurs	=	Span # 1		Span # where maximum occurs	=	Span # 1	
<b>Maximum Deflection</b>							
Max Downward Transient Deflection		0.024 in	Ratio =	<b>1991</b>	>=240	Span: 1 : S Only	
Max Upward Transient Deflection		0 in	Ratio =	<b>0</b>	<240	n/a	
Max Downward Total Deflection		0.029 in	Ratio =	<b>1655</b>	>=180	Span: 1 : +D+S	
Max Upward Total Deflection		0 in	Ratio =	<b>0</b>	<180	n/a	

### Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only																				
Length = 4.0 ft	1	0.112	0.077	0.90	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.30	117.4	1,053.0	0.0	0.00	0.0	0.0	0.0	162.0
+D+S																				
Length = 4.0 ft	1	0.518	0.356	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.00	1.78	696.6	1,345.5	1.25	73.7	207.0	0.0	0.0	0.0
+D+0.750S																				
Length = 4.0 ft	1	0.410	0.282	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.00	1.41	551.8	1,345.5	0.99	58.4	207.0	0.0	0.0	0.0
+0.60D																				
Length = 4.0 ft	1	0.038	0.026	1.60	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.18	70.4	1,872.0	0.13	7.5	288.0	0.0	0.0	0.0



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 17 AUG 2023, 10:22AM

**Wood Beam**

Project File: P-2869-23 - Grant Union HS HVAC.ec6

LIC# : KW-06014690, Build:20.23.05.01

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (N) 4x8 HDR

**Overall Maximum Deflections**

Load Combination	Span	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
+D+S	1	0.0290	2.015		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	1.780	1.780
Max Upward from Load Combinations	1.780	1.780
Max Upward from Load Cases	1.480	1.480
D Only	0.300	0.300
+D+S	1.780	1.780
+D+0.750S	1.410	1.410
+0.60D	0.180	0.180
S Only	1.480	1.480



PROJECT: Grant Union HS HVAC

PROJECT #: P-2869-23

CLIENT: Grant County School District

DATE: 3/7/2024

VERSION: 3.05

DESIGNED BY: BLD

# WIND LOADS C&C

## Building Data

Structure Type:	Buildings: Main Wind Force Resisting System
Enclosure Classification:	Enclosed Buildings
Exposure Category:	C
Mean Roof Height:	20.00 ft
Design Roof Angle:	2.39 °
Site Elevation:	3,140 ft

## Velocity Pressure & Internal Pressure Coefficient

Velocity Pressure Exposure Coefficient ( $K_z$ )	$K_z =$ 0.900	Table 26.10-1
Topographic Factor ( $K_{zt}$ )	$K_{zt} =$ 1.000	Figure 26.8-1
Wind Directionality Factor ( $K_d$ )	$K_d =$ 0.850	Table 26.6-1
Wind Elevation Factor ( $K_e$ )	$K_e =$ 0.893	Table 26.9-1
Basic Wind Speed ( $V$ )	$V =$ 108 mph	26.5.1
Velocity Pressure ( $q_z$ )	$q_z =$ 20.39 psf	26.10.2
Internal Pressure Coefficients ( $GC_{pi}$ )	$GC_{pi} =$ 0.18	Table 26.13-1

## External Pressure Coefficients & Wall Pressures

Area (ft <sup>2</sup> )	Wall ( $GC_p$ )				Wall Pressure (psf)				Max Pressure (psf)
	4		5		4		5		
	+	-	+	-	+	-	+	-	
30.00	0.82	-0.91	0.82	-1.11	20.47	-22.31	20.47	26.27	26.27



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 4 MAR 2024, 3:25PM

**Wood Column**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC#: KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (2) 2x6 King Stud

**Code References**

Calculations per NDS 2018, IBC 2021, ASCE 7-16  
 Load Combinations Used : ASCE 7-16

**General Information**

Analysis Method	Allowable Stress Design			Wood Section Name	<b>2-2x6</b>
End Fixities	Top & Bottom Pinned			Wood Grading/Manuf.	Graded Lumber
Overall Column Height	20 ft			Wood Member Type	Sawn
<i>( Used for non-slender calculations )</i>					
Wood Species	Douglas Fir-Larch			Exact Width	<b>3.0</b> in Allow Stress Modification Factors
Wood Grade	No.2			Exact Depth	<b>5.50</b> in Cf or Cv for Bending 1.30
Fb +	900.0 psi	Fv	180.0 psi	Area	16.50 in^2 Cf or Cv for Compression 1.10
Fb -	900.0 psi	Ft	575.0 psi	Ix	41.594 in^4 Cf or Cv for Tension 1.30
Fc - Prll	1,350.0 psi	Density	31.210 pcf	Iy	<b>12.375</b> in^4 Cm : Wet Use Factor 1.0
Fc - Perp	625.0 psi			Ct : Temperature Fact 1.0	
E : Modulus of Elasticity . . .	x-x Bending	y-y Bending	Axial	Cfu : Flat Use Factor 1.0	
	Basic	1,600.0	1,600.0	1,600.0 ksi	Kf : Built-up columns 1.0
	Minimum	580.0	580.0	Column Buckling Condition:	Use Cr : Repetitive ? No
ABOUT X-X Axis: Lux = 20 ft, Kx = 1.0					
Fully braced against buckling ABOUT Y-Y Axis					

**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Column self weight included : 71.523 lbs \* Dead Load Factor  
 BENDING LOADS . . .  
 WIND: Lat. Uniform Load creating Mx-x, W = 0.04290 k/ft

**DESIGN SUMMARY**

**Bending & Shear Check Results**

**PASS** Max. Axial+Bending Stress Ratio = **0.5664 : 1**  
 Load Combination +D+0.60W  
 Governing NDS Formula Comp + Mxx, NDS Eq. 3.9-3  
 Location of max.above base 10.067 ft  
 At maximum location values are .  
 Applied Axial 0.07152 k  
 Applied Mx 1.287 k-ft  
 Applied My 0.0 k-ft  
 Fc : Allowable 244.760 psi

**Maximum SERVICE Lateral Load Reactions . .**  
 Top along Y-Y 0.4290 k Bottom along Y-Y 0.4290 k  
 Top along X-X 0.0 k Bottom along X-X 0.0 k

**Maximum SERVICE Load Lateral Deflections . . .**  
 Along Y-Y 2.346 in at 10.067 ft above base  
 for load combination : W Only  
 Along X-X 0.0 in at 0.0 ft above base  
 for load combination : n/a

**Other Factors used to calculate allowable stresses . . .**  
 Bending Compression Tension

**PASS** Maximum Shear Stress Ratio = **0.08125 : 1**  
 Load Combination +D+0.60W  
 Location of max.above base 20.0 ft  
 Applied Design Shear 35.10 psi  
 Allowable Shear 288.0 psi

**Load Combination Results**

Load Combination	C <sub>D</sub>	C <sub>P</sub>	Maximum Axial + Bending Stress Ratios			Maximum Shear Ratios		
			Stress Ratio	Status	Location	Stress Ratio	Status	Location
D Only	0.900	0.179	0.01807	PASS	0.0 ft	0.0	PASS	20.0 ft
+D+0.60W	1.600	0.103	0.5664	PASS	10.067 ft	0.08125	PASS	20.0 ft
+D+0.450W	1.600	0.103	0.4249	PASS	9.933 ft	0.06094	PASS	20.0 ft
+0.60D+0.60W	1.600	0.103	0.5622	PASS	10.067 ft	0.08125	PASS	20.0 ft
+0.60D	1.600	0.103	0.01063	PASS	0.0 ft	0.0	PASS	20.0 ft

**Maximum Reactions**

Note: Only non-zero reactions are listed.

Load Combination	X-X Axis Reaction		Y-Y Axis Reaction		Axial Reaction	My - End Moments		Mx - End Moments	
	@ Base	@ Top	@ Base	@ Top	@ Base	@ Base	@ Top	@ Base	@ Top
D Only					0.072				
+D+0.60W			0.257	0.257	0.072				



Project Title: Grant Union HS HVAC  
 Engineer:  
 Project ID: P-2869-23  
 Project Descr:

Printed: 4 MAR 2024, 3:25PM

**Wood Column**

Project File: p-2869-23 - grant union hs hvac.ec6

LIC# : KW-06014690, Build:20.23.08.30

ZCS, INC.

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** (2) 2x6 King Stud

**Maximum Reactions**

Note: Only non-zero reactions are listed.

Load Combination	X-X Axis Reaction		k	Y-Y Axis Reaction		Axial Reaction	My - End Moments		k-ft Mx - End Moments	
	@ Base	@ Top		@ Base	@ Top		@ Base	@ Top	@ Base	@ Top
+D+0.450W				0.193	0.193	0.072				
+0.60D+0.60W				0.257	0.257	0.043				
+0.60D						0.043				
W Only				0.429	0.429					

**Maximum Deflections for Load Combinations**

Load Combination	Max. X-X Deflection	Distance	Max. Y-Y Deflection	Distance
D Only	0.0000 in	0.000ft	0.000 in	0.000 ft
+D+0.60W	0.0000 in	0.000ft	1.407 in	10.067 ft
+D+0.450W	0.0000 in	0.000ft	1.056 in	10.067 ft
+0.60D+0.60W	0.0000 in	0.000ft	1.407 in	10.067 ft
+0.60D	0.0000 in	0.000ft	0.000 in	0.000 ft
W Only	0.0000 in	0.000ft	2.346 in	10.067 ft

**Sketches**

