

# Certification of Delivery of Consumer Confidence Report (CCR)

The attached CCR for years June 23, 2025 was provided to all customers of the Second Mesa Day School.  
Public Water System, PWS ID No. 090400057.

NOTE: The CCR may be posted in a newspaper, in a public place, or made available upon request, *in addition to one of the following*: **delivery to each water customer or delivery of a notification of availability to each water customer.**

## MANDATORY METHODS (choose one)

☒ Hand Delivery

☐ Mail

## ADDITIONAL OPTIONAL METHODS

☐ Newspaper (attach copy)

☐ Advertising in News Media (attach copy of announcement)

☒ Posting in Public Places (attach a list of locations)

☒ Posting the CCR on the Internet at www.secondmesadayschool.com

☐ Delivery to Community Organizations (attach a list)

☐ Delivery of multiple copies to apartments, business, and large private employers

☐ Other Direct Delivery \_\_\_\_\_

Certified by:

Name: Walter Fowler

Title: Operations Manager

Phone No.: 928.737.2571 ext: 4325 or mobile: 928.614.5508

Signature: 

Date: June 23, 2025

**PLEASE ATTACH CCR NOTICE TO THIS CERTIFICATION.**

# **Second Mesa Day School - BIA Annual Water Quality Report**

**Public Water System #090400057**

**Calendar Year 2024**

This report is a snapshot of your water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Your water comes from 1 ground water source.

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including:

- microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming;
- pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems;
- radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## WATER QUALITY TABLE

The table below lists all of the drinking water contaminants detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires monitoring for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MRDLG	MRDL	Your Water	Range Low High		Sample Date	MRDL Exceeded	Typical Source
--------------	-------	------	------------	-------------------	--	-------------	---------------	----------------

### Disinfectants

Chlorine Units: Chlorine residual, ppm	4	4	0.5617	0.14	1.03	2024	No	Drinking water additive used for disinfection
---	---	---	--------	------	------	------	----	---

Contaminants	MCLG	MCL	Your Water	Range Low High		Sample Date	Violation	Typical Source
--------------	------	-----	------------	-------------------	--	-------------	-----------	----------------

### Disinfection By-Products

Total Trihalomethanes (TTHMs) Units: ppb	N/A	80	3.9	N/A	N/A	2024	No	By-product of drinking water chlorination
---	-----	----	-----	-----	-----	------	----	---

Contaminants	MCLG	MCL	Your Water	Range Low High		Sample Date	Violation	Typical Source
--------------	------	-----	------------	-------------------	--	-------------	-----------	----------------

### Inorganic Contaminants

Arsenic Units: ppb	0	10	11.2	ND	30	2024	Yes	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
-----------------------	---	----	------	----	----	------	-----	--

Fluoride Units: ppm	4	4	0.28	N/A	N/A	2021	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
------------------------	---	---	------	-----	-----	------	----	---

Contaminants	MCLG	Action Level	Your Water	Range Low High	Sample Date	A.L. Exceeded	Typical Source
--------------	------	--------------	------------	----------------	-------------	---------------	----------------

### Lead and Copper Rule

Copper	1.3	1.3	0.345	0.16	0.4	2024	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Units: ppm - 90th Percentile				0 sites over Action Level				

Contaminants	MCLG	MCL	Your Water	Range Low High	Sample Date	Violation	Typical Source
--------------	------	-----	------------	----------------	-------------	-----------	----------------

### Radiological Contaminants

Adjusted Alpha (Excl. Radon & U)	0	15	8.6	N/A	N/A	2021	No	Erosion of natural deposits
Units: pCi/L								
Uranium (combined)	0	30	12.8	N/A	N/A	2021	No	Erosion of natural deposits
Units: ppb								

### Special Statements

#### Educational Statement for Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Second Mesa Day School - BIA is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your water utility. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

#### Service Line Inventory for Systems with All Non-Lead

Second Mesa Day School - BIA was required to complete an inventory of service line materials to determine whether any service lines connected to the distribution system are made of lead material. We determined that all service lines at Second Mesa Day School - BIA are made of non-lead materials. The service line inventory is available upon request, please contact us for more information.

#### Additional Information on Lead

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.





## Microbiological Testing

We are required to test your water regularly for signs of microbial contamination. Positive test results could lead to follow-up investigations called assessments and potentially the issuance of public health advisories. Assessments could lead to required corrective actions. The information below summarizes the results of those tests.

Calendar Year	Sampling Requirements	Sampling Conducted (months)	Total E.coli Positive	Assessment Triggers	Assessments Conducted
2024	1 Sample due monthly	11 out of 12	0	0	0

## Health-Based Violations

The table below lists the health-based violations the water system incurred during the last calendar year. While you should have received notification of the violations at an earlier date, we are required to list them in this report.

Contaminant Name	Type of Violation	Begin/End Date	Steps Taken to Correct the Violation	Return to Compliance	Return Date	Action Comment
Revised Total Coliform Rule (RTCR)	Failure to conduct routine monitoring	6/1/2024 - 6/30/2024	Following month reporting of all required results.			

## Public Notice for Monitoring/Reporting and Other Violations

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the period covered by this report, we did not complete all monitoring or testing for the contaminants listed below, and therefore cannot be sure of the quality of your drinking water during that time. Violations which have not been returned to compliance will be repeated annually. The table below lists the contaminants we did not properly test for or other violations during the report period.

Contaminant Name	Type of Violation	Begin/End Date	Steps Taken to Correct the Violation	Return to Compliance	Return Date	Action Comment
Nitrate [reported as Nitrogen]	Major monitoring/reporting violation for routine chemical monitoring.	1/1/2024 - 12/31/2024	Reporting monitoring results as required.			
Chlorine	Failure to submit DBPR results for Stage 1 or 2 Disinfection By-Products Rule	4/1/2024 - 6/30/2024	Submission of subsequent monitoring results.			

What should I do, as a consumer?

There is nothing you need to do at this time.

What is being done by the utility?

We will work with our regulatory official to conduct all required contaminant monitoring as directed.

## Definitions

Term	Definition
ppm	parts per million, or milligrams per liter (mg/L)
ppb	parts per billion, or microgram per liter (ug/L)
positive samples	the number of positive samples taken that year
% positive samples/month	% of samples taken monthly that were positive
pCi/L	picocuries per liter
ND	Not detected
N/A	Not applicable
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MRDL	Maximum Residual Disinfectant Level
MRDLG	Maximum Residual Disinfectant Level Goal
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, trigger treatment or other requirements which a water system must follow.
90th Percentile	Statistical value used to determine if Action Level is exceeded. Determined by calculating the value at which 90% of the samples tested were below that value.

### How can I get involved?

Please feel free to contact the number provided below for more information or for a translated copy of the report if you need it in another language.

\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\*

#### For more information please contact:

Kimberly Thomas, SMDS Principal, PO Box 98, Second Mesa, AZ 86043

Phone:

Fax: