



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Margaret Mace Elementary School

1201 Atlantic Avenue
North Wildwood, NJ 08260

Results of Lead Analysis

Date & Time First Draw Sampled: 02/16/2017 06:33 - 07:17

Date & Time Analyzed: 02/21/2017 12:38 - 16:42

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MM-Teacher's Lounge	<2.00	15.5
MM-Room14	3.17	15.5
MM-Room 13	5.29	15.5
MM-Room 12	4.90	15.5
MM-Room 11	3.25	15.5
MM-Kitchen Sink	<2.00	15.5
MM-Ice Machine	<2.00	15.5
MM-Room 9	2.82	15.5
MM-Room 8 Sink	5.36	15.5
MM-WF-12th Street Hall	4.40	15.5
MM-Room 7	8.97	15.5
MM-Room 6	4.87	15.5
MM-Room 5	28.6	15.5
MM-Annex North Left	4.70	15.5
MM-Annex North Right	5.80	15.5
MM-Annex South	4.74	15.5
MM-Woodshop Fountain	3.36	15.5
MM-First Floor New Left	<2.00	15.5
MM-First Floor New Right	<2.00	15.5
MM-Nurse Office Front	<2.00	15.5
MM-Office Back	23.9	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Merchantville Public School

130 South Centre Street
Merchantville, NJ 08109

Results of Lead Analysis

Date & Time First Draw Sampled: 02/16/2017 05:06 - 05:53

Date & Time Analyzed: 02/21/2017 15:32 - 16:34

Date & Time Analyzed: 02/22/2017 13:25 - 15:26

Sample Location	First Draw	Action Level
MM-Second Floor New Left	<2.00	15.5
MM-Second Floor New Right	<2.00	15.5
MM-Second Floor Old	5.32	15.5
MM-Music Room	11.5	15.5
MM-Third Floor New Left	<2.00	15.5
MM-Third Floor New Right	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

2-23-17

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfertest.com
 NJ DEP Certification #08006



Customer:	Margaret Mace Elementary School
Contact	Michael DeMayo
Address:	1201 Atlantic Avenue North Wildwood, NJ 08260
Phone:	Fax:
Office:	(609) 522-1454 x 634

Lab ID#	Sample Location	Collection Date	Time	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P60801	M.M. - Field Blank	2/16/17	633	X	D	1 x 250	HNO3*	First Draw Lead	
P60802	Teacher's lounge		635	X	D	1 x 250	HNO3*	First Draw Lead	
P60803	Room 14		636	X	D	1 x 250	HNO3*	First Draw Lead	
P60804	Room 13		637	X	D	1 x 250	HNO3*	First Draw Lead	
P60805	Room 12		638	X	D	1 x 250	HNO3*	First Draw Lead	
P60806	Room 11		640	X	D	1 x 250	HNO3*	First Draw Lead	
P60807	Kitchen Sink		642	X	D	1 x 250	HNO3*	First Draw Lead	
P60808	Ice Machine		643	X	D	1 x 250	HNO3*	First Draw Lead	
P60809	Room 9		646	X	D	1 x 250	HNO3*	First Draw Lead	
P60810	Room 8 Sink		648	X	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval _____	Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	* HNO3 preserved upon receipt at laboratory Yes No	°C Properly Preserved

Sampled by: <u>Justin M. Lillo</u>	Date	Time	Received by: <u>[Signature]</u>	Date	Time
Sampled by/Relinquished by: <u>[Signature]</u>	2/16/17	1515	(Signature)	2-16-17	1515
Relinquished by: <u>[Signature]</u>	Date	Time	(Signature)	Date	Time
Relinquished by: <u>[Signature]</u>	Date	Time	(Signature)	Date	Time



South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094
Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfertest.com
NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer: Margaret Mace Elementary School
Contact: Michael DeMayo
Address: 1201 Atlantic Avenue
North Wildwood, NJ 08260
Phone: Fax:
Office: (609) 522-1454 x 634

Lab ID#	Sample Location	Collection Date	Time	g Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P60811	M.M. - Water Fountain 1st St. H	2/16/17	650	X		D	1 x 250	HNO3*	First Draw Lead	
P60812	Room 7		652	X		D	1 x 250	HNO3*	First Draw Lead	
P60813	Room 6		653	X		D	1 x 250	HNO3*	First Draw Lead	
P60814	Room 5		655	X		D	1 x 250	HNO3*	First Draw Lead	
P60815	Annex North Left		656	X		D	1 x 250	HNO3*	First Draw Lead	
P60816	Annex North Right		657	X		D	1 x 250	HNO3*	First Draw Lead	
P60817	Annex South		658	X		D	1 x 250	HNO3*	First Draw Lead	
P60818	Woodshop Fountain		701	X		D	1 x 250	HNO3*	First Draw Lead	
P60819	First Floor New-Left		703	X		D	1 x 250	HNO3*	First Draw Lead	
P60820	First Floor New-Right		704	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SLISLUDGE GWGROUND WATER SWISURFACE WATER WWWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions		Cooler Temp °C Properly Preserved Yes No
		* HNO3 preserved upon receipt at laboratory		

Sampled by: Justin M. Lillo (Print)	Date	Time	Received by: (Signature)	Date	Time
Sampled by/Relinquished by: (Signature)	2/16/17	1515	(Signature)	2-16-17	1515
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time



South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094
Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfertest.com
NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer:	Margaret Mace Elementary School
Contact	Michael DeMayo
Address:	1201 Atlantic Avenue North Wildwood, NJ 08260
Phone:	Fax:
Office:	(609) 522-1454 x 634

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P60821	M.M. - Nurse Office front	2/16/17	706	X		D	1 x 250	HNO3*	First Draw Lead	
P60822	Nurse Office back		707	X		D	1 x 250	HNO3*	First Draw Lead	
P60823	Second Floor New-Left		709	X		D	1 x 250	HNO3*	First Draw Lead	
P60824	Second Floor New-Right		710	X		D	1 x 250	HNO3*	First Draw Lead	
P60825	Second Floor Old		712	X		D	1 x 250	HNO3*	First Draw Lead	
P60826	Music Room		714	X		D	1 x 250	HNO3*	First Draw Lead	
P60827	Third Floor New-Left		716	X		D	1 x 250	HNO3*	First Draw Lead	
P60828	Third Floor New-Right		717	X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions		Cooler Temp
				°C
		* HNO3 preserved upon receipt at laboratory		Properly Preserved Yes No

Sampled by: Justin M. Lillo	Received by: [Signature]	Date: 2/16/17	Time: 1515
Sampled by/Relinquished by: [Signature]	Received by: [Signature]	Date:	Time:
Relinquished by: [Signature]	Received by: [Signature]	Date:	Time:
Relinquished by: [Signature]	Received by: [Signature]	Date:	Time: