


# Climax Springs R-IV Schools

571 Climax Ave., Climax Springs, Missouri 65324-2535  
Phone: (573) 347-3905 [www.cspringsr4.org](http://www.cspringsr4.org)



RE: Get the Lead Out / Remediation Plan Climax Springs R-IV Schools

May 10, 2024

There were 70 water fixtures that were tested on April 1, 2024. Out of the 70, 16 of them tested over 5 PPB. There were zero water fountains and primary drinking sources that tested above the remediation level. With the 16 fixtures, the remediation plan will be as follows:

<u>Fixture Number</u>	<u>Remediation Step</u>	<u>Date</u>
008 (Cafeteria Coffe Pot)	Removed from Service	May 2024 (Complete)
016 (Elementary Bathroom Sink)	Post Sign Handwashing Only	May 2024 (Complete)
019 (Office Sink)	Replace Fixture	June 2024
040 (Science Sink)	Replace Fixture	June 2024
041 (Science Sink)	Replace Fixture	June 2024
042 (Science Sink)	Replace Fixture	June 2024
044 (Science Sink)	Replace Fixture	June 2024
046 (Science Sink)	Replace Fixture	June 2024
051 (Boys Locker Room Shower)	Post Sign Handwashing/Shower Only)	May 2024 (Complete)
054 (Concession stand sink)	Replace Fixture	June 2024
057 (Boys Bathroom Sink)	Post Sign Handwashing Only)	May 2024 (Complete)
059 (Girls Locker Room Sink)	Post Sign Handwashing Only)	May 2024 (Complete)
062 (Girls Locker Room Shower)	Post Sign Handwashing/Shower Only)	May 2024 (Complete)
063 (FACS Sink)	Replace Fixture	June 2024
064 (FACS Sink)	Replace Fixture	June 2024
070 (Bus Barn Bathroom Faucet)	Post Sign Handwashing Only	May 2024

Fixtures will be re-tested in the fall of 2024, after remediation and completion of the new well. For any questions please contact Mr. Joshua L. Griffith at [jgriffith@cspringsr4.org](mailto:jgriffith@cspringsr4.org).

Dr. Julie Dill  
Superintendent