

HOUSTON COUNTY SCHOOL DISTRICT

REQUEST FOR PROPOSALS

For

WRMS Track

RFP NUMBER 25-029

Questions and Answers

1. Question: While reviewing Addendum 1, I wanted to get some clarifications on the long Jump runway. Do you want a physical take off board system or do you want them painted? Also, are you looking for a concrete or asphalt runway. If asphalt, can we offer a price for concrete?

Answer:

- a. A painted line is sufficient to keep us consistent across the system.
- b. Regarding concrete or asphalt runway: Director of Maintenance would be ok with either for the runway but would like the box that retains the sand to be concrete.