



49 Woodside Street Stamford, CT 06902

December 22, 2016

New Milford Schools
Attn. Kevin Munrett

Re: Radon Re-evaluation
Schaghticoke Middle School

To Whom It May Concern:

Enclosed with this letter are the results of radon testing conducted at the above mentioned site. The radon testing was conducted in accordance with Connecticut Department of Public Health radon re-evaluation protocols. The testing was conducted over a three day period – December 12-15, 2016. The radon kits were sent via FedEx to Air Chek, Inc. in Mills River, NC for radon analysis. Listed below is a summary of the testing results:

<u>Kit Number</u>	<u>Location</u>	<u>Results</u>
• Kit # 7824225	Room 101	<0.3 pCi/L
• Kit # 7824226	Room 105	<0.3 pCi/L
• Kit # 7824227	QA/QC	<0.3 pCi/L
• Kit # 7824229	Room 110	0.5 pCi/L
• Kit # 7824219	Room 113A	0.6 pCi/L
• Kit # 7824233	Room 118	0.9 pCi/L
• Kit # 7824223	Room 141	<0.3 pCi/L
• Kit # 7824222	Room 153	0.7 pCi/L
• Kit # 7824221	Room 154	1.4 pCi/L
• Kit # 7824220	QA/QC	0.6 pCi/L
• Kit # 7824230	Room 194	<0.3 pCi/L
• Kit # 7824231	QA/QC	<0.3 pCi/L
• Kit # 7824232	Room 198	0.6 pCi/L
• Kit # 7824224	Room 97 - Nurse	0.6 pCi/L

As shown on the attached analysis report, none of the test kits deployed during this round of testing returned results that exceeded the **EPA action level of 4 pCi/L**.

For further information, please refer to the following websites:

<https://www.epa.gov/radon>

http://www.ct.gov/dph/cwp/view.asp?a=3140&q=387592&dphNav_GID=1828&dphPNa_vCtr=#47072

I am certified by the National Radon Safety Board (Certification Number 7SS0001), and listed on the Connecticut Department of Public Health list of "Radon Measurement Professionals".
If you have questions or would like to discuss the radon testing, please call me at 203-324-2222 or e-mail me at rebenhack@hygenix.com.

Sincerely,



Ryan Ebenhack MS CIEC
Hygenix, Inc.

*Attachments: Laboratory Results
Site Layout with sample locations*

December 21, 2016


**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
NEW MILFORD SCHOOLS
SMS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824225	101	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824226	105	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824227	105D	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824229	110	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.5 ± 0.2	2016-12-17
7824219	113A	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.6 ± 0.2	2016-12-17
7824233	118	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.9 ± 0.3	2016-12-17
7824223	141	2016-12-12 @ 12:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824222	153	2016-12-12 @ 12:00 pm	2016-12-15 @ 9:00 am	0.7 ± 0.2	2016-12-17
7824221	154	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	1.4 ± 0.3	2016-12-17
7824220	154B	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.6 ± 0.2	2016-12-17
7824230	194	2016-12-12 @ 12:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824231	194D	2016-12-12 @ 12:00 pm	2016-12-15 @ 9:00 am	< 0.3	2016-12-17
7824232	198	2016-12-12 @ 12:00 pm	2016-12-15 @ 8:00 am	0.6 ± 0.2	2016-12-17
7824224	97 - NURSE	2016-12-12 @ 1:00 pm	2016-12-15 @ 9:00 am	0.6 ± 0.2	2016-12-17

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

SMS 1st Fl.



(11)

11/15 - 11/17/11

Rooms TESTED:

- Main OFFICE
- Main OFF/DUP
- Principal OFFICE
- 79
- 75
- 92
- 92/BLANK
- 120
- 125
- 149
- 152
- 144
- 144/DUP
- 142

Blank 20

Rooms tested
December 12/12-12/15/16