

Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
BG	MV-GFW-DF-1	Ground Floor West Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-GFW-DF-2	Ground Floor West Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	7.99	2.00	
BG	MV-KIT-WS-1	West Kitchen Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	2.66	2.00	
BG	MV-KIT-WS-2	West Kitchen Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.31	2.00	
BG	MV-KIT-ES-1	East Kitchen Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-KIT-ES-2	East Kitchen Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	4.74	2.00	
BG	MV-GFC-DF-1	Ground Floor Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-GFC-DF-2	Ground Floor Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-GFE-DF-1	Ground Floor East Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-GFE-DF-2	Ground Floor East Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-WTR-DF-1	Weight Room Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	5.09	2.00	
BG	MV-WTR-DF-2	Weight Room Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.31	2.00	
BG	MV-HE-NS-1	North Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	38.40	2.00	
BG	MV-HE-NS-2	North Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.18	2.00	
BG	MV-HE-CS-1	Center Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	49.90	2.00	
BG	MV-HE-CS-2	Center Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.92	2.00	
BG	MV-HE-SS-1	South Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	38.40	2.00	
BG	MV-HE-SS-2	South Home Ec Sink	KS - Kitchen Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.43	2.00	
BG	MV-2FW-DF-1	Second Floor West Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	2.07	2.00	
BG	MV-2FW-DF-2	Second Floor West Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	5.18	2.00	
BG	MV-2FWC-DF-1	Second Floor West-Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-2FWC-DF-2	Second Floor West-Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-2FEC-DF-1	Second Floor East-Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	3.50	2.00	
BG	MV-2FEC-DF-2	Second Floor East-Center Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	2.94	2.00	
BG	MV-2FE-DF-1	Second Floor East Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	3.10	2.00	
BG	MV-2FE-DF-2	Second Floor East Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	6.61	2.00	
BG	MV-GYM-DF-1	Gym Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	3.36	2.00	
BG	MV-GYM-DF-2	Gym Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	2.52	2.00	
BG	MV-3F-DF-1	Third Floor Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	2.53	2.00	
BG	MV-3F-DF-2	Third Floor Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	3.84	2.00	
BG	MV-103-DF-1	Classroom 103 Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	26.60	2.00	
BG	MV-103-DF-2	Classroom 103 Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	27.50	2.00	
BG	MV-104-DF-1	Classroom 104 Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	9.06	2.00	
BG	MV-104-DF-2	Classroom 104 Drinking Fountain	DF - Drinking Fountain	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	11.20	2.00	
BG	MV-WKR-S-1	Teachers Lounge Sink	S - Sink	10/16/2017	4:00 PM	First Draw	250	STAT Analysis	EPA 200.8	<2.00	2.00	
BG	MV-WKR-S-2	Teachers Lounge Sink	S - Sink	10/16/2017	4:00 PM	Flush	250	STAT Analysis	EPA 200.8	<2.00	2.00	