

**Appendix D
Lead Results**

Client : PARS Environmental
Project ID : Broad Street Elementary School, 255 W. Broad Street

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
BSE-Field Blank	N	P21-09735-01	PAS	NJDEP 15001	8/27/21	8:05	SM 3113 B	9/9/21	12:53	0.470	2.00	1	N	ND
BSE-1-H7-WC-P	N	P21-09735-02	PAS	NJDEP 15001	8/27/21	8:06	SM 3113 B	9/9/21	12:57	2.42	2.00	1	N	
BSE-1-7-BF-P	N	P21-09735-03	PAS	NJDEP 15001	8/27/21	8:07	SM 3113 B	9/9/21	12:34	1.79	2.00	1	N	J
BSE-1-H108-WC-P	N	P21-09735-04	PAS	NJDEP 15001	8/27/21	8:10	SM 3113 B	9/9/21	13:37	0.310	2.00	1	N	ND
BSE-1-H102-WC-P	N	P21-09735-05	PAS	NJDEP 15001	8/27/21	8:12	SM 3113 B	9/9/21	13:41	0.240	2.00	1	N	ND
BSE-1-H102-BT-P	N	P21-09735-06	PAS	NJDEP 15001	8/27/21	8:13	SM 3113 B	9/9/21	13:44	0.240	2.00	1	N	ND
BSE-1-Kitchen-FP1-P	N	P21-09735-07	PAS	NJDEP 15001	8/27/21	8:15	SM 3113 B	9/9/21	13:51	34.3	20.0	10	N	
BSE-1-Kitchen-FP2-P	N	P21-09735-08	PAS	NJDEP 15001	8/27/21	8:16	SM 3113 B	9/9/21	13:55	3.66	2.00	1	N	
BSE-1-Kitchen-ST-P	N	P21-09735-09	PAS	NJDEP 15001	8/27/21	8:17	SM 3113 B	9/9/21	13:58	3.66	2.00	1	N	
BSE-1-Kitchen-FP3-P	N	P21-09735-10	PAS	NJDEP 15001	8/27/21	8:19	SM 3113 B	9/9/21	14:02	0.240	2.00	1	N	ND
BSE-1-H219-WC-P	N	P21-09735-11	PAS	NJDEP 15001	8/27/21	8:23	SM 3113 B	9/9/21	14:06	1.56	2.00	1	N	J
BSE-1-H212-WC-P	N	P21-09735-12	PAS	NJDEP 15001	8/27/21	8:25	SM 3113 B	9/9/21	14:17	0.240	2.00	1	N	ND
BSE-1-H212-BT-P	N	P21-09735-13	PAS	NJDEP 15001	8/27/21	8:26	SM 3113 B	9/9/21	14:20	0.160	2.00	1	N	ND
BSE-1-H206-WC-P	N	P21-09735-14	PAS	NJDEP 15001	8/27/21	8:27	SM 3113 B	9/9/21	14:24	0.240	2.00	1	N	ND
BSE-1-H206-BT-P	N	P21-09735-15	PAS	NJDEP 15001	8/27/21	8:28	SM 3113 B	9/9/21	14:27	0.470	2.00	1	N	ND