



Thursday, September 08, 2022

Attn: Andrew Donnelly
White Water, Inc.
253B Worcester Road
Charlton, MA 01507

Project ID: STERLING WATER SYSTEM
SDG ID: GCM18940
Sample ID#s: CM18940 - CM18941

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Sample Id Cross Reference

September 08, 2022

SDG I.D.: GCM18940

Project ID: STERLING WATER SYSTEM

Client Id	Lab Id	Matrix
251 STERLING RD.	CM18940	DRINKING WATER
EP-WELLS 1A, 2 & 3	CM18941	DRINKING WATER



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

September 08, 2022

FOR: Attn: Andrew Donnelly
White Water, Inc.
253B Worcester Road
Charlton, MA 01507

Sample Information

Matrix: DRINKING WATER
Location Code: WHITEWAT
Rush Request: Standard
P.O.#:

Custody Information

Collected by: PHOENIX
Received by: LB
Analyzed by: see "By" below

Date

08/31/22
08/31/22

Time

8:55
12:10

Laboratory Data

SDG ID: GCM18940
Phoenix ID: CM18940

Project ID: STERLING WATER SYSTEM
Client ID: 251 STERLING RD.

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Chlorine Residual	0.28	0.01	1	mg/L		4		08/31/22 08:55	*	SM4500Cl-G-00
Extraction for Haloacetic Acids	Completed							09/01/22	D/D	E552.2
<u>Haloacetic Acids</u>										
Dibromoacetic Acid	ND	1.0	1	ug/L				09/05/22	CK	E552.2
Dichloroacetic Acid	ND	1.0	1	ug/L				09/05/22	CK	E552.2
Monobromoacetic Acid	ND	1.0	1	ug/L				09/05/22	CK	E552.2
Monochloroacetic Acid	ND	2.0	1	ug/L				09/05/22	CK	E552.2
Total Haloacetic Acids	ND	1.0	1	ug/L		60		09/05/22	CK	E552.2
Trichloroacetic Acid	ND	1.0	1	ug/L				09/05/22	CK	E552.2
<u>QA/QC Surrogates</u>										
% 2,3-DBPA	93		1	%	NA	NA	NA	09/05/22	CK	70 - 130 %
% 2,3-DBPA (Confirmation)	90		1	%	NA	NA	NA	09/05/22	CK	70 - 130 %

Trihalomethane Analysis

Bromodichloromethane	2.9	0.50	1	ug/L				09/01/22	HM	E524.2
Bromoform	0.67	0.50	1	ug/L				09/01/22	HM	E524.2
Chloroform	2.4	0.50	1	ug/L				09/01/22	HM	E524.2
Dibromochloromethane	2.7	0.50	1	ug/L				09/01/22	HM	E524.2
Total Trihalomethanes (TTHM)	8.67	0.50	1	ug/L		80		09/01/22	HM	E524.2
<u>QA/QC Surrogates</u>										
% 1,2-dichlorobenzene-d4	95		1	%	NA	NA	NA	09/01/22	HM	70 - 130 %
% Bromofluorobenzene	93		1	%	NA	NA	NA	09/01/22	HM	70 - 130 %

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected

BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)


AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

QA/QC Surrogates: Surrogates are compounds (preceded with a %) added by the lab to determine analysis efficiency. Surrogate results(%) listed in the report are not "detected" compounds.

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs; CT Public Health Code 19-13-B102. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

September 08, 2022

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

September 08, 2022

FOR: Attn: Andrew Donnelly
White Water, Inc.
253B Worcester Road
Charlton, MA 01507

Sample Information

Matrix: DRINKING WATER
Location Code: WHITEWAT
Rush Request: Standard
P.O.#:

Custody Information

Collected by: PHOENIX
Received by: LB
Analyzed by: see "By" below

Date

08/31/22
08/31/22

Time

9:00
12:10

Laboratory Data

SDG ID: GCM18940
Phoenix ID: CM18941

Project ID: STERLING WATER SYSTEM
Client ID: EP-WELLS 1A, 2 & 3

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Nitrite as Nitrogen	< 0.004	0.004	1	mg/L		1		09/01/22 03:55	BS/GD	E300.0
Nitrate as Nitrogen	0.08	0.01	1	mg/L		10		09/01/22 03:55	BS/GD	E300.0

Volatiles

1,1,1,2-Tetrachloroethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,1,1-Trichloroethane	ND	0.50	1	ug/L		200		09/01/22	HM	E524.2
1,1,2,2-Tetrachloroethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,1,2-Trichloroethane	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
1,1,2-Trichlorotrifluoroethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,1-Dichloroethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,1-Dichloroethene	ND	0.50	1	ug/L		7		09/01/22	HM	E524.2
1,1-Dichloropropene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,2,3-Trichlorobenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,2,3-Trichloropropane	ND	0.50	1	ug/L	0.05			09/01/22	HM	E524.2
1,2,4-Trichlorobenzene	ND	0.50	1	ug/L		70		09/01/22	HM	E524.2
1,2,4-Trimethylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,2-Dichlorobenzene	ND	0.50	1	ug/L		600		09/01/22	HM	E524.2
1,2-Dichloroethane	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
1,2-Dichloropropane	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
1,3,5-Trimethylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,3-Dichlorobenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,3-Dichloropropane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
1,4-Dichlorobenzene	ND	0.50	1	ug/L		75		09/01/22	HM	E524.2
2,2-Dichloropropane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
2-Chlorotoluene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
4-Chlorotoluene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Benzene	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
Bromobenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Bromochloromethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Bromodichloromethane	1.5	0.50	1	ug/L				09/01/22	HM	E524.2
Bromoform	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Bromomethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Carbon tetrachloride	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
Chlorobenzene	ND	0.50	1	ug/L		100		09/01/22	HM	E524.2
Chloroethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Chloroform	1.1	0.50	1	ug/L				09/01/22	HM	E524.2
Chloromethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
cis-1,2-Dichloroethene	ND	0.50	1	ug/L		70		09/01/22	HM	E524.2
cis-1,3-Dichloropropene	ND	0.40	1	ug/L				09/01/22	HM	E524.2
Dibromochloromethane	1.3	0.50	1	ug/L				09/01/22	HM	E524.2
Dibromomethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Dichlorodifluoromethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Ethylbenzene	ND	0.50	1	ug/L		700		09/01/22	HM	E524.2
Hexachlorobutadiene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Isopropylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
m&p-Xylene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Methyl t-butyl ether (MTBE)	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Methylene chloride	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
Naphthalene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
n-Butylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
n-Propylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
o-Xylene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
p-Isopropyltoluene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
sec-Butylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Styrene	ND	0.50	1	ug/L		100		09/01/22	HM	E524.2
tert-Butylbenzene	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Tetrachloroethene	ND	0.50	1	ug/L		5		09/01/22	HM	E524.2
Toluene	ND	0.50	1	ug/L		1000		09/01/22	HM	E524.2
Total 1,3-Dichloropropene	ND	0.40	1	ug/L				09/01/22	HM	E524.2
Total Trihalomethanes	3.90	0.50	1	ug/L		80		09/01/22	HM	E524.2
Total Xylenes	ND	0.50	1	ug/L		10000		09/01/22	HM	E524.2
trans-1,2-Dichloroethene	ND	0.50	1	ug/L		100		09/01/22	HM	E524.2
trans-1,3-Dichloropropene	ND	0.40	1	ug/L				09/01/22	HM	E524.2
Trichloroethene	ND	0.50	1	ug/L	1000	5		09/01/22	HM	E524.2
Trichlorofluoromethane	ND	0.50	1	ug/L				09/01/22	HM	E524.2
Vinyl chloride	ND	0.50	1	ug/L		2		09/01/22	HM	E524.2
QA/QC Surrogates										
% 1,2-dichlorobenzene-d4	92		1	%	NA	NA	NA	09/01/22	HM	70 - 130 %
% Bromofluorobenzene	94		1	%	NA	NA	NA	09/01/22	HM	70 - 130 %

Volatile Library Search Completed

09/08/22 HM

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)

AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal


QA/QC Surrogates: Surrogates are compounds (preceded with a %) added by the lab to determine analysis efficiency. Surrogate results(%) listed in the report are not "detected" compounds.

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; CT Public Health Code 19-13-B102. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): CT Public Health Code 19-13-B102.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

September 08, 2022

Reviewed and Released by: Phyllis Shiller, Laboratory Director



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045

Tel. (860) 645-1102

Fax (860) 645-0823

QA/QC Report

September 08, 2022

QA/QC Data

SDG I.D.: GCM18940

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 640284 (mg/L), QC Sample No: CM19906 (CM18941)													
Nitrate as Nitrogen	BRL	0.05	1.40	1.41	0.70	101			96.5			90 - 110	20
Nitrite as Nitrogen	BRL	0.01	<0.01	<0.01	NC	99.1			96.6			90 - 110	20



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045

Tel. (860) 645-1102

Fax (860) 645-0823

QA/QC Report

September 08, 2022

QA/QC Data

SDG I.D.: GCM18940

Parameter	Blank	Blk RL	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 640432A (ug/L), QC Sample No: CM18387 (CM18940)

Haloacetic Acids - Drinking Water

Dibromoacetic Acid	ND	1.0	102			104			70 - 130	20
Dichloroacetic Acid	ND	1.0	103			101			70 - 130	20
Monobromoacetic Acid	ND	1.0	105			101			70 - 130	20
Monochloroacetic Acid	ND	2.0	111			107			70 - 130	20
Trichloroacetic Acid	ND	1.0	94			87			70 - 130	20
% 2,3-DBPA	97	%	99			93			70 - 130	20
% 2,3-DBPA (Confirmation)	94	%	97			94			70 - 130	20

QA/QC Batch 640429 (ug/L), QC Sample No: CM18940 (CM18940, CM18941)

Volatiles - Drinking Water

1,1,1,2-Tetrachloroethane	ND	0.50	107	107	0.0				70 - 130	30
1,1,1-Trichloroethane	ND	0.50	102	104	1.9				70 - 130	30
1,1,2,2-Tetrachloroethane	ND	0.50	96	94	2.1				70 - 130	30
1,1,2-Trichloroethane	ND	0.50	101	103	2.0				70 - 130	30
1,1-Dichloroethane	ND	0.50	102	102	0.0				70 - 130	30
1,1-Dichloroethene	ND	0.50	94	99	5.2				70 - 130	30
1,1-Dichloropropene	ND	0.40	102	103	1.0				70 - 130	30
1,2,3-Trichlorobenzene	ND	0.50	103	104	1.0				70 - 130	30
1,2,3-Trichloropropane	ND	0.50	100	98	2.0				70 - 130	30
1,2,4-Trichlorobenzene	ND	0.50	101	104	2.9				70 - 130	30
1,2,4-Trimethylbenzene	ND	0.50	100	103	3.0				70 - 130	30
1,2-Dichlorobenzene	ND	0.50	102	103	1.0				70 - 130	30
1,2-Dichloroethane	ND	0.50	103	100	3.0				70 - 130	30
1,2-Dichloropropane	ND	0.50	97	101	4.0				70 - 130	30
1,3,5-Trimethylbenzene	ND	0.50	103	104	1.0				70 - 130	30
1,3-Dichlorobenzene	ND	0.50	104	104	0.0				70 - 130	30
1,3-Dichloropropane	ND	0.50	100	101	1.0				70 - 130	30
1,4-Dichlorobenzene	ND	0.50	102	105	2.9				70 - 130	30
2,2-Dichloropropane	ND	0.50	103	102	1.0				70 - 130	30
2-Chlorotoluene	ND	0.50	101	104	2.9				70 - 130	30
4-Chlorotoluene	ND	0.50	103	106	2.9				70 - 130	30
Benzene	ND	0.50	101	101	0.0				70 - 130	30
Bromobenzene	ND	0.50	104	105	1.0				70 - 130	30
Bromochloromethane	ND	0.50	103	106	2.9				70 - 130	30
Bromodichloromethane	ND	0.50	105	105	0.0				70 - 130	30
Bromoform	ND	0.50	106	105	0.9				70 - 130	30
Bromomethane	ND	0.50	101	100	1.0				70 - 130	30
Carbon tetrachloride	ND	0.50	114	117	2.6				70 - 130	30
Chlorobenzene	ND	0.50	101	102	1.0				70 - 130	30
Chloroethane	ND	0.50	99	101	2.0				70 - 130	30
Chloroform	ND	0.50	104	107	2.8				70 - 130	30
Chloromethane	ND	0.50	97	93	4.2				70 - 130	30

QA/QC Data

SDG I.D.: GCM18940

Parameter	Blank	Blk RL	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
cis-1,2-Dichloroethene	ND	0.50	102	100	2.0				70 - 130	30
cis-1,3-Dichloropropene	ND	0.40	101	103	2.0				70 - 130	30
Dibromochloromethane	ND	0.50	105	107	1.9				70 - 130	30
Dibromomethane	ND	0.50	101	99	2.0				70 - 130	30
Dichlorodifluoromethane	ND	0.50	79	95	18.4				70 - 130	30
Ethylbenzene	ND	0.50	104	103	1.0				70 - 130	30
Hexachlorobutadiene	ND	0.40	105	107	1.9				70 - 130	30
Isopropylbenzene	ND	0.50	103	105	1.9				70 - 130	30
m&p-Xylene	ND	0.50	105	105	0.0				70 - 130	30
Methyl t-butyl ether (MTBE)	ND	0.50	94	92	2.2				70 - 130	30
Methylene chloride	ND	0.50	96	95	1.0				70 - 130	30
Naphthalene	ND	0.50	95	95	0.0				70 - 130	30
n-Butylbenzene	ND	0.50	102	106	3.8				70 - 130	30
n-Propylbenzene	ND	0.50	102	105	2.9				70 - 130	30
o-Xylene	ND	0.50	101	101	0.0				70 - 130	30
p-Isopropyltoluene	ND	0.50	101	105	3.9				70 - 130	30
sec-Butylbenzene	ND	0.50	102	106	3.8				70 - 130	30
Styrene	ND	0.50	104	105	1.0				70 - 130	30
tert-Butylbenzene	ND	0.50	101	103	2.0				70 - 130	30
Tetrachloroethene	ND	0.50	101	102	1.0				70 - 130	30
Toluene	ND	0.50	101	101	0.0				70 - 130	30
trans-1,2-Dichloroethene	ND	0.50	99	99	0.0				70 - 130	30
trans-1,3-Dichloropropene	ND	0.40	102	103	1.0				70 - 130	30
Trichloroethene	ND	0.50	103	104	1.0				70 - 130	30
Trichlorofluoromethane	ND	0.50	96	106	9.9				70 - 130	30
Trichlorotrifluoroethane	ND	0.50	81	93	13.8				70 - 130	30
Vinyl chloride	ND	0.50	98	101	3.0				70 - 130	30
% 1,2-dichlorobenzene-d4	95	%	105	106	0.9				70 - 130	30
% Bromofluorobenzene	97	%	101	101	0.0				70 - 130	30

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

RPD - Relative Percent Difference

LCS - Laboratory Control Sample


LCSD - Laboratory Control Sample Duplicate

MS - Matrix Spike

MS Dup - Matrix Spike Duplicate

NC - No Criteria

Intf - Interference



Phyllis Shiller, Laboratory Director
September 08, 2022

Thursday, September 08, 2022

Criteria: CT: DW

State: CT

Sample Criteria Exceedances Report
GCM18940 - WHITEWAT

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedances. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedance information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

September 08, 2022

SDG I.D.: GCM18940

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

Coolant: Cooler: Yes ☒ No ☐
IPK ☒ ICE ☐ N ☐
Temp 216 Pg of



CHAIN OF CUSTODY RECORD

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
Email: service@phoenixlabs.com Fax (860) 645-0823

Client Services (860) 645-8726

PO #:

JAMES - YR
Chlorinated System
PWS #: CT1360011

Customer: Town of Sterling (WHITEWAT)

Report To: Russell M. Gray

PWS Project: Sterling Water System 01-01-22 / 12-31-22 (YR)

Address: 1114 Plainfield Parkway, P.O. Box 157

Invoice To: Russell M. Gray

PWS Address: 1114 Plainfield Parkway, STERLING

City, State Zip: Oneco, CT 06373-0157

Ph / Fax: 860-564-2904 / 860-564-1660

PWS Phone: Russell M. Gray 860-564-2904

Client Sample - Information - Identification

**Sampler's
Signature**

Date 8/31/22

Matrix Code:

DW=drinking water
GW=groundwater

WW=wastewater
SL=sludge

S=soil/solid O=other
A=air

Analysis Request

[illegible]

Relinquished by:

Accepted by:

Date:

Time:

Turnaround:

☐ 1 Day*

☐ 2 Days*

☐ 3 Days*

☐ Standard

☐ Other

* Surcharge Applies

Sample Type: RT-Compliance Routine, RP-Repeat, SP-Special, O-Other

Sampling Point ID: Assigned by DWD or 4-Generic Distribution, 3- Entry Point,
2- Raw Well

WSFID: Assigned or 00600-Distribution, 00700-Entry Point

Duration: M-Monthly, Q-Quarterly, A-Annual, 3-Triannual, Y-Yearly

Repeat Location: OR-Original, DN-Downstream, UP-Upstream, OT-Other

Comments, Special Requirements or Regulations:

must collect in August

Numerical Value Needed for Chlorine Residual
See attachment for Sampling Point Ids...