



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-07 Client Sample ID: Burns HS Kitchen
 Collection Date: 2/21/2024 5:00:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Kitchen

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.520		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-08 Client Sample ID: Burns HS Boys Locker Rm DF
 Collection Date: 2/21/2024 5:07:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Boys Locker Rm DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.901		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-09 Client Sample ID: Burns HS Girls Locker Rm DF
 Collection Date: 2/21/2024 5:12:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Girls Locker Rm DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.41		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-10 Client Sample ID: Burns HS Btwn Locker Rms DF
 Collection Date: 2/21/2024 5:02:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Btwn Locker Rms DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-11 Client Sample ID: Burns HS Rm 41
 Collection Date: 2/21/2024 5:05:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Rm 41

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	13.6		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-12 Client Sample ID: Burns HS Booster Rm DF
 Collection Date: 2/21/2024 5:15:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Booster Rm DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-13 Client Sample ID: Burns HS Center Hall DF
 Collection Date: 2/21/2024 5:20:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Center Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.700		0.500	ppb	1	2/27/2024	15.0	A	

Lab ID: 24021000-14 Client Sample ID: Burns HS South Hall DF
 Collection Date: 2/21/2024 5:30:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS South Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A	

Lab ID: 24021000-15 Client Sample ID: Burns HS Staff Rm
 Collection Date: 2/21/2024 5:25:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Staff Rm

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.940		0.500	ppb	1	2/27/2024	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original