



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-07 Client Sample ID: Burns HS Kitchen
 Collection Date: 2/21/2024 5:00:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Kitchen

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.520		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-08 Client Sample ID: Burns HS Boys Locker Rm DF
 Collection Date: 2/21/2024 5:07:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Boys Locker Rm DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.901		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-09 Client Sample ID: Burns HS Girls Locker Rm DF
 Collection Date: 2/21/2024 5:12:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Girls Locker Rm DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.41		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-10 Client Sample ID: Burns HS Btwn Locker Rms DF
 Collection Date: 2/21/2024 5:02:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Btwn Locker Rms DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-11 Client Sample ID: Burns HS Rm 41
 Collection Date: 2/21/2024 5:05:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Rm 41

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	13.6		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-12 Client Sample ID: Burns HS Booster Rm DF
 Collection Date: 2/21/2024 5:15:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Booster Rm DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-13 Client Sample ID: Burns HS Center Hall DF
 Collection Date: 2/21/2024 5:20:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Center Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.700		0.500	ppb	1	2/27/2024	15.0	A	

Lab ID: 24021000-14 Client Sample ID: Burns HS South Hall DF
 Collection Date: 2/21/2024 5:30:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS South Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A	

Lab ID: 24021000-15 Client Sample ID: Burns HS Staff Rm
 Collection Date: 2/21/2024 5:25:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Burns HS Staff Rm

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.940		0.500	ppb	1	2/27/2024	15.0	A	

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-07A

Date Received: 2 / 26 / 24

Received By: DG Ambo

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21</u> : <u>00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05</u> : <u>00</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>		PWS ID 41- _____
Sample Collected by:	<u>CB / WP DIST #3</u>		Bottle # <u>13309</u>
Address:	<u>BURNS HIGH SCHOOL</u>		Space # _____
Faucet Location: (e.g. Kitchen Faucet)	<u>KITCHEN</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature	<u>HARNEY COUNTY SCHOOL DIST #3</u>		Date <u>02-21-24</u>



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-08A
Received By: DG

Date Received: 2 / 26 / 24
Time Received: 10 : 05 am/pm

amb

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21 : 00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05 : 07</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>	PWS ID 41- _____	
Sample Collected by:	<u>CB / WP DIST #3</u>	Bottle # <u>13251</u>	
Address:	<u>BURNS HIGH SCHOOL</u>	Space # _____	
Faucet Location: (e.g. Kitchen Faucet)	<u>DRINKING FOUNTAIN IN BOY'S LOCKER ROOM</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature <u>HARNEY COUNTY SCHOOL</u>	Date <u>02-21-24</u>		

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-09A

Date Received: 2 / 26 / 24

Received By: DG DMW

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21 : 00 am/pm Date 02, 20, 2024

Sample was collected: Time 05 : 12 am/pm Date 02, 21, 2024

Name of Water System: HARNEY COUNTY SCHOOL PWS ID 41- _____

Sample Collected by: CB / WP DIST #3 Bottle # 13252

Address: BURNS HIGH SCHOOL Space # _____

Faucet Location: (e.g. Kitchen Faucet) DRINKING FOUNTAIN IN GIRLS LOCKER RM

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-21-24

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-10A

Date Received: 2 / 26 / 24

Received By: DG amb

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21</u> : <u>00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05</u> : <u>02</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>		PWS ID 41- _____
Sample Collected by:	<u>CB / WP DIST #3</u>		Bottle # <u>13259</u>
Address:	<u>BURNS HIGH SCHOOL</u>		Space # _____
Faucet Location: (e.g. Kitchen Faucet)	<u>DRINKING FOUNTAIN BETWEEN LOCKER ROOMS</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature <u>HARNEY COUNTY SCHOOL</u>	Date <u>02-21-24</u>		

Page 24 of 40
DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-11A

Date Received: 2, 26, 24

Received By: DG Ambs

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21 : 00 am/pm Date 02, 20, 2024

Sample was collected: Time 05 : 05 am/pm Date 02, 21, 2024

Name of Water System: HARNEY COUNTY SCHOOL PWS ID 41- _____

Sample Collected by: CB / WP DIST #3 Bottle # 13264

Address: BURNS HIGH SCHOOL Space # _____

Faucet Location: (e.g. Kitchen Faucet) RM 41

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-21-24

Page 23 of 40
DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-12A
 Received By: DG

Date Received: 2 / 26 / 24
 Time Received: 10 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21 : 00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05 : 15</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>		PWS ID 41- _____
Sample Collected by:	<u>CB / WP DIST #3</u>		Bottle # _____
Address:	<u>BURNS HIGH SCHOOL</u>		Space # _____
Faucet Location: (e.g. Kitchen Faucet)	<u>BOOSTER ROOM DRINKING FOUNTAIN</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature <u>HANEY COUNTY SCHOOL</u>	Date <u>02-21-24</u>		



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-13A

Date Received: 2 / 26 / 24

Received By: DB

AWD

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21 : 00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05 : 20</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>		PWS ID 41- _____
Sample Collected by:	<u>CB / WP DIST #3</u>		Bottle # <u>133024</u>
Address:	<u>BURNS HIGH SCHOOL</u>		Space # _____
Faucet Location: (e.g. Kitchen Faucet)	<u>DRINKING FOUNTAIN CENTER HALL</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature <u>HARNEY COUNTY SCHOOL</u>	Date <u>02-21-24</u>		

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-14A
 Received By: DG

Date Received: 2 / 26 / 24
 Time Received: 10 : 05 am/pm

Amw

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT			
Water was last used:	Time <u>21 : 00</u> am/pm	Date <u>02, 20, 2024</u>	
Sample was collected:	Time <u>05 : 30</u> am/pm	Date <u>02, 21, 2024</u>	
Name of Water System:	<u>HARNEY COUNTY SCHOOL</u>		PWS ID 41- _____
Sample Collected by:	<u>CB / WP DIST #3</u>		Bottle # <u>13209</u>
Address:	<u>BURNS HIGH SCHOOL</u>		Space # _____
Faucet Location: (e.g. Kitchen Faucet)	<u>DRINKING FOUNTAIN SOUTH HALL</u>		
I have read the above directions and have taken a tap sample in accordance with these directions.			
Signature <u>HANEY COUNTY SCHOOL</u>	Date <u>02-21-24</u>		

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-15A

Date Received: 2 / 26 / 24

Received By: DG

AMND

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21 : 00 am/pm Date 02, 20, 2024

Sample was collected: Time 05 : 25 am/pm Date 02, 21, 2024

Name of Water System: HARNEY COUNTY SCHOOL PWS ID 41- _____

Sample Collected by: CB / WP DIST #3 Bottle # 13313

Address: BURNS HIGH SCHOOL Space # _____

Faucet Location: (e.g. Kitchen Faucet) STAFF ROOM

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-21-24

Page 29 of 40
DIST #3