



# Mobile County PUBLIC SCHOOLS

**BOARD OF SCHOOL COMMISSIONERS**  
Sherry Dillihay-McDade, President - District 4  
Don Stringfellow, Vice President - District 2  
L. Douglas Harwell, Jr. - District 1  
Reginald A. Crenshaw, Ph.D. - District 3  
Johnny Hatcher - District 5

1 Magnum Pass | Mobile, Alabama 36618 | 251-221-4000 | www.mcpss.com

**SUPERINTENDENT Chresal D. Threadgill**

Purchasing Department  
Phone (251)221-4473  
Fax (251)221-4472  
mcpss.com

PQ NO. 23-31  
Buyer: Julie Morgan

October 2, 2023

**ADDENDUM #1**  
**REQUEST FOR QUOTE**  
**ELECTRIC BOILER AND INSTALLATION**  
**THEODORE HIGH SCHOOL**

Please incorporate the following changes/clarifications into your quote:

- All isolation valves must be replaced with new valves.
- The existing pump will be removed and left in the mechanical room for MCPSS.
- The new pump must not be installed over the top of the boiler. Furnish and install new pump (Taco brand; or approved equal).
- Chemical feeder, make up water, backflow and air vents must be replaced with new replacements.
- Must add a "Y" strainer to the main line feeding the boiler.

Sincerely,

Russell Hudson  
Director of Purchasing

RH/jdm