

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET

WASHINGTON, NEW JERSEY 07882

LABORATORY CERT# 21016

908-835-2510

Date of Report: 6/13/22

Project Name: GW School

Sample Date & Time: 5/31/22 09:37

Sampled By: KR

386 Hudson Street
Hackensack City, NJ 07601
Sample Type: First Draw

Parameter	Result	MCL	Procedure	NJ Lab Cert #	Analysis Date/Time
Lead (Men's Bathroom 1 st)	2.56 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:31
Lead (Kitchen Middle)	2.97 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:32
Lead (Women's Bathroom 1 st Right)	5.63 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:34
Lead (2 nd Staff Bathroom)	3.52 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:35
Lead (Nurse Room)	3.71 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:37
Lead (2 nd Floor Left Student Bathroom)	3.42 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:38
Lead (3 rd Boys Bathroom)	5.09 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:43

Lead (3 rd Staff Bathroom)	1.63 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:45
Lead (2 nd Rights Student)	2.34 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:46
Lead (Left 3 rd Boys Bathroom)	3.11 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:48
Lead (1 st Bathroom Right Men)	5.21 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:54
Lead (Right Kitchen)	8.02 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:56
Lead (Left Kitchen)	10.7 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:57
Lead (1 st Woman Bathroom Left)	4.89 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 6:02
Lead (Janitors 2 nd)	7.50 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:48
Lead (Office Bathroom)	1.33 ug/l	15 ug/l	EPA Method 200.8	03036	06/07/22 5:26

Analytical results HAVE met NJDEP drinking water standards of 1300 ug/l for Copper or Action Level of 15 ug/l for Lead.

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.



Harold Blaine
Laboratory Manager

MCL – Maximum Contaminant Level