

SECTION 009113 – ADDENDUM

PART 1 - Addendum 3

1.1 PROJECT INFORMATION

- A. Project Name: RFP 268 Roof, Tuckpointing at FCRC Building
- B. Owner: Riverview Gardens School District.
- C. Date of Addendum: 08/24/2022.

1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is changed by this Addendum, please refer to website for new time.

1.3 ADDITIONAL INFORMATION FOR SCOPE OF WORK

- A. **Change to the scope of work for the “Dome” roof:**
 - 1. Roof will receive infrared scan to mark any areas containing moisture in the insulation. These locations will be marked for removal.
 - 2. Remove only damaged insulation, the rest to remain.
 - 3. Pressure wash roof to remove loose dirt and debris.
 - 4. Install 60 mil KEE FB in low rise foam adhesive to a prepared substrate.
 - 5. The scope otherwise remains the same.

END OF SECTION 009113