

Environmental Consultants
And Laboratory Services

(203) 324-2222
Fax (203) 324-9857



49 Woodside Street Stamford, CT 06902

December 22, 2016

New Milford Schools
Attn. Kevin Munrett

Re: Radon Re-evaluation
New Milford High School

To Whom It May Concern:

Enclosed with this letter are the results of radon testing conducted at the above mentioned site. The radon testing was conducted in accordance with Connecticut Department of Public Health radon re-evaluation protocols. The testing was conducted over a three day period – December 12-15, 2016. The radon kits were sent via FedEx to Air Chek, Inc. in Mills River, NC for radon analysis. Listed below is a summary of the testing results:

<u>Kit Number</u>	<u>Location</u>	<u>Results</u>
• Kit # 7824265	Room 1011	0.7 pCi/L
• Kit # 7824266	QA/QC	<0.3 pCi/L
• Kit # 7824267	Room 1108	<0.3 pCi/L
• Kit # 7824268	Room 1105	<0.3 pCi/L
• Kit # 7824272	Room 1111	<0.3 pCi/L
• Kit # 7824271	QA/QC	<0.3 pCi/L
• Kit # 7824278	Room 1303	<0.3 pCi/L
• Kit # 7824277	Room 1311	<0.3 pCi/L
• Kit # 7824274	Room 1313	<0.3 pCi/L
• Kit # 7824275	Room 1315	<0.3 pCi/L
• Kit # 7824276	Room 1318	<0.3 pCi/L
• Kit # 7824269	Room 1404	0.6 pCi/L
• Kit # 7824279	Room 1407	0.7 pCi/L
• Kit # 7824280	QA/QC	0.6 pCi/L
• Kit # 7824273	Room 1504	<0.3 pCi/L
• Kit # 7824263	Room 1518	0.5 pCi/L
• Kit # 7824270	Library Computer Lab	0.6 pCi/L
• Kit # 7824264	Resource	<0.3 pCi/L

As shown on the attached analysis report, none of the test kits deployed during this round of testing returned results that exceeded the EPA action level of 4 pCi/L.

For further information, please refer to the following websites:

<https://www.epa.gov/radon>

http://www.ct.gov/dph/cwp/view.asp?a=3140&q=387592&dphNav_GID=1828&dphPNa_vCtr=#47072

I am certified by the National Radon Safety Board (Certification Number 7SS0001), and listed on the Connecticut Department of Public Health list of "Radon Measurement Professionals".

If you have questions or would like to discuss the radon testing, please call me at 203-324-2222 or e-mail me at rebenhack@hygenix.com.

Sincerely,



Ryan Ebenhack MS CIEC
Hygenix, Inc.

*Attachments: Laboratory Results
Site Layout with sample locations*

December 21, 2016

**** LABORATORY ANALYSIS REPORT ****


Radon test result report for:
**NEW MILFORD SCHOOLS
NM HIGH**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824265	1101	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	0.7 ± 0.2	2016-12-17
7824266	1101D	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824268	1105	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824267	1108	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824272	1111	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824271	1111B	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824278	1303	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824277	1311	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824274	1313	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824275	1315	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824276	1318	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824269	1404	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	0.6 ± 0.2	2016-12-17
7824279	1407	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	0.7 ± 0.2	2016-12-17
7824280	1407B	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	0.6 ± 0.2	2016-12-17
7824273	1504	2016-12-12 @ 9:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17
7824263	1518	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	0.5 ± 0.2	2016-12-17
7824270	LIBRARY COMPUTER	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	0.6 ± 0.2	2016-12-17
7824264	RESOURCE	2016-12-12 @ 10:00 am	2016-12-15 @ 7:00 am	< 0.3	2016-12-17

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

NEW MILFORD HIGH SCHOOL 1st FLOOR PLAN

CHARLES BANNAK
KYLE BIRD
MATT MCLAGHLAN
CLASS OF 2009



Resources
Computer Lab