

JIMMY NEIL ANDERSON

Registered Architect Sustainable Design Construction Administrator

1 Anderson Trail Clifton, TN 38425

(731) 394-6565 www.jnanderson.com

16 September 2023

Mr. Reza Kheshti
Department of Commerce and Insurance
Fire Protection Division
TN State Fire Marshall's Office
Codes Enforcement and Plans Review Section
Davy Crockett Tower-9th Floor
500 James Robertson Parkway
Nashville, TN 37243-0565

RE: Wayne County Board of Education
FHS-CTE (Dollar General Building) Renovation
TFM# 03387-C Project #2023-07-03-01
506 Main Street
Clifton, TN 38425

Dear Mr. Kheshti:

It has become necessary to issue Revision #3 to the above referenced project as a response to Bidder's questions. This document will be referred to as Bid Addendum #1.

Bid Addendum #1

Item 1. The new Fire Hydrant shown on Sheet AS is being installed by the City of Clifton and the Wayne County Department of Education. It is not in contract.

Item 2. The new asphalt driveway shown on Sheet AS is to be included in the contract. There is a satisfactory gravel base existing. Therefore, install only a 2" thickness asphalt layer, 12 feet wide as indicated. Note that the new asphalt should match the elevation of the existing concrete slab out of door #13 at it's location.

Item 3. Air compressor and drops, dust collection system and drops, as well as the electric power cord system and drops will be purchased and installed by the Owner. Any electrical j-boxes shown are to be by Contractor.

Page 2. FHS-CTE Bid Addendum #1

Item 4. There are no known or recognizable sources of asbestos in this project , however no testing has been done.

Item 5. Please see attached partial Sheet A1.1: Door #6,13 & 15 are Type C. Due to recent damage of the existing storefront door please include in the bid two new 42" wide doors and specified hardware as described under Door 0 in Door Type A, new aluminum storefront doors to fit within the existing frame system.




Item 6. Please see attached partial Sheet A1.1: Window "A" design standard or equal to be similar to manufacturer Ply-Gem series 3700 with associated opening, glazing and frame specifications.

End of bid Addendum #1.



Jimmy Neil Anderson, Registered Architect 13,635

DOOR & WINDOW TYPES



Wayne County Board of Education

FHS-CTE Classrooms TFM # 03387-C
 PROJ# 2023-07-03-01

Frank Hughes School- Clifton, TN

