



120 East Davis Street
Fayette, MO 65248-1405
(660) 248-1911
www.inovatia.com

Date: 7/1/2024

RE: Drinking Water Lead Analysis
Facility: Lincoln R-II

Date Received: 06/03/24
Time Received: 10:45
Relinquished by: Angie Moore
Sampler: Bob Franklin

Chain of Custody Number: Pb-0246

Enclosed please find results for the sample(s) received as described above. The values reported are in conformance with internal and method quality control guidelines.

If you have questions or need more information, please contact us.

Thank you for your interest in working with Inovatia Laboratories.

Sincerely,

A handwritten signature in black ink that reads "Jennifer Vandelight". The signature is written in a cursive, flowing style.

Jennifer Vandelight
Quality Assurance

Note: Testing Performed by NELAC Facility E87688

Enclosures:
Chain of Custody Record(s)



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0246
Facility: Lincoln R-II

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0246-001	LINC-HS-OLD-BOIL-HS-MTP-PS-001	5/29/2024	Draw	ND	1.0
Pb-0246-002	LINC-HS-GLKR-RRFG-PS-002	5/29/2024	Draw	ND	1.0
Pb-0246-003	LINC-HS-BLKR-RRFB-PS-003	5/29/2024	Draw	ND	1.0
Pb-0246-004	LINC-HS-BLKR-DF-PS-004	5/29/2024	Draw	ND	1.0
Pb-0246-005	LINC-HS-GYM-DF-PS-005	5/29/2024	Draw	ND	1.0
Pb-0246-006	LINC-HS-GYM-DW PS-006	5/29/2024	Draw	ND	1.0
Pb-0246-007	LINC-BBALL-CONC-FP PS-007	5/29/2024	Draw	2.68	1.0
Pb-0246-008	LINC-HS-OFF-RRFG PS-008	5/29/2024	Draw	ND	1.0
Pb-0246-009	LINC-HS-OFF-RRFB PS-009	5/29/2024	Draw	1.12	1.0
Pb-0246-010	LINC-HS-FRNT-HALL-RRFGR PS-010	5/29/2024	Draw	3.33	1.0
Pb-0246-011	LINC-HS-FRNT-HALL-RRFGL PS-011	5/29/2024	Draw	ND	1.0
Pb-0246-012	LINC-HS-FRNT-HALL-RRFBR PS-012	5/29/2024	Draw	ND	1.0
Pb-0246-013	LINC-HS-FRNT-HALL-RRFBL PS-013	5/29/2024	Draw	1.70	1.0
Pb-0246-014	LINC-HS-FRNT-HALL-DF PS-014	5/29/2024	Draw	ND	1.0
Pb-0246-015	LINC-HS-FRNT-HALL-DW PS-015	5/29/2024	Draw	ND	1.0
Pb-0246-016	LINC-HS-RM1-HOME-FPR PS-016	5/29/2024	Draw	8.42	1.0
Pb-0246-017	LINC-HS-RM1-HOME-FPR-SC PS-017	5/29/2024	Draw	ND	1.0
Pb-0246-018	LINC-HS-RM1-HOME-FPM PS-018	5/29/2024	Draw	1.26	1.0
Pb-0246-019	LINC-HS-RM1-HOME-FPL PS-019	5/29/2024	Draw	2.01	1.0
Pb-0246-020	LINC-HS-RM1-HOME-FPL-SC PS-020	5/29/2024	Draw	1.58	1.0
Pb-0246-021	LINC-HS-RM2-LIB-FP PS-021	5/29/2024	Draw	ND	1.0
Pb-0246-022	LINC-HS-5HALL-DW PS-022	5/29/2024	Draw	ND	1.0
Pb-0246-023	LINC-HS-5HALL-DF PS-023	NO SAMPLE/NOT WORKING			
Pb-0246-024	LINC-HS-RM6-SCI-FRT-HSL PS-024	5/29/2024	Draw	6.00	1.0
Pb-0246-025	LINC-HS-RM6-SCI-MID-HSR PS-025	5/29/2024	Draw	25.4	1.0
Pb-0246-026	LINC-HS-RM6-SCI-MID-HSL PS-026	5/29/2024	Draw	1.32	1.0
Pb-0246-027	LINC-HS-RM6-SCI-BACK-HS PS-027	5/29/2024	Draw	2.25	1.0
Pb-0246-028	LINC-HS-RM7-SCI-HS PS-028	5/29/2024	Draw	9.47	1.0
Pb-0246-029	LINC-HS-RM8-BAND-STOR-HS PS-029	5/29/2024	Draw	1.15	1.0
Pb-0246-030	LINC-JR-RM12-AG-FP PS-030	5/29/2024	Draw	ND	1.0
Pb-0246-031	LINC-JR-RM12-AG-FP-SC PS-031	5/29/2024	Draw	ND	1.0
Pb-0246-032	LINC-JR-AGHALL-DF PS-032	5/29/2024	Draw	ND	1.0
Pb-0246-033	LINC-JR-AGHALL-DW PS-033	5/29/2024	Draw	ND	1.0
Pb-0246-034	LINC-JR-18HALL-DF PS-034	5/29/2024	Draw	ND	1.0
Pb-0246-035	LINC-JR-18HALL-DW PS-035	5/29/2024	Draw	ND	1.0
Pb-0246-036	LINC-NRS-RRF PS-036	5/29/2024	Draw	ND	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0246
Facility: Lincoln R-II

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0246-037	LINC-CAFÉ-IM PS-037	5/29/2024	Draw	ND	1.0
Pb-0246-038	LINC-CAFÉ-DW PS-038	5/29/2024	Draw	ND	1.0
Pb-0246-039	LINC-KITCH-DSHR PS-039	5/29/2024	Draw	ND	1.0
Pb-0246-040	LINC-KITCH-DSHL PS-040	5/29/2024	Draw	1.29	1.0
Pb-0246-041	LINC-KITCH-FP PS-041	5/29/2024	Draw	2.30	1.0
Pb-0246-042	LINC-KITCH-SC PS-042	5/29/2024	Draw	21.5	1.0
Pb-0246-043	LINC-KITCH-RRF PS-043	5/29/2024	Draw	2.10	1.0
Pb-0246-044	LINC-ELM-51HALL-RRFGR PS-044	5/29/2024	Draw	ND	1.0
Pb-0246-045	LINC-ELM-51HALL-RRFGL PS-045	5/29/2024	Draw	ND	1.0
Pb-0246-046	LINC-ELM-51HALL-RRFBR PS-046	5/29/2024	Draw	ND	1.0
Pb-0246-047	LINC-ELM-51HALL-RRFBL PS-047	5/29/2024	Draw	ND	1.0
Pb-0246-048	LINC-ELM-53HALL-DF PS-048	5/29/2024	Draw	ND	1.0
Pb-0246-049	LINC-ELM-RM24-HSR PS-049	5/29/2024	Draw	ND	1.0
Pb-0246-050	LINC-ELM-RM24-HSL PS-050	5/29/2024	Draw	1.62	1.0
Pb-0246-051	LINC-ELM-24HALL-DW PS-051	5/29/2024	Draw	ND	1.0
Pb-0246-052	LINC-LIFE-RM25-FP PS-052	5/29/2024	Draw	ND	1.0
Pb-0246-053	LINC-LIFE-RM25-RRF PS-053	5/29/2024	Draw	ND	1.0
Pb-0246-054	LINC-ELM-24HALL-DF PS-054	NO SAMPLE/NOT WORKING			
Pb-0246-055	LINC-BSMT-WEIGHT-DW PS-055	5/29/2024	Draw	ND	1.0
Pb-0246-056	LINC-BSMT-WEIGHT-RRF PS-056	5/29/2024	Draw	4.56	1.0
Pb-0246-057	LINC-WEIGHT-DF PS-057	5/29/2024	Draw	ND	1.0
Pb-0246-058	LINC-ELM-4TH/6TH-RRFM PS-058	5/29/2024	Draw	2.86	1.0
Pb-0246-059	LINC-ELM-4TH/6TH-RRFL PS-059	5/29/2024	Draw	2.75	1.0
Pb-0246-060	LINC-ELM-4TH/6TH-JAN-FP PS-060	5/29/2024	Draw	ND	1.0
Pb-0246-061	LINC-ELM-26HALL-DF PS-061	5/29/2024	Draw	ND	1.0
Pb-0246-062	LINC-ELM-26HALL-DW PS-062	5/29/2024	Draw	1.08	1.0
Pb-0246-063	LINC-ELM-RM26-MUSIC-HS PS-063	5/29/2024	Draw	44.0	1.0
Pb-0246-064	LINC-ELM-LIB-HS PS-064	5/29/2024	Draw	30.8	1.0
Pb-0246-065	LINC-ELM-RM28-HS PS-065	5/29/2024	Draw	22.4	1.0
Pb-0246-066	LINC-ELM-RM29-HS PS-066	5/29/2024	Draw	46.0	1.0
Pb-0246-067	LINC-ELM-29HALL-DF PS-067	5/29/2024	Draw	ND	1.0
Pb-0246-068	LINC-ELM-29HALL-DW PS-068	5/29/2024	Draw	1.19	1.0
Pb-0246-069	LINC-ELM-RM30-HS PS-069	5/29/2024	Draw	17.8	1.0
Pb-0246-070	LINC-ELM-RM31-HS PS-070	5/29/2024	Draw	26.5	1.0
Pb-0246-071	LINC-ELM-RM32-HS PS-071	5/29/2024	Draw	16.2	1.0
Pb-0246-072	LINC-ELM-RM33-HS PS-072	5/29/2024	Draw	21.0	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0246
Facility: Lincoln R-II

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0246-073	LINC-ELM-27HALL-DFR PS-073	5/29/2024	Draw	ND	1.0
Pb-0246-074	LINC-ELM-27HALL-DFL PS-074	5/29/2024	Draw	ND	1.0
Pb-0246-075	LINC-ELM-27HALL-DW PS-075	5/29/2024	Draw	ND	1.0
Pb-0246-076	LINC-ELM-27HALL-RRFR PS-076	5/29/2024	Draw	1.66	1.0
Pb-0246-077	LINC-ELM-27HALL-RRFM PS-077	5/29/2024	Draw	1.94	1.0
Pb-0246-078	LINC-ELM-27HALL-RRFL PS-078	5/29/2024	Draw	2.06	1.0
Pb-0246-079	LINC-ELM-RM34-HS PS-079	5/29/2024	Draw	14.2	1.0
Pb-0246-080	LINC-ELM-RM34-RRF PS-080	5/29/2024	Draw	3.80	1.0
Pb-0246-081	LINC-ELM-RM35-HS PS-081	5/29/2024	Draw	8.50	1.0
Pb-0246-082	LINC-ELM-RM35-RRF PS-082	5/29/2024	Draw	2.08	1.0
Pb-0246-083	LINC-ELM-RM36-HS PS-083	5/29/2024	Draw	21.7	1.0
Pb-0246-084	LINC-ELM-RM36-RRF PS-084	5/29/2024	Draw	19.5	1.0
Pb-0246-085	LINC-ELM-RM37-HS PS-085	5/29/2024	Draw	9.27	1.0
Pb-0246-086	LINC-ELM-RM37-RRF PS-086	5/29/2024	Draw	5.26	1.0
Pb-0246-087	LINC-ELM-RM38-HS PS-087	5/29/2024	Draw	4.96	1.0
Pb-0246-088	LINC-ELM-RM39-HS PS-088	5/29/2024	Draw	8.08	1.0
Pb-0246-089	LINC-ELM-39HALL-DFR PS-089	5/29/2024	Draw	1.13	1.0
Pb-0246-090	LINC-ELM-39HALL-DFL PS-090	5/29/2024	Draw	1.81	1.0
Pb-0246-091	LINC-ELM-39HALL-DW PS-091	5/29/2024	Draw	1.11	1.0
Pb-0246-092	LINC-ELM-RM40-HS PS-092	5/29/2024	Draw	19.1	1.0
Pb-0246-093	LINC-ELM-RM41-HS PS-093	5/29/2024	Draw	12.5	1.0
Pb-0246-094	LINC-ELM-RM42-HS PS-094	5/29/2024	Draw	1.55	1.0
Pb-0246-095	LINC-ELM-RM43-HS PS-095	5/29/2024	Draw	13.8	1.0
Pb-0246-096	LINC-NEW-STOR-VLV-MTP PS-096	5/29/2024	Draw	3.33	1.0
Pb-0246-097	LINC-NEW-STOR-HALL-RRF PS-097	5/29/2024	Draw	3.79	1.0
Pb-0246-098	LINC-NEW-ART-WALL-HSR PS-098	5/29/2024	Draw	2.07	1.0
Pb-0246-099	LINC-NEW-ART-WALL-HSM PS-099	5/29/2024	Draw	2.17	1.0
Pb-0246-100	LINC-NEW-ART-WALL-HSL PS-100	5/29/2024	Draw	3.75	1.0
Pb-0246-101	LINC-NEW-ART-KILN-HS PS-101	5/29/2024	Draw	2.28	1.0
Pb-0246-102	LINC-NEW-WEIGHT-DF PS-102	5/29/2024	Draw	ND	1.0
Pb-0246-103	LINC-NEW-WEIGHT-DW PS-103	5/29/2024	Draw	ND	1.0
Pb-0246-104	LINC-NEW-RM103-CONC-IM PS-104	5/29/2024	Draw	ND	1.0
Pb-0246-105	LINC-NEW-RM103-CONC-FP PS-105	5/29/2024	Draw	ND	1.0
Pb-0246-106	LINC-NEW-RM103-CONC-SC PS-106	5/29/2024	Draw	1.85	1.0
Pb-0246-107	LINC-NEW-LEFT-RRFGR PS-107	5/29/2024	Draw	2.06	1.0
Pb-0246-108	LINC-NEW-LEFT-RRFGM PS-108	5/29/2024	Draw	1.21	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0246
Facility: Lincoln R-II

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0246-109	LINC-NEW-LEFT-RRFGL PS-109	5/29/2024	Draw	1.58	1.0
Pb-0246-110	LINC-NEW-RIGHT-RRFBR PS-110	5/29/2024	Draw	2.57	1.0
Pb-0246-111	LINC-NEW-RIGHT-RRFBM PS-111	5/29/2024	Draw	ND	1.0
Pb-0246-112	LINC-NEW-RIGHT-RRFBL PS-112	5/29/2024	Draw	1.24	1.0
Pb-0246-113	LINC-NEW-RM107-PREK-HS PS-113	5/29/2024	Draw	ND	1.0
Pb-0246-114	LINC-NEW-RM107-PREK-RRF PS-114	5/29/2024	Draw	ND	1.0
Pb-0246-115	LINC-FBFLD-SOUTH-HYD PS-115	NO SAMPLE/DUPLICATE			
Pb-0246-116	LINC-FBFLD-SOUTH-HYD-MTP PS-116	5/29/2024	Draw	ND	1.0
Pb-0246-117	LINC-FBLKR-VAR-RRFB PS-117	5/29/2024	Draw	1.68	1.0
Pb-0246-118	LINC-FBLKR-JRH-RRFB PS-118	5/29/2024	Draw	2.89	1.0
Pb-0246-119	LINC-FBCONC-FP PS-119	5/29/2024	Draw	ND	1.0
Pb-0246-120	LINC-FBCONC-HOT-CHOC-RT PS-120	5/29/2024	Draw	ND	1.0
Pb-0246-121	LINC-FBCONC-HOT-CHOC-LFT PS-121	5/29/2024	Draw	ND	1.0
Pb-0246-122	LINC-FBCONC-HALL-RRF PS-122	5/29/2024	Draw	1.74	1.0
Pb-0246-123	LINC-FB-BLCHRS-HYD PS-123	5/29/2024	Draw	ND	1.0
Pb-0246-124	LINC-FB-BLCHRS-RRFGR PS-124	5/29/2024	Draw	ND	1.0
Pb-0246-125	LINC-FB-BLCHRS-RRFGL PS-125	5/29/2024	Draw	2.10	1.0
Pb-0246-126	LINC-FB-BLCHRS-RRFBR PS-126	5/29/2024	Draw	3.09	1.0
Pb-0246-127	LINC-FB-BLCHRS-RRFBL PS-127	5/29/2024	Draw	ND	1.0
Pb-0246-128	LINC-BASK-CONC-FP-SC PS-128	5/29/2024	Draw	19.6	1.0
Pb-0246-129	LINC-RM6-SCI-MID-ISL-HSR PS-129	5/29/2024	Draw	1.54	1.0
Pb-0246-130	LINC-ELM-4TH/6TH-RRFR PS-130	5/29/2024	Draw	2.60	1.0
Pb-0246-131	LINC-NEW-DFR PS-131	5/29/2024	Draw	ND	1.0
Pb-0246-132	LINC-NEW-DFL PS-132	5/29/2024	Draw	ND	1.0
Pb-0246-133	LINC-NEW-DW PS-133	5/29/2024	Draw	ND	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



120 East Davis Street
 Fayette, MO 65248-1405
 (660) 248-1911
 www.inovatia.com

Contact Name: Bob Franklin
 Company Name: Get the Lead Out LLC
 Address: PO Box 118
 City,State,zip: Sturgeon, MO 65284
 Phone Number: 417-294-6112
 E-Mail: bobfranklin@gettheleadoutmo.us

Matrix: Water
 Grab/Composite: Grab
 Number of Containers: 130
 Preservation: HNO3
 Chain of Custody: Pb-0246

Facility: Lincoln R-II
 Facility Address: 101 W Lamine St. #39 Lincoln, MO 65338
 Facility Contact: Mr. Kevin J Smith

Lab Number	Customer Sample Number	Date Collected
1 Pb-0246-001	LINC-HS-OLD-BOIL-HS-MTP-PS-001	5/29/2024
2 Pb-0246-002	LINC-HS-GLKR-RRFG-PS-002	5/29/2024
3 Pb-0246-003	LINC-HS-BLKR-RRFB-PS-003	5/29/2024
4 Pb-0246-004	LINC-HS-BLKR-DF-PS-004	5/29/2024
5 Pb-0246-005	LINC-HS-GYM-DF-PS-005	5/29/2024
6 Pb-0246-006	LINC-HS-GYM-DW PS-006	5/29/2024
7 Pb-0246-007	LINC-BBALL-CONC-FP PS-007	5/29/2024
8 Pb-0246-008	LINC-HS-OFF-RRFG PS-008	5/29/2024
9 Pb-0246-009	LINC-HS-OFF-RRFB PS-009	5/29/2024
10 Pb-0246-010	LINC-HS-FRNT-HALL-RRFGR PS-010	5/29/2024
11 Pb-0246-011	LINC-HS-FRNT-HALL-RRFGL PS-011	5/29/2024
12 Pb-0246-012	LINC-HS-FRNT-HALL-RRFBR PS-012	5/29/2024
13 Pb-0246-013	LINC-HS-FRNT-HALL-RRFBL PS-013	5/29/2024
14 Pb-0246-014	LINC-HS-FRNT-HALL-DF PS-014	5/29/2024
15 Pb-0246-015	LINC-HS-FRNT-HALL-DW PS-015	5/29/2024
16 Pb-0246-016	LINC-HS-RM1-HOME-FPR PS-016	5/29/2024
17 Pb-0246-017	LINC-HS-RM1-HOME-FPR-SC PS-017	5/29/2024
18 Pb-0246-018	LINC-HS-RM1-HOME-FPM PS-018	5/29/2024
19 Pb-0246-019	LINC-HS-RM1-HOME-FPL PS-019	5/29/2024
20 Pb-0246-020	LINC-HS-RM1-HOME-FPL-SC PS-020	5/29/2024
21 Pb-0246-021	LINC-HS-RM2-LIB-FP PS-021	5/29/2024
22 Pb-0246-022	LINC-HS-5HALL-DW PS-022	5/29/2024
23 Pb-0246-023	LINC-HS-5HALL-DF PS-023	NO SAMPLE/NOT WORKING
24 Pb-0246-024	LINC-HS-RM6-SCI-FRT-HSL PS-024	5/29/2024
25 Pb-0246-025	LINC-HS-RM6-SCI-MID-HSR PS-025	5/29/2024
26 Pb-0246-026	LINC-HS-RM6-SCI-MID-HSL PS-026	5/29/2024
27 Pb-0246-027	LINC-HS-RM6-SCI-BACK-HS PS-027	5/29/2024

28	Pb-0246-028	LINC-HS-RM7-SCI-HS PS-028	5/29/2024
29	Pb-0246-029	LINC-HS-RM8-BAND-STOR-HS PS-029	5/29/2024
30	Pb-0246-030	LINC-JR-RM12-AG-FP PS-030	5/29/2024
31	Pb-0246-031	LINC-JR-RM12-AG-FP-SC PS-031	5/29/2024
32	Pb-0246-032	LINC-JR-AGHALL-DF PS-032	5/29/2024
33	Pb-0246-033	LINC-JR-AGHALL-DW PS-033	5/29/2024
34	Pb-0246-034	LINC-JR-18HALL-DF PS-034	5/29/2024
35	Pb-0246-035	LINC-JR-18HALL-DW PS-035	5/29/2024
36	Pb-0246-036	LINC-NRS-RRF PS-036	5/29/2024
37	Pb-0246-037	LINC-CAFÉ-IM PS-037	5/29/2024
38	Pb-0246-038	LINC-CAFÉ-DW PS-038	5/29/2024
39	Pb-0246-039	LINC-KITCH-DSHR PS-039	5/29/2024
40	Pb-0246-040	LINC-KITCH-DSHL PS-040	5/29/2024
41	Pb-0246-041	LINC-KITCH-FP PS-041	5/29/2024
42	Pb-0246-042	LINC-KITCH-SC PS-042	5/29/2024
43	Pb-0246-043	LINC-KITCH-RRF PS-043	5/29/2024
44	Pb-0246-044	LINC-ELM-51HALL-RRFGR PS-044	5/29/2024
45	Pb-0246-045	LINC-ELM-51HALL-RRFGL PS-045	5/29/2024
46	Pb-0246-046	LINC-ELM-51HALL-RRFBR PS-046	5/29/2024
47	Pb-0246-047	LINC-ELM-51HALL-RRFBL PS-047	5/29/2024
48	Pb-0246-048	LINC-ELM-53HALL-DF PS-048	5/29/2024
49	Pb-0246-049	LINC-ELM-RM24-HSR PS-049	5/29/2024
50	Pb-0246-050	LINC-ELM-RM24-HSL PS-050	5/29/2024
51	Pb-0246-051	LINC-ELM-24HALL-DW PS-051	5/29/2024
52	Pb-0246-052	LINC-LIFE-RM25-FP PS-052	5/29/2024
53	Pb-0246-053	LINC-LIFE-RM25-RRF PS-053	5/29/2024
54	Pb-0246-054	LINC-ELM-24HALL-DF PS-054	NO SAMPLE/NOT WORKING
55	Pb-0246-055	LINC-BSMT-WEIGHT-DW PS-055	5/29/2024
56	Pb-0246-056	LINC-BSMT-WEIGHT-RRF PS-056	5/29/2024
57	Pb-0246-057	LINC-WEIGHT-DF PS-057	5/29/2024
58	Pb-0246-058	LINC-ELM-4TH/6TH-RRFM PS-058	5/29/2024
59	Pb-0246-059	LINC-ELM-4TH/6TH-RRFL PS-059	5/29/2024
60	Pb-0246-060	LINC-ELM-4TH/6TH-JAN-FP PS-060	5/29/2024
61	Pb-0246-061	LINC-ELM-26HALL-DF PS-061	5/29/2024
62	Pb-0246-062	LINC-ELM-26HALL-DW PS-062	5/29/2024
63	Pb-0246-063	LINC-ELM-RM26-MUSIC-HS PS-063	5/29/2024
64	Pb-0246-064	LINC-ELM-LIB-HS PS-064	5/29/2024
65	Pb-0246-065	LINC-ELM-RM28-HS PS-065	5/29/2024
66	Pb-0246-066	LINC-ELM-RM29-HS PS-066	5/29/2024

67	Pb-0246-067	LINC-ELM-29HALL-DF PS-067	5/29/2024
68	Pb-0246-068	LINC-ELM-29HALL-DW PS-068	5/29/2024
69	Pb-0246-069	LINC-ELM-RM30-HS PS-069	5/29/2024
70	Pb-0246-070	LINC-ELM-RM31-HS PS-070	5/29/2024
71	Pb-0246-071	LINC-ELM-RM32-HS PS-071	5/29/2024
72	Pb-0246-072	LINC-ELM-RM33-HS PS-072	5/29/2024
73	Pb-0246-073	LINC-ELM-27HALL-DFR PS-073	5/29/2024
74	Pb-0246-074	LINC-ELM-27HALL-DFL PS-074	5/29/2024
75	Pb-0246-075	LINC-ELM-27HALL-DW PS-075	5/29/2024
76	Pb-0246-076	LINC-ELM-27HALL-RRFR PS-076	5/29/2024
77	Pb-0246-077	LINC-ELM-27HALL-RRFM PS-077	5/29/2024
78	Pb-0246-078	LINC-ELM-27HALL-RRFL PS-078	5/29/2024
79	Pb-0246-079	LINC-ELM-RM34-HS PS-079	5/29/2024
80	Pb-0246-080	LINC-ELM-RM34-RRF PS-080	5/29/2024
81	Pb-0246-081	LINC-ELM-RM35-HS PS-081	5/29/2024
82	Pb-0246-082	LINC-ELM-RM35-RRF PS-082	5/29/2024
83	Pb-0246-083	LINC-ELM-RM36-HS PS-083	5/29/2024
84	Pb-0246-084	LINC-ELM-RM36-RRF PS-084	5/29/2024
85	Pb-0246-085	LINC-ELM-RM37-HS PS-085	5/29/2024
86	Pb-0246-086	LINC-ELM-RM37-RRF PS-086	5/29/2024
87	Pb-0246-087	LINC-ELM-RM38-HS PS-087	5/29/2024
88	Pb-0246-088	LINC-ELM-RM39-HS PS-088	5/29/2024
89	Pb-0246-089	LINC-ELM-39HALL-DFR PS-089	5/29/2024
90	Pb-0246-090	LINC-ELM-39HALL-DFL PS-090	5/29/2024
91	Pb-0246-091	LINC-ELM-39HALL-DW PS-091	5/29/2024
92	Pb-0246-092	LINC-ELM-RM40-HS PS-092	5/29/2024
93	Pb-0246-093	LINC-ELM-RM41-HS PS-093	5/29/2024
94	Pb-0246-094	LINC-ELM-RM42-HS PS-094	5/29/2024
95	Pb-0246-095	LINC-ELM-RM43-HS PS-095	5/29/2024
96	Pb-0246-096	LINC-NEW-STOR-VLV-MTP PS-096	5/29/2024
97	Pb-0246-097	LINC-NEW-STOR-HALL-RRF PS-097	5/29/2024
98	Pb-0246-098	LINC-NEW-ART-WALL-HSR PS-098	5/29/2024
99	Pb-0246-099	LINC-NEW-ART-WALL-HSM PS-099	5/29/2024
100	Pb-0246-100	LINC-NEW-ART-WALL-HSL PS-100	5/29/2024
101	Pb-0246-101	LINC-NEW-ART-KILN-HS PS-101	5/29/2024
102	Pb-0246-102	LINC-NEW-WEIGHT-DF PS-102	5/29/2024
103	Pb-0246-103	LINC-NEW-WEIGHT-DW PS-103	5/29/2024
104	Pb-0246-104	LINC-NEW-RM103-CONC-IM PS-104	5/29/2024
105	Pb-0246-105	LINC-NEW-RM103-CONC-FP PS-105	5/29/2024

