

October 3, 2023

Mr. Henry Ilges  
Jennings School District  
2559 Dorwood Drive  
Jennings, MO 64136

**RE: Drinking Water Sampling – Hanrahan Elementary School**  
8430 Lucas and Hunt Rd  
St. Louis, MO 63136  
**Project Number: 923235**

Mr. Ilges,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Hanrahan Elementary School in Jennings, Missouri. The sampling was requested and approved by Mr. Henry Ilges of Jennings School District (JSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

#### **METHODOLOGY**

On August 9, 2023, Mr. Jeff Smith and Mr. Nathaniel Jones of OCCU-TEC completed testing of twenty-nine (29) sources throughout Hanrahan Elementary School. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of 8 hours. Samples were collected in dedicated, laboratory-provided 250-milliliter plastic sample containers. Sample location information and photographic documentation are noted in the attached table.

Samples were shipped to Teklab, Inc. (Teklab) of Collinsville, Illinois for analysis using EPA method 200.8. Teklab is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification number 00930. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

## RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, eleven (11) of the twenty-nine (29) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
235-HRH-01	Art Room	Art Room Sink	50.3
235-HRH-06	1 <sup>st</sup> Floor North Girls' RR	Restroom Sink	5.8
235-HRH-11	Kitchen	Serving Station Faucet	70
235-HRH-12	Kitchen	Kitchen Dish Sprayer	77.2
235-HRH-15	Kitchen	Kitchen Fryer Filler	107
235-HRH-17	Kitchen	Hand Washing Sink	13.5
235-HRH-22	Gym Office	Office Sink	577
235-HRH-28	2 <sup>nd</sup> Floor South Boys' RR	Restroom Sink	15.9
235-HRH-29	2 <sup>nd</sup> Floor South Girls' RR	Restroom Sink	59.6
235-HRH-31	2 <sup>nd</sup> Floor South Girls' RR	Restroom Sink	45.1
235-HRH-32	2 <sup>nd</sup> Floor South Girls' RR	Restroom Sink	119

## LIMITATIONS

At the request of JSD, janitorial closet sinks were excluded from sampling. OCCU-TEC recommends placing signage on all sources not sampled during this assessment that indicate the source is not to be used for drinking water.

## RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662.

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school

shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:


- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25-percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

**SIGNATURE(S)**

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to the JSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Nathaniel Jones  
Environmental Technician




Jeff Smith  
Senior Project Manager (QA/QC)


**ATTACHMENTS**


Outlet Inventory with Analytical Results Summary  
Laboratory Analytical Results and COC Documentation

**ATTACHMENT 1**  
**OUTLET INVENTORY WITH ANALYTICAL RESULTS SUMMARY**


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-01	Location:	W100 Restrooms	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-02	Location:	W100 Restrooms	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-03	Location:	W100 Men's Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 1 (Rightmost Unit, Non-Functional)		
		Result:	N/A	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-04	Location:	W100 Boys' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 2		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-05	Location:	W100 Boys' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 3		
		Result:	1.9	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-06	Location:	W100 Boys' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 4 (Leftmost Unit)		
		Result:	<b>16.8</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-07	Location:	W100 Girls' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 1 (Leftmost Unit)		
		Result:	1	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-08	Location:	W100 Girls' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 2 (Non-Functional)		
		Result:	N/A	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-09	Location:	W100 Girls' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 3		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ



Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-10	Location:	W100 Girls' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink 4 (Rightmost Unit)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-11	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Kitchen Dish Sprayer with Disposal (Out of Order)		
		Result:	N/A	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-12	Location:	Kitchen	
Photo:		Manufacturer:	Fisher USA	
		Description:		
		Island Sink		
		Result:	3.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-13	Location:	Kitchen	
Photo:		Manufacturer:	Fisher USA	
		Description:		
		Dish Washing Station Sink, Left Faucet		
		Result:	1.3	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-14	Location:	Kitchen	
Photo:		Manufacturer:	Fisher USA	
		Description:		
		Dish Washing Station Sink, Right Faucet		
		Result:	1.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-15	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink, South Wall		
		Result:	1	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-16	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Kitchen Appliance, Fryer Faucet		
		Result:	3.3	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-17	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Pressure Pot Filler		
		Result:	<b>12.7</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				

ID:	235-JMS-18	Location:	Kitchen	
Photo:		Manufacturer:	Fisher USA	
		Description:		
		West Wall Sink		
		Result:	2.9	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-19	Location:	Kitchen	
Photo:		Manufacturer:	UPC	
		Description:		
		Back Hall Hand Washing Sink		
		Result:	2.1	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-20	Location:	Kitchen	
Photo:		Manufacturer:	Manitowoc	
		Description:		
		Ice Machine		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-21	Location:	Kitchen Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink		
		Result:	1.1	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-22	Location:	S100 Hall
Photo:		Manufacturer:	Elkay
		Description:	
		Drinking Fountain Bottle Filler	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ


ID:	235-JMS-23	Location:	S100 Hall
Photo:		Manufacturer:	Elkay
		Description:	
		Drinking Fountain Bottle Filler	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ


ID:	235-JMS-24	Location:	S105 Lab
Photo:		Manufacturer:	Moen
		Description:	
		Lab Sink, Teacher Desk (Non-Functional)	
		Result:	N/A
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-25	Location:	S105 Lab
Photo:		Manufacturer:	Moen
		Description:	
		South Wall Lab Sink with Eyewash Station, Left	
		Result:	<b>11.1</b>
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>	
		Date Sampled:	8/10/2023 By: NJ


ID:	235-JMS-26	Location:	S105 Lab
Photo:		Manufacturer:	Moen
		Description:	
		South Wall Lab Sink, Center (Non-Functional)	
		Result:	<b>N/A</b>
Recommended Action:			
		Date Sampled:	8/10/2023 By: NJ

ID:	235-JMS-27	Location:	S105 Lab
Photo:		Manufacturer:	Moen
		Description:	
		South Wall Lab Sink, Right	
		Result:	<b>26.2</b>
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>	
		Date Sampled:	8/10/2023 By: NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-28	Location:	S105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Left		
		Result:	4.7	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-29	Location:	S105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Center		
		Result:	4.6	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-30	Location:	S105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Right		
		Result:	<b>7.7</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-31	Location:	S108, Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Left		
		Result:	2.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-32	Location:	S108, Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Center (Low Flow, not Sampled)		
		Result:	N/A	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-33	Location:	S108, Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Right		
		Result:	2.3	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-34	Location:	S109 Boys' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Right		
		Result:	1.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-35	Location:	S109 Boys' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Center		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-36	Location:	S109 Boys' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Left		
		Result:	<b>9.4</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-37	Location:	S104	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Classroom Sink, Left (Non-Functional)		
		Result:	N/A	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				


ID:	235-JMS-38	Location:	S104	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		Classroom Sink, Center (Non-Functional)		
		Result:	N/A	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				

ID:	235-JMS-39	Location:	S104	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		Classroom Sink, Right (Non-Functional)		
		Result:	N/A	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-40	Location:	Outside Gym
Photo:		Manufacturer:	Elkay
		Description:	
		Drinking Fountain Bottle Filler	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ


ID:	235-JMS-41	Location:	Outside Gym
Photo:		Manufacturer:	Elkay
		Description:	
		Drinking Fountain Bubbler	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ

ID:	235-JMS-42	Location:	Gym Girls' Restroom
Photo:		Manufacturer:	American Standard
		Description:	
		Restroom Sink, Left Side, Left Unit	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-43	Location:	Gym Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Left Side, Right Unit		
		Result:	1.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-44	Location:	Gym Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Right Side, Left Unit		
		Result:	N/A	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-45	Location:	Gym Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Right Side, Center Unit		
		Result:	5.4	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				



Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-46	Location:	Gym Girls' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink, Right Side, Right Unit		
		Result:	1.4	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-47	Location:	S113 Boys' Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Restroom Sink, Left		
		Result:	4.1	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-48	Location:	S113 Boys' Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Restroom Sink, Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-49	Location:	S114 Girls' Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Restroom Sink, Left		
		Result:	3.5	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-50	Location:	S114 Girls' Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		Restroom Sink, Right		
		Result:	<b>11.5</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				

ID:	235-JMS-51	Location:	M110 Nurse's Office	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		Restroom Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-52	Location:	M103 Music Hall
Photo:		Manufacturer:	Unknown
		Description:	
		Kitchenette Sink, Left	
		Result:	<b>8.1</b>
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>	
Date Sampled:		8/10/2023	By: NJ


ID:	235-JMS-53	Location:	M103 Music Hall
Photo:		Manufacturer:	Unknown
		Description:	
		Kitchenette Sink, Right	
		Result:	<b>29.5</b>
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>	
Date Sampled:		8/10/2023	By: NJ

ID:	235-JMS-54	Location:	M203 FACS
Photo:		Manufacturer:	Delta
		Description:	
		South Station 1 (South Sink)	
		Result:	<1.0
Recommended Action:			
Date Sampled:		8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-55	Location:	M203 FACS
Photo:		Manufacturer:	Delta
		Description:	
		South Station 2 (North Sink)	
		Result:	1.4
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ


ID:	235-JMS-56	Location:	M203 FACS
Photo:		Manufacturer:	Delta
		Description:	
		North Station 1 (South Sink)	
		Result:	1.2
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ

ID:	235-JMS-57	Location:	M203 FACS
Photo:		Manufacturer:	Delta
		Description:	
		North Station 2 (North Sink)	
		Result:	<1.0
Recommended Action:		Date Sampled:	8/10/2023
		By:	NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-58	Location:	M203 FACS	
Photo:		Manufacturer:	Delta	
		Description:		
		Island Sink		
		Result:	2.9	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				


ID:	235-JMS-59	Location:	M 115 Boys' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink 1 (Leftmost Unit)		
		Result:	1.4	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				


ID:	235-JMS-60	Location:	M115 Boys' Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		Restroom Sink 2		
		Result:	<1.0	ppb
		Date Sampled:	8/10/2023	By: NJ
Recommended Action:				




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-61	Location:	M115 Boys' Restroom		
Photo:		Manufacturer:	American Standard		
		Description:			
		Restroom Sink 3			
		Result:	1.5	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ


ID:	235-JMS-62	Location:	M115 Boys' Restroom		
Photo:		Manufacturer:	American Standard		
		Description:			
		Restroom Sink 4			
		Result:	1.6	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ

ID:	235-JMS-63	Location:	M115 Boys' Restroom		
Photo:		Manufacturer:	American Standard		
		Description:			
		Restroom Sink 5			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-64	Location:	M115 Boys' Restroom		
Photo:		Manufacturer:	American Standard		
		Description:			
		Restroom Sink 6 (Rightmost Unit)			
		Result:	1.5	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ


ID:	235-JMS-65	Location:	N104, Main Office		
Photo:		Manufacturer:	Unknown		
		Description:			
		Restroom Sink			
		Result:	4.3	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ


ID:	235-JMS-66	Location:	N112, Library Office		
Photo:		Manufacturer:	Unknown		
		Description:			
		Restroom Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	8/10/2023	By:	NJ




Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-67	Location:	N108 Girls' Restroom	
Photo:		Manufacturer:	Chicago Faucet Co.	
		Description:		
		Restroom Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-68	Location:	N213	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink		
		Result:	3.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-69	Location:	N200 Hallway	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-70	Location:	N200 Hallway	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-71	Location:	N211 Boys' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink, Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-72	Location:	N211 Boys' Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		Restroom Sink, Right		
		Result:	1.7	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-73	Location:	N212 Girls' Restroom	
Photo:		Manufacturer:	Zurn	
		Description:		
		Restroom Sink, Right		
		Result:	3.4	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-74	Location:	N212 Girls' Restroom	
Photo:		Manufacturer:	Zurn	
		Description:		
		Restroom Sink, Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-75	Location:	Maintenance Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		Maintenance Sink		
		Result:	<b>26.4</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District


ID:	235-JMS-76	Location:	N100 Hallway	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-77	Location:	N100 Hallway	
Photo:		Manufacturer:	Elkay	
		Description:		
		Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ


ID:	235-JMS-78	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		South Wall Lab Sink, Left		
		Result:	2.8	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ




Drinking Water Assessment  
Jennings Junior High School  
Jennings School District


ID:	235-JMS-79	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		South Wall Lab Sink, Center		
		Result:	2.2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

ID:	235-JMS-80	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		South Wall Lab Sink, Right		
		Result:	<b>29.3</b>	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ
<b>Replace Fixture/Unit and Resample</b>				

ID:	235-JMS-81	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Left		
		Result:	2	ppb
Recommended Action:		Date Sampled:	8/10/2023	By: NJ

Drinking Water Assessment  
 Jennings Junior High School  
 Jennings School District

ID:	235-JMS-82	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Center		
		Result:	<b>5.5</b>	ppb
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>		
Date Sampled:	8/10/2023	By:	NJ	

ID:	235-JMS-83	Location:	W105 Lab	
Photo:		Manufacturer:	Moen	
		Description:		
		North Wall Lab Sink, Right		
		Result:	<b>7.9</b>	ppb
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>		
Date Sampled:	8/10/2023	By:	NJ	



## **ATTACHMENT 2**

### **LABORATORY ANALYTICAL RESULTS AND COC DOCUMENTATION**

September 25, 2023

Kevin Heriford  
Occu-Tec  
2604 NE Industrial Drive  
Suite 230  
North Kansas, MO 64117  
TEL: (816) 231-5580  
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** 923235 JMS

**WorkOrder:** 23080908

Dear Kevin Heriford:

TEKLAB, INC received 74 samples on 8/11/2023 8:08:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Occu-Tec

**Work Order:** 23080908

**Client Project:** 923235 JMS

**Report Date:** 25-Sep-23

---

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	81
Chain of Custody	Appended

Client: Occu-Tec

Work Order: 23080908

Client Project: 923235 JMS

Report Date: 25-Sep-23

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

**Client:** Occu-Tec

**Work Order:** 23080908

**Client Project:** 923235 JMS

**Report Date:** 25-Sep-23

---

### Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)





## Case Narrative

<http://www.teklabinc.com/>

**Client:** Occu-Tec

**Work Order:** 23080908

**Client Project:** 923235 JMS

**Report Date:** 25-Sep-23

**Cooler Receipt Temp:** NA °C

---

### Locations

---

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

---

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

---

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

---

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

---

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 23080908

Client Project: 923235 JMS

Report Date: 25-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-001  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-01  
Collection Date: 08/10/2023 13:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 14:43	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-002  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-02  
Collection Date: 08/10/2023 13:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 14:46	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-003  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-04  
Collection Date: 08/10/2023 13:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 15:08	211464





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-004  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-05  
Collection Date: 08/10/2023 13:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.9	µg/L	1	09/16/2023 15:12	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-005  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-06  
Collection Date: 08/10/2023 13:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		16.8	µg/L	5	09/21/2023 22:34	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-006  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-07  
Collection Date: 08/10/2023 13:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.0	µg/L	1	09/16/2023 15:16	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-007  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-09  
Collection Date: 08/10/2023 13:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 15:19	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-008  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-10  
Collection Date: 08/10/2023 13:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 15:23	211464





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-009  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-12  
Collection Date: 08/10/2023 13:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.2	µg/L	1	09/16/2023 15:27	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-010  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-13  
Collection Date: 08/10/2023 13:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/16/2023 15:30	211464



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-011  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-14  
Collection Date: 08/10/2023 13:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	09/16/2023 17:35	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-012  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-15  
Collection Date: 08/10/2023 13:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.0	µg/L	1	09/16/2023 17:39	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-013  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-16  
Collection Date: 08/10/2023 13:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.3	µg/L	1	09/16/2023 17:42	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-014  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-17  
Collection Date: 08/10/2023 13:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		12.7	µg/L	5	09/21/2023 22:38	211541





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-015  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-18  
Collection Date: 08/10/2023 13:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.9	µg/L	1	09/16/2023 17:53	211466



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Occu-Tec **Work Order:** 23080908  
**Client Project:** 923235 JMS **Report Date:** 25-Sep-23  
**Lab ID:** 23080908-016 **Client Sample ID:** 235-JMS-19  
**Matrix:** DRINKING WATER **Collection Date:** 08/10/2023 13:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.1	µg/L	1	09/16/2023 17:57	211466



## Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-017  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-20  
Collection Date: 08/10/2023 13:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 18:01	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-018  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-21  
Collection Date: 08/10/2023 13:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	1	09/16/2023 18:04	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-019  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-22  
Collection Date: 08/10/2023 13:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 18:19	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-020  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-23  
Collection Date: 08/10/2023 13:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 18:23	211466





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-021  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-25  
Collection Date: 08/10/2023 13:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		11.1	µg/L	1	09/16/2023 18:26	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-022  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-27  
Collection Date: 08/10/2023 13:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		26.2	µg/L	1	09/16/2023 18:37	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-023  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-28  
Collection Date: 08/10/2023 13:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.7	µg/L	1	09/16/2023 18:41	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-024  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-29  
Collection Date: 08/10/2023 13:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.6	µg/L	1	09/16/2023 18:44	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-025  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-30  
Collection Date: 08/10/2023 13:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.7	µg/L	1	09/16/2023 18:48	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-026  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-31  
Collection Date: 08/10/2023 13:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.2	µg/L	1	09/16/2023 18:52	211466





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-027  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-33  
Collection Date: 08/10/2023 13:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.3	µg/L	1	09/18/2023 14:12	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-028  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-34  
Collection Date: 08/10/2023 13:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	09/18/2023 14:16	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-029  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-35  
Collection Date: 08/10/2023 13:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 14:19	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-030  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-36  
Collection Date: 08/10/2023 13:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		9.4	µg/L	1	09/18/2023 14:23	211466



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-031  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-40  
Collection Date: 08/10/2023 13:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/19/2023 23:34	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-032  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-41  
Collection Date: 08/10/2023 14:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/19/2023 23:38	211514





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-033  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-42  
Collection Date: 08/10/2023 14:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/19/2023 23:42	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-034  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-43  
Collection Date: 08/10/2023 14:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	09/19/2023 23:45	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-035  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-44  
Collection Date: 08/10/2023 14:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/19/2023 23:49	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-036  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-45  
Collection Date: 08/10/2023 14:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.4	µg/L	1	09/20/2023 0:00	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-037  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-46  
Collection Date: 08/10/2023 14:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/20/2023 0:14	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-038  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-47  
Collection Date: 08/10/2023 14:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.1	µg/L	1	09/20/2023 0:18	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-039  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-48  
Collection Date: 08/10/2023 14:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/20/2023 0:22	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-040  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-49  
Collection Date: 08/10/2023 14:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.5	µg/L	1	09/20/2023 0:25	211514





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-041  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-50  
Collection Date: 08/10/2023 14:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		11.5	µg/L	1	09/20/2023 0:29	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-042  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-51  
Collection Date: 08/10/2023 14:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/20/2023 0:33	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-043  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-52  
Collection Date: 08/10/2023 14:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		8.1	µg/L	1	09/20/2023 0:44	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-044  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-53  
Collection Date: 08/10/2023 14:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		29.5	µg/L	5	09/21/2023 22:42	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-045  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-54  
Collection Date: 08/10/2023 14:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/20/2023 0:47	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-046  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-55  
Collection Date: 08/10/2023 14:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/20/2023 1:02	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-047  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-56  
Collection Date: 08/10/2023 14:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	09/20/2023 1:06	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-048  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-57  
Collection Date: 08/10/2023 14:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/20/2023 1:09	211514





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-049  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-58  
Collection Date: 08/10/2023 14:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.9	µg/L	1	09/20/2023 1:13	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-050  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-59  
Collection Date: 08/10/2023 14:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/20/2023 1:17	211514



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-051  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-60  
Collection Date: 08/10/2023 14:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 6:30	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-052  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-61  
Collection Date: 08/10/2023 14:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	1	09/17/2023 6:34	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-053  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-62  
Collection Date: 08/10/2023 14:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/17/2023 6:38	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-054  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-63  
Collection Date: 08/10/2023 14:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 6:41	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-055  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-64  
Collection Date: 08/10/2023 14:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	1	09/17/2023 6:45	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-056  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-65  
Collection Date: 08/10/2023 14:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.3	µg/L	1	09/17/2023 6:49	211515





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-057  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-66  
Collection Date: 08/10/2023 14:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:03	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-058  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-67  
Collection Date: 08/10/2023 14:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:07	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-059  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-68  
Collection Date: 08/10/2023 14:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.2	µg/L	1	09/17/2023 7:18	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-060  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-69  
Collection Date: 08/10/2023 14:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:22	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-061  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-70  
Collection Date: 08/10/2023 14:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:25	211515



## Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-062  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-71  
Collection Date: 08/10/2023 14:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/21/2023 22:45	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-063  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-72  
Collection Date: 08/10/2023 14:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.7	µg/L	5	09/21/2023 22:49	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-064  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-73  
Collection Date: 08/10/2023 14:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.4	µg/L	1	09/17/2023 7:36	211515





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-065  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-74  
Collection Date: 08/10/2023 14:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:51	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-066  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-75  
Collection Date: 08/10/2023 15:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		26.4	µg/L	5	09/21/2023 22:53	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-067  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-76  
Collection Date: 08/10/2023 15:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:55	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-068  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-77  
Collection Date: 08/10/2023 15:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 7:58	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-069  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-78  
Collection Date: 08/10/2023 15:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.8	µg/L	1	09/17/2023 8:02	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-070  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-79  
Collection Date: 08/10/2023 15:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.2	µg/L	1	09/17/2023 8:06	211515



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-071  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-80  
Collection Date: 08/10/2023 15:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		29.3	µg/L	5	09/22/2023 16:30	211541



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-072  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-81  
Collection Date: 08/10/2023 15:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.0	µg/L	1	09/21/2023 14:31	211506





# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-073  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-82  
Collection Date: 08/10/2023 15:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.5	µg/L	1	09/20/2023 4:41	211506



# Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec  
Client Project: 923235 JMS  
Lab ID: 23080908-074  
Matrix: DRINKING WATER

Work Order: 23080908  
Report Date: 25-Sep-23  
Client Sample ID: 235-JMS-83  
Collection Date: 08/10/2023 15:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.9	µg/L	1	09/20/2023 4:45	211506



# Receiving Check List

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 23080908

Client Project: 923235 JMS

Report Date: 25-Sep-23

Carrier: Crossroads

Received By: ANC

Completed by:

*Allison Colin*

Reviewed by:

*Elizabeth A. Hurley*

On:

11-Aug-23

Allison Colin

On:

14-Aug-23

Elizabeth A. Hurley

Pages to follow: Chain of custody

Extra pages included

- |   |  |                              |  |                                  |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  | Not Present <input type="checkbox"/>   | Temp °C <b>NA</b>                |
| Type of thermal preservation?                           | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/>      | Dry Ice <input type="checkbox"/> |
| Chain of custody present?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Chain of custody agrees with sample labels?             | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Samples in proper container/bottle?                     | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Sample containers intact?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Sufficient sample volume for indicated test?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| All samples received within holding time?               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Reported field parameters measured:                     | Field <input type="checkbox"/>           | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |                                  |
| Container/Temp Blank temperature in compliance?         | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- |   |                              |                             |   |
|---|------------------------------|-----------------------------|---|
| Water – at least one vial per sample has zero headspace?  | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/>      |
| Water - TOX containers have zero headspace?               | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt?                       | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/>                |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/>                |

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival at the laboratory.

### CHAIN OF CUSTODY

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: OCCU-TEC  
 Address: 2604 NE Industrial Drive, #230  
 City/State/Zip: North Kansas City  
 Contact: Kevin Heriford Phone: 816-825-0628  
 Email: kheriford@occutec.com Fax:

Samples on:  ICE  BLUE ICE  NO ICE NA °C  
 Preserved in:  LAB  FIELD FOR LAB USE ONLY

Are these samples known to be involved in litigation? If yes, a surcharge will apply:  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section:  Yes  No

Client Comments:  
 5 ppb



PROJECT NAME/NUMBER: 923235  
 SAMPLE COLLECTOR'S NAME: Nate Jones

# and Type of Containers      INDICATE ANALYSIS REQUESTED

RESULTS REQUESTED:  Standard  1-2 Day (100% Surcharge)  Other  3 Day (50% Surcharge)  
 BILLING INSTRUCTIONS

UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other	Pb										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										
									✓										

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
23080908-001	235-JMS-01	8/10/23 13:00	Drinking Water
002	235-JMS-02	8/10/23 13:00	Drinking Water
003	235-JMS-04	8/10/23 13:05	Drinking Water
004	235-JMS-05	8/10/23 13:06	Drinking Water
005	235-JMS-06	8/10/23 13:08	Drinking Water
006	235-JMS-07	8/10/23 13:09	Drinking Water
007	235-JMS-09	8/10/23 13:11	Drinking Water
008	235-JMS-10	8/10/23 13:12	Drinking Water
009	235-JMS-12	8/10/23 13:19	Drinking Water
010	235-JMS-13	8/10/23 13:20	Drinking Water
011	235-JMS-14	8/10/23 13:21	Drinking Water

Relinquished By:  Date/Time: \_\_\_\_\_  
 Received By:  Date/Time: 8/11 808

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this... See www.teklabinc.com for terms and conditions

# CHAIN OF CUSTODY

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: OCCU-TEC  
 Address: 2604 NE Industrial Drive, #230  
 City/State/Zip: North Kansas City  
 Contact: Kevin Heriford Phone: 816-825-0628  
 Email: kheriford@occutec.com Fax:

Samples on:  ICE  BLUE ICE  NO ICE \_\_\_\_\_ °C  
 Preserved in:  LAB  FIELD FOR LAB USE ONLY  
 LAB NOTES:

Are these samples known to be involved in litigation? If yes, a surcharge will apply:  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section:  Yes  No

Client Comments:  
 5 ppb

PROJECT NAME/NUMBER: 923235  
 SAMPLE COLLECTOR'S NAME: Nate Jones

RESULTS REQUESTED:  Standard  1-2 Day (100% Surcharge)  Other \_\_\_\_\_  
 3 Day (50% Surcharge)

BILLING INSTRUCTIONS

# and Type of Containers      INDICATE ANALYSIS REQUESTED

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
<u>23080908-012</u>	<u>235-JMS-15</u>	<u>8/10/23 13:22</u>	<u>Drinking Water</u>
<u>013</u>	<u>235-JMS-16</u>	<u>8/10/23 13:23</u>	<u>Drinking Water</u>
<u>014</u>	<u>235-JMS-17</u>	<u>8/10/23 13:24</u>	<u>Drinking Water</u>
<u>015</u>	<u>235-JMS-18</u>	<u>8/10/23 13:25</u>	<u>Drinking Water</u>
<u>016</u>	<u>235-JMS-19</u>	<u>8/10/23 13:26</u>	<u>Drinking Water</u>
<u>017</u>	<u>235-JMS-20</u>	<u>8/10/23 13:28</u>	<u>Drinking Water</u>
<u>018</u>	<u>235-JMS-21</u>	<u>8/10/23 13:30</u>	<u>Drinking Water</u>
<u>019</u>	<u>235-JMS-22</u>	<u>8/10/23 13:34</u>	<u>Drinking Water</u>
<u>020</u>	<u>235-JMS-23</u>	<u>8/10/23 13:35</u>	<u>Drinking Water</u>
<u>021</u>	<u>235-JMS-25</u>	<u>8/10/23 13:38</u>	<u>Drinking Water</u>
<u>022</u>	<u>235-JMS-27</u>	<u>8/10/23 13:39</u>	<u>Drinking Water</u>

UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other	Pb										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										
									<input checked="" type="checkbox"/>										

Relinquished By: [Signature] Date/Time: \_\_\_\_\_

Received By: [Signature] Date/Time: 8/11/08

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

## CHAIN OF CUSTODY

Pg 3 of 7 Workorder # 23080908

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>OCCU-TEC</u> Address: <u>2604 NE Industrial Drive, #230</u> City/State/Zip: <u>North Kansas City</u> Contact: <u>Kevin Heriford</u> Phone: <u>816-825-0628</u> Email: <u>kheriford@occutec.com</u> Fax:				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES:																
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Client Comments: 5 ppb																
PROJECT NAME/NUMBER 923235		SAMPLE COLLECTOR'S NAME Nate Jones		# and Type of Containers		INDICATE ANALYSIS REQUESTED														
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)			BILLING INSTRUCTIONS			UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other	Pb					
Lab Use Only	Sample ID	Date/Time Sampled		Matrix																
<u>23080908-023</u>	<u>235-JMS-28</u>	<u>8/10/23</u>	<u>13:40</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>024</u>	<u>235-JMS-29</u>	<u>8/10/23</u>	<u>13:41</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>025</u>	<u>235-JMS-30</u>	<u>8/10/23</u>	<u>13:43</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>026</u>	<u>235-JMS-31</u>	<u>8/10/23</u>	<u>13:46</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>027</u>	<u>235-JMS-33</u>	<u>8/10/23</u>	<u>13:47</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>028</u>	<u>235-JMS-34</u>	<u>8/10/23</u>	<u>13:49</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>029</u>	<u>235-JMS-35</u>	<u>8/10/23</u>	<u>13:50</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>030</u>	<u>235-JMS-36</u>	<u>8/10/23</u>	<u>13:51</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>031</u>	<u>235-JMS-40</u>	<u>8/10/23</u>	<u>13:59</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>032</u>	<u>235-JMS-41</u>	<u>8/10/23</u>	<u>14:00</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
<u>033</u>	<u>235-JMS-42</u>	<u>8/10/23</u>	<u>14:01</u>	<u>Drinking Water</u>											<input checked="" type="checkbox"/>					
Relinquished By			Date/Time			Received By			Date/Time											
<u>JS</u>						<u>A. Collier</u>			<u>8/11/23 8:08</u>											

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions

# CHAIN OF CUSTODY

Pg 4 of 7 Workorder # 23080908

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>OCCU-TEC</u> Address: <u>2604 NE Industrial Drive, #230</u> City/State/Zip: <u>North Kansas City</u> Contact: <u>Kevin Heriford</u> Phone: <u>816-825-0628</u> Email: <u>kheriford@occutec.com</u> Fax: _____				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: _____					
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Client Comments: 5 ppb					
PROJECT NAME/NUMBER 923235		SAMPLE COLLECTOR'S NAME Nate Jones		# and Type of Containers		INDICATE ANALYSIS REQUESTED			
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		BILLING INSTRUCTIONS		UMP HNO3 NaOH H2SO4 HCL MeOH NaHSO4 TSP Other Pb					
Lab Use Only	Sample ID	Date/Time Sampled	Matrix						
23080908 -034	235-JMS -43	8/10/23 14:02	Drinking Water			✓			
035	235-JMS -44	8/10/23 14:03	Drinking Water			✓			
036	235-JMS -45	8/10/23 14:05	Drinking Water			✓			
037	235-JMS -46	8/10/23 14:06	Drinking Water			✓			
038	235-JMS -47	8/10/23 14:08	Drinking Water			✓			
039	235-JMS -48	8/10/23 14:09	Drinking Water			✓			
040	235-JMS -49	8/10/23 14:12	Drinking Water			✓			
041	235-JMS -50	8/10/23 14:13	Drinking Water			✓			
042	235-JMS -51	8/10/23 14:16	Drinking Water			✓			
043	235-JMS -52	8/10/23 14:18	Drinking Water			✓			
044	235-JMS -53	8/10/23 14:20	Drinking Water			✓			
Relinquished By 		Date/Time		Received By 		Date/Time 8/11/08			

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

# CHAIN OF CUSTODY

Pg 5 of 7 Workorder # 23080908

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>OCCU-TEC</u> Address: <u>2604 NE Industrial Drive, #230</u> City/State/Zip: <u>North Kansas City</u> Contact: <u>Kevin Heriford</u> Phone: <u>816-825-0628</u> Email: <u>kheriford@occutec.com</u> Fax: _____				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: _____															
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Client Comments: 5 ppb															
PROJECT NAME/NUMBER 923235		SAMPLE COLLECTOR'S NAME Nate Jones		# and Type of Containers		INDICATE ANALYSIS REQUESTED													
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		BILLING INSTRUCTIONS		UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	TSP	Other	Pb						
Lab Use Only	Sample ID	Date/Time Sampled	Matrix																
<u>23080908 045</u>	<u>235-JMS-54</u>	<u>8/10/23 14:24</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>046</u>	<u>235-JMS-55</u>	<u>8/10/23 14:25</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>047</u>	<u>235-JMS-56</u>	<u>8/10/23 14:26</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>048</u>	<u>235-JMS-57</u>	<u>8/10/23 14:27</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>049</u>	<u>235-JMS-58</u>	<u>8/10/23 14:28</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>060</u>	<u>235-JMS-59</u>	<u>8/10/23 14:32</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>061</u>	<u>235-JMS-60</u>	<u>8/10/23 14:33</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>062</u>	<u>235-JMS-61</u>	<u>8/10/23 14:34</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>063</u>	<u>235-JMS-62</u>	<u>8/10/23 14:35</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>064</u>	<u>235-JMS-63</u>	<u>8/10/23 14:36</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
<u>065</u>	<u>235-JMS-64</u>	<u>8/10/23 14:37</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>						
Relinquished By			Date/Time	Received By			Date/Time												
<u>[Signature]</u>				<u>[Signature]</u>			<u>8/11/08</u>												

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions



# CHAIN OF CUSTODY

Pg 6 of 7 Workorder # 23080908

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>OCCU-TEC</u> Address: <u>2604 NE Industrial Drive, #230</u> City/State/Zip: <u>North Kansas City</u> Contact: <u>Kevin Heriford</u> Phone: <u>816-825-0628</u> Email: <u>kheriford@occutec.com</u> Fax: _____				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: _____																
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Client Comments: 5 ppb																
PROJECT NAME/NUMBER 923235		SAMPLE COLLECTOR'S NAME Nate Jones		# and Type of Containers		INDICATE ANALYSIS REQUESTED														
<b>RESULTS REQUESTED</b> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		<b>BILLING INSTRUCTIONS</b>		UNP	HNO3	NaOH	H2SO4	HCL	MeOH	NAHSO4	TSP	Other	Pb							
<b>Lab Use Only</b>	<b>Sample ID</b>	<b>Date/Time Sampled</b>	<b>Matrix</b>																	
<u>23080908-056</u>	<u>235-JMS-65</u>	<u>8/10/23 14:43</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>057</u>	<u>235-JMS-66</u>	<u>8/10/23 14:46</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>058</u>	<u>235-JMS-67</u>	<u>8/10/23 14:49</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>059</u>	<u>235-JMS-68</u>	<u>8/10/23 14:51</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>060</u>	<u>235-JMS-69</u>	<u>8/10/23 14:52</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>061</u>	<u>235-JMS-70</u>	<u>8/10/23 14:53</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>062</u>	<u>235-JMS-71</u>	<u>8/10/23 14:55</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>063</u>	<u>235-JMS-72</u>	<u>8/10/23 14:57</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>064</u>	<u>235-JMS-73</u>	<u>8/10/23 14:58</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>065</u>	<u>235-JMS-74</u>	<u>8/10/23 14:59</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
<u>066</u>	<u>235-JMS-75</u>	<u>8/10/23 15:03</u>	<u>Drinking Water</u>										<input checked="" type="checkbox"/>							
Relinquished By <u>[Signature]</u>		Date/Time _____		Received By <u>[Signature]</u>				Date/Time <u>8/11/08</u>												

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

# CHAIN OF CUSTODY

Pg 7 of 7 Workorder # 23080908

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>OCCU-TEC</u> Address: <u>2604 NE Industrial Drive, #230</u> City/State/Zip: <u>North Kansas City</u> Contact: <u>Kevin Heriford</u> Phone: <u>816-825-0628</u> Email: <u>kheriford@occutec.com</u> Fax:				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES:  Client Comments: 5 ppb															
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																			
PROJECT NAME/NUMBER 923235		SAMPLE COLLECTOR'S NAME Nate Jones		# and Type of Containers		INDICATE ANALYSIS REQUESTED													
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		BILLING INSTRUCTIONS		UNP HNO3 NaOH H2SO4 HCL MeOH NaHSO4 TSP Other Pb															
Lab Use Only	Sample ID	Date/Time Sampled	Matrix																
<u>23080908-067</u>	235-JMS-76	8/10/23 15:06	Drinking Water																✓
<u>068</u>	235-JMS-77	8/10/23 15:03	Drinking Water																✓
<u>069</u>	235-JMS-78	8/10/23 15:10	Drinking Water																✓
<u>070</u>	235-JMS-79	8/10/23 15:12	Drinking Water																✓
<u>071</u>	235-JMS-80	8/10/23 15:13	Drinking Water																✓
<u>072</u>	235-JMS-81	8/10/23 15:14	Drinking Water																✓
<u>073</u>	235-JMS-82	8/10/23 15:15	Drinking Water																✓
<u>074</u>	235-JMS-83	8/10/23 15:16	Drinking Water																✓
<u>075</u>	235-JMS	8/10/23	Drinking Water																✓
<u>TS</u> <u>AL</u> <u>076</u>	235-JMS	8/10/23	Drinking Water																✓
<u>077</u>	235-JMS	8/10/23	Drinking Water																✓
Relinquished By		Date/Time		Received By				Date/Time											
<u>[Signature]</u>		<u>8/10/23 805</u>		<u>[Signature]</u>				<u>8/11 808</u>											

\*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions