



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-01 Client Sample ID: Hines MS Rm #28 DF
 Collection Date: 2/21/2024 5:55:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS Rm #28 DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-02 Client Sample ID: Hines MS Gym
 Collection Date: 2/21/2024 6:00:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS Gym

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-03 Client Sample ID: Hines MS DF by Office
 Collection Date: 2/21/2024 5:58:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS DF by Office


Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-04 Client Sample ID: Hines MS DF by Cafeteria
 Collection Date: 2/21/2024 5:49:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS DF by Cafeteria

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.585		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-05 Client Sample ID: Hines MS Kitchen
 Collection Date: 2/21/2024 5:47:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS Kitchen

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.581		0.500	ppb	1	2/27/2024	15.0	A

Lab ID: 24021000-06 Client Sample ID: Hines MS Office Sink
 Collection Date: 2/21/2024 6:02:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Hines MS Office Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.78		0.500	ppb	1	2/27/2024	15.0	A

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- CI Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original