South Jersey Water Test, LLC
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arch Bishop Damiano School

1145 Delsea Drive
Westville, NJ 08093

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
X150656	Field Blank	06/20/2025 09:50	06/24/2025 18:45	<2.00	15.5	SM3113B
X150657	Room 2 Kitchen	06/20/2025 09:53	06/24/2025 18:51	<2.00	15.5	SM3113B
X150658	Room 3A Kitchen	06/20/2025 09:47	06/24/2025 18:58	<2.00	15.5	SM3113B
X150659	Room 3B Kitchen	06/20/2025 09:48	06/24/2025 19:04	<2.00	15.5	SM3113B
X150660	Room 3 Bath	06/20/2025 09:49	06/24/2025 19:24	<2.00	15.5	SM3113B
X150661	Room 4 Kitchen	06/20/2025 09:45	06/24/2025 19:30	<2.00	15.5	SM3113B
X150662	Room 4 Bath	06/20/2025 09:40	06/24/2025 19:36	<2.00	15.5	SM3113B
X150663	Room 5 Kitchen	06/20/2025 09:41	06/24/2025 19:43	3.23	15.5	SM3113B
X150664	Room 5 Bath	06/20/2025 09:42	06/24/2025 19:49	<2.00	15.5	SM3113B
X150665	Room 5 Library	06/20/2025 09:43	06/24/2025 19:56	4.03	15.5	SM3113B
X150666	Room 6 Kitchen	06/20/2025 09:38	06/24/2025 20:02	<2.00	15.5	SM3113B
X150667	Room 6 Bath	06/20/2025 09:39	06/24/2025 20:09	<2.00	15.5	SM3113B
X150668	Room 7 Kitchen	06/20/2025 09:31	06/24/2025 20:15	<2.00	15.5	SM3113B
X150669	Room 7 Bath	06/20/2025 09:32	06/24/2025 20:22	<2.00	15.5	SM3113B
X150670	Room 8 Kitchen	06/20/2025 09:35	06/24/2025 20:41	<2.00	15.5	SM3113B
X150671	Room 8 Bath	06/20/2025 09:34	06/24/2025 20:47	2.55	15.5	SM3113B
X150672	Water Fountain 6/8	06/20/2025 09:37	06/24/2025 20:54	<2.00	15.5	SM3113B
X150673	Room 9 Kitchen	06/20/2025 09:29	06/24/2025 21:13	<2.00	15.5	SM3113B
X150674	Bath (Elain) ADM	06/20/2025 09:27	06/24/2025 21:19	2.03	15.5	SM3113B
X150675	Bath (Kate) ADM	06/20/2025 09:25	06/24/2025 21:26	<2.00	15.5	SM3113B
X150676	Bath - Main Boys	06/20/2025 09:23	06/24/2025 21:32	<2.00	15.5	SM3113B
X150677	Bath - Main Boys	06/20/2025 09:24	06/24/2025 21:39	<2.00	15.5	SM3113B
X150678	Bath - Main Girls #24	06/20/2025 09:20	06/24/2025 21:58	<2.00	15.5	SM3113B
X150679	Bath - Maimn Girls #22	06/20/2025 09:21	06/24/2025 22:04	<2.00	15.5	SM3113B
X150680	Bath - Main Girls #23	06/20/2025 09:19	06/24/2025 22:11	<2.00	15.5	SM3113B
X150681	Room 15 - Kitchen	06/20/2025 09:17	06/24/2025 22:17	<2.00	15.5	SM3113B
X150682	Room 15 - Bath	06/20/2025 09:18	06/24/2025 22:24	<2.00	15.5	SM3113B
X150683	Room 16 - Kitchen	06/20/2025 09:14	06/24/2025 22:30	<2.00	15.5	SM3113B
X150684	Room 16 - Bath	06/20/2025 09:15	06/26/2025 14:19	5.60	15.5	SM3113B
X150685	Room 17 - Kitchen	06/20/2025 09:10	06/26/2025 14:26	<2.00	15.5	SM3113B
X150686	Room 17 - Bath	06/20/2025 09:11	06/26/2025 14:32	<2.00	15.5	SM3113B
X150687	Room 18 - Kitchen	06/20/2025 09:09	06/26/2025 14:39	<2.00	15.5	SM3113B
X150688	Room 18 - Bath	06/20/2025 09:08	06/26/2025 14:45	<2.00	15.5	SM3113B
X150689	Room 19 - Kitchen	06/20/2025 09:03	06/26/2025 14:52	<2.00	15.5	SM3113B
X150690	Room 19 - Bath	06/20/2025 09:00	06/26/2025 14:58	<2.00	15.5	SM3113B
X150691	Room 20 - Kitchen	06/20/2025 09:05	06/26/2025 15:05	<2.00	15.5	SM3113B
X150692	Room 20 - Bath	06/20/2025 09:06	06/26/2025 15:11	<2.00	15.5	SM3113B

Units - ug/L = ppb

South Jersey Water Test, LLC
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Arch Bishop Damiano School

1145 Delsea Drive
Westville, NJ 08093

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
X150693	Water Fountain 16/18	06/20/2025 09:13	06/26/2025 15:50	<2.00	15.5	SM3113B
X150694	Water Fountain 19/21	06/20/2025 09:02	06/26/2025 15:56	3.41	15.5	SM3113B
X150695	Room 21 - Kitchen	06/20/2025 08:59	06/26/2025 16:03	<2.00	15.5	SM3113B
X150696	Room 21 - Bath	06/20/2025 08:58	06/26/2025 16:09	<2.00	15.5	SM3113B
X150697	Room 22 - Kitchen	06/20/2025 08:54	06/26/2025 16:16	<2.00	15.5	SM3113B
X150698	Room 22 - Bath Right	06/20/2025 08:55	06/26/2025 16:22	3.30	15.5	SM3113B
X150699	Room 22 - Bath Center	06/20/2025 08:56	06/26/2025 16:29	<2.00	15.5	SM3113B
X150700	Room 22 - Bath Left	06/20/2025 08:57	06/26/2025 15:31	<2.00	15.5	SM3113B
X150701	Room 23 - Kitchen	06/20/2025 08:50	06/26/2025 16:48	<2.00	15.5	SM3113B
X150702	Room 23 - Bath	06/20/2025 08:51	06/26/2025 16:54	<2.00	15.5	SM3113B
X150703	Room 24 - Kitchen	06/20/2025 08:49	06/26/2025 17:01	<2.00	15.5	SM3113B
X150704	Bath (Maint)	06/20/2025 08:48	06/26/2025 17:07	<2.00	15.5	SM3113B
X150705	Bath (Janitor)	06/20/2025 08:46	06/26/2025 17:13	<2.00	15.5	SM3113B
X150706	Water Fountain (Herp Hall)	06/20/2025 08:44	06/26/2025 17:20	<2.00	15.5	SM3113B
X150707	Room 25 - Kitchen	06/20/2025 08:43	06/26/2025 17:26	<2.00	15.5	SM3113B
X150708	Room 30 - Bath	06/20/2025 08:37	06/26/2025 17:33	<2.00	15.5	SM3113B
X150709	Room 31 - Bath	06/20/2025 08:38	06/26/2025 17:39	<2.00	15.5	SM3113B
X150710	Gym (Boys) #54	06/20/2025 08:32	06/26/2025 17:46	<2.00	15.5	SM3113B
X150711	Gym (Boys) #55	06/20/2025 08:33	06/26/2025 18:05	<2.00	15.5	SM3113B
X150712	Gym (Girls) #56	06/20/2025 08:35	06/26/2025 18:25	<2.00	15.5	SM3113B
X150713	Gym (Girls) # 57	06/20/2025 08:34	06/26/2025 18:31	<2.00	15.5	SM3113B
X150714	Caf (Ice Machine)	06/20/2025 08:17	06/26/2025 18:37	<2.00	15.5	SM3113B
X150715	Kitchen #61	06/20/2025 08:20	06/26/2025 18:44	<2.00	15.5	SM3113B
X150716	Kitchen #60	06/20/2025 08:22	06/26/2025 18:50	<2.00	15.5	SM3113B
X150717	Kitchen #59	06/20/2025 08:21	06/26/2025 18:57	<2.00	15.5	SM3113B
X150718	Kitchen Bath #62	06/20/2025 08:26	06/26/2025 19:03	3.41	15.5	SM3113B
X150719	Dish Wash Sink #63	06/20/2025 08:24	06/26/2025 19:22	<2.00	15.5	SM3113B
X150720	Ice Maker #58	06/20/2025 08:28	06/26/2025 19:29	23.66	15.5	SM3113B

Mark J. Riether, Lab Director

06/27/2025
Date

Units - ug/L = ppb