



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-16 Client Sample ID: Slater Elem Kitchen
 Collection Date: 2/20/2024 5:15:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Kitchen

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | 0.544 | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

Lab ID: 24021000-17 Client Sample ID: Slater Elem DF by Office
 Collection Date: 2/20/2024 5:12:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem DF by Office

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

Lab ID: 24021000-18 Client Sample ID: Slater Elem DF by Boy's/Girl's RR
 Collection Date: 2/20/2024 5:18:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem DF by Boy's/Girl's RR

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-19 Client Sample ID: Slater Elem NW Hall DF
 Collection Date: 2/20/2024 5:23:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem NW Hall DF

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|--|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status | |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A | |

Lab ID: 24021000-20 Client Sample ID: Slater Elem End of Hall DF
 Collection Date: 2/20/2024 5:20:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem End of Hall DF

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|--|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status | |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A | |

Lab ID: 24021000-21 Client Sample ID: Slater Elem Staff Rm
 Collection Date: 2/20/2024 5:17:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Staff Rm


| Trace Metals by EPA 200.8 ICP-MS | | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|--|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status | |
| Lead | 1.08 | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A | |

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-22 Client Sample ID: Slater Elem Unit #2 DF by #28
 Collection Date: 2/20/2024 5:32:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Unit #2 DF by #28

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

Lab ID: 24021000-23 Client Sample ID: Slater Elem Faucet by #26
 Collection Date: 2/20/2024 5:36:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Faucet by #26

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

Lab ID: 24021000-24 Client Sample ID: Slater Elem Faucet by Gym
 Collection Date: 2/20/2024 5:29:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Faucet by Gym

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | Analyst: CJS | |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A |

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 24021000
 Date Reported: 3/7/2024

Box R Waterlab
 567 NW Second Street
 Prineville, OR 97754

Lab Order: 24021000
Received Date: 2/26/2024 10:05:00 AM
Reported Date: 3/7/2024 8:51:41 AM

Sample Information:

Lab ID: 24021000-25 Client Sample ID: Slater Elem Gym
 Collection Date: 2/20/2024 5:30:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Gym

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | Analyst: CJS | | |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|--|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status | |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A | |

Lab ID: 24021000-26 Client Sample ID: Slater Elem Cafeteria DF
 Collection Date: 2/20/2024 5:10:00 AM Collected By: CB/WP
 Matrix: Drinking Water Sample Location: Slater Elem Cafeteria DF

| Trace Metals by EPA 200.8 ICP-MS | | | | | | | Analyst: CJS | | |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|--|
| Analyses | Result | Qual | MRL | Units | DF | Date Analyzed | MCL | NELAP Status | |
| Lead | ND | | 0.500 | ppb | 1 | 2/27/2024 | 15.0 | A | |

QUALIFIERS

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-16A

Date Received: 2 / 26 / 24

Received By: DG *pmo*

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.

2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.

3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.

4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.

5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.

6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.

7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21 : 00 am/pm Date 02, 19, 2024

Sample was collected: Time 05 : 15 am/pm Date 02, 20, 2024

Name of Water System: HARNEY COUNTY SCHOOL DIST #3 PWS ID 41: _____

Sample Collected by: CB/WP Bottle # 10247

Address: SLATER ELEMENTARY Space # _____

Faucet Location: (e.g. Kitchen Faucet) KITCHEN

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-20-24



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-17A
 Received By: DG *Amb*

Date Received: 2/26/24
 Time Received: 10:05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.

2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.

3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.

4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.

5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.

6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.

7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057493 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | | |
|---|-------------------------------------|------------------------|------------------|
| Water was last used: | Time <u>21:00</u> am/pm | Date <u>02/19/2024</u> | |
| Sample was collected: | Time <u>05:12</u> am/pm | Date <u>02/20/2024</u> | |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | | PWS ID 41: _____ |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>13132</u> | |
| Address: | <u>SLATER ELEMENTARY</u> | | Space # _____ |
| Faucet Location: (e.g. Kitchen Faucet) | <u>DRINKING FOUNTAIN BY OFFICE</u> | | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> | |



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-18A
 Received By: DG

Date Received: 2/26/24
 Time Received: 10:05 am/pm

AMB

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057493 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | |
|---|---|------------------------|
| Water was last used: | Time <u>21:00</u> am/pm | Date <u>02/19/2024</u> |
| Sample was collected: | Time <u>05:18</u> am/pm | Date <u>02/20/2024</u> |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>10444</u> |
| Address: | <u>SLATER ELEMENTARY</u> | |
| Faucet Location: (e.g. Kitchen Faucet) | <u>DRINKING FOUNTAIN BY BOY'S & GIRL'S RESTROOM</u> | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> |



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-19A
 Received By: DG AWB

Date Received: 2, 26, 24
 Time Received: 10:05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | | |
|---|-------------------------------------|--------------------------|------------------|
| Water was last used: | Time <u>21:00</u> am/pm | Date <u>02, 19, 2024</u> | |
| Sample was collected: | Time <u>05:23</u> am/pm | Date <u>02, 20, 2024</u> | |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | | PWS ID 41: _____ |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>13310</u> | |
| Address: | <u>SLATER ELEMENTARY</u> | | Space # _____ |
| Faucet Location: (e.g. Kitchen Faucet) | <u>DRINKING FOUNTAIN NW HALL</u> | | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> | |

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-20A

Date Received: 2 / 26 / 24

Received By: DG AWD

Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057493 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | |
|---|--|--------------------------|
| Water was last used: | Time <u>21 : 00</u> am/pm | Date <u>02, 19, 2024</u> |
| Sample was collected: | Time <u>05 : 20</u> am/pm | Date <u>02, 20, 2024</u> |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> PWS ID 41- _____ | |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>13255</u> |
| Address: | <u>SLATER ELEMENTARY</u> Space # _____ | |
| Faucet Location: (e.g. Kitchen Faucet) | <u>DRINKING FOUNTAIN END OF HALL</u> | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> |



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-21A
 Received By: DG

Date Received: 2, 26, 24
 Time Received: 10 : 05 am/pm

amp

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | | |
|---|-------------------------------------|--------------------------|------------------|
| Water was last used: | Time <u>21 : 00</u> am/pm | Date <u>02, 19, 2024</u> | |
| Sample was collected: | Time <u>05 : 17</u> am/pm | Date <u>02, 20, 2024</u> | |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | | PWS ID 41: _____ |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>13302</u> | |
| Address: | <u>SLATER ELEMENTARY</u> | | Space # _____ |
| Faucet Location: (e.g. Kitchen Faucet) | <u>STAFF ROOM</u> | | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> | |



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-22A
 Received By: DG am

Date Received: 2/26/24
 Time Received: 10:05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21:00 am/pm Date 02, 19, 2024
 Sample was collected: Time 05:32 am/pm Date 02, 20, 2024
 Name of Water System: HARNEY COUNTY SCHOOL DIST #3 PWS ID 41: _____
 Sample Collected by: CB/WP Bottle # 13140
 Address: SLATER ELEMENTARY Space # _____
 Faucet Location: (e.g. Kitchen Faucet) UNIT 2 DRINKING FOUNTAIN BY #28

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-20-24



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-23A
 Received By: DG

Date Received: 2 / 26 / 24
 Time Received: 10 : 05 am/pm

AWB

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.

2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.

3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.

4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.

5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.

6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.

7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057493 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | |
|---|-------------------------------------|--------------------------|
| Water was last used: | Time <u>21 : 00</u> am/pm | Date <u>02, 19, 2024</u> |
| Sample was collected: | Time <u>05 : 36</u> am/pm | Date <u>02, 20, 2024</u> |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | PWS ID 41: _____ |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>104675</u> |
| Address: | <u>SLATER ELEMENTARY</u> | Space # _____ |
| Faucet Location: (e.g. Kitchen Faucet) | <u>FAUCET BY #26</u> | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> |



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000-24A
 Received By: DG

Date Received: 2 / 26 / 24
 Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.

2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. Do not intentionally flush the water line before the start of the 6 hour period.

3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. Do not remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.

4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.

5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.

6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.

7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | | |
|---|-------------------------------------|--------------------------|------------------------|
| Water was last used: | Time <u>21 : 00</u> am/pm | Date <u>02, 19, 2024</u> | |
| Sample was collected: | Time <u>05 : 29</u> am/pm | Date <u>02, 20, 2024</u> | |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> | | PWS ID 41- _____ |
| Sample Collected by: | <u>CB / WP</u> | | Bottle # <u>104630</u> |
| Address: | <u>SLATER ELEMENTARY</u> | | Space # _____ |
| Faucet Location: (e.g. Kitchen Faucet) | <u>FAUCET BY GYM</u> | | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | | Date <u>02-20-24</u> |

DIST #3



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

6700642126124

LAB NRC Sample Number: 24021000-17A-25A

Date Received: 2/26/24

Received By: DG AMB

Time Received: 10:05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.

2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.

3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.

4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.

5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.

6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.

7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057499 at _____ if you have any questions.

TO BE COMPLETED BY RESIDENT

Water was last used: Time 21:00 am/pm Date 02/19/2024

Sample was collected: Time 05:30 am/pm Date 02/20/2024

Name of Water System: HARNEY COUNTY SCHOOL DIST #3 PWS ID 41- _____

Sample Collected by: CB/WP Bottle # 13306

Address: SLATER ELEMENTARY Space # _____

Faucet Location: (e.g. Kitchen Faucet) GYM

I have read the above directions and have taken a tap sample in accordance with these directions.

Signature HARNEY COUNTY SCHOOL Date 02-20-24



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

LAB NRC Sample Number: 24021000 ^{Error #4 2/26/24} ~~16A~~ - 26A
 Received By: DG _{AMB} Date Received: 2, 26, 24
 Time Received: 10 : 05 am/pm

Directions for Homeowner Tap Sample Collection Procedures

These samples are being collected to determine the lead and copper levels in your tap water. This sampling effort is required by the U.S. Environmental Protection Agency and your State under the Lead and Copper Rule, and is being accomplished through collaboration between the public water system and their consumers (e.g. residents).

Collect samples from a tap that has not been used for at least 6 hours. To ensure the water has not been used for at least 6 hours, the best time to collect samples is either early in the morning or in the evening upon returning from work. Be sure to use a kitchen or bathroom cold water tap that has been used for drinking water consumption in the past few weeks. The collection procedure is described below.

1. Prior arrangements will be made with you to coordinate the sample collection. Dates will be set for sample kit delivery and pick-up by water system staff.
2. There must be a minimum of 6 hours during which there is no water used from the tap where the sample will be collected and any taps adjacent or close to that tap. Either early mornings or evenings upon returning home are the best sampling times to ensure that the necessary stagnant water conditions exist. **Do not** intentionally flush the water line before the start of the 6 hour period.
3. Use a kitchen or bathroom cold-water faucet for sampling. If you have water softeners on your kitchen taps, collect your sample from the bathroom tap that is not attached to a water softener, or a point of use filter, if possible. **Do not** remove the aerator prior to sampling. Place the opened sample bottle below the faucet and open the cold water tap as you would do to fill a glass of water. Fill the sample bottle to the line marked "1000-mL" and turnoff the water.
4. Tightly cap the sample bottle and place in the sample kit provided. Please review the sample kit label at this time to ensure that all information contained on the label is correct.
5. If any plumbing repairs or replacements have been done in the home since the previous sampling event, note this information on the back of this form. Also if your sample was collected from a tap with a water softener, note this as well.
6. Place the sample kit in the location the kit was delivered to so that water system staff may pick up the sample kit.
7. Results from this monitoring effort and information about lead will be provided to you as soon as practical but no later than 30 days after the system learns of the tap monitoring results. However, if excessive lead and/or copper levels are found, immediate notification will be provided (usually 1-2 working days after the system learns of the tap monitoring results).

Call X057493 at _____ if you have any questions.

| TO BE COMPLETED BY RESIDENT | | |
|---|--|--------------------------|
| Water was last used: | Time <u>21 : 00</u> am/pm | Date <u>02, 19, 2024</u> |
| Sample was collected: | Time <u>05 : 10</u> am/pm | Date <u>02, 20, 2024</u> |
| Name of Water System: | <u>HARNEY COUNTY SCHOOL DIST #3</u> PWS ID 41- _____ | |
| Sample Collected by: | <u>CB/WP</u> | Bottle # <u>104674</u> |
| Address: | <u>SLATER ELEMENTARY</u> Space # _____ | |
| Faucet Location: (e.g. Kitchen Faucet) | <u>FOUNTAIN IN CAFETERIA</u> | |
| I have read the above directions and have taken a tap sample in accordance with these directions. | | |
| Signature | <u>HARNEY COUNTY SCHOOL</u> | Date <u>02-20-24</u> |