



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24021000  
 Date Reported: 3/7/2024

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 24021000  
**Received Date:** 2/26/2024 10:05:00 AM  
**Reported Date:** 3/7/2024 8:51:41 AM

Sample Information:

**Lab ID:** 24021000-16      Client Sample ID: Slater Elem Kitchen  
 Collection Date: 2/20/2024 5:15:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem Kitchen

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.544		0.500	ppb	1	2/27/2024	15.0	A

**Lab ID:** 24021000-17      Client Sample ID: Slater Elem DF by Office  
 Collection Date: 2/20/2024 5:12:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem DF by Office

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

**Lab ID:** 24021000-18      Client Sample ID: Slater Elem DF by Boy's/Girl's RR  
 Collection Date: 2/20/2024 5:18:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem DF by Boy's/Girl's RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24021000  
 Date Reported: 3/7/2024

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 24021000  
**Received Date:** 2/26/2024 10:05:00 AM  
**Reported Date:** 3/7/2024 8:51:41 AM

Sample Information:

**Lab ID:** 24021000-19      Client Sample ID: Slater Elem NW Hall DF  
 Collection Date: 2/20/2024 5:23:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem NW Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A	

**Lab ID:** 24021000-20      Client Sample ID: Slater Elem End of Hall DF  
 Collection Date: 2/20/2024 5:20:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem End of Hall DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A	

**Lab ID:** 24021000-21      Client Sample ID: Slater Elem Staff Rm  
 Collection Date: 2/20/2024 5:17:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem Staff Rm

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.08		0.500	ppb	1	2/27/2024	15.0	A	

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 24021000  
 Date Reported: 3/7/2024

Box R Waterlab  
 567 NW Second Street  
 Prineville, OR 97754

**Lab Order:** 24021000  
**Received Date:** 2/26/2024 10:05:00 AM  
**Reported Date:** 3/7/2024 8:51:41 AM

Sample Information:

**Lab ID:** 24021000-22      Client Sample ID: Slater Elem Unit #2 DF by #28  
 Collection Date: 2/20/2024 5:32:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem Unit #2 DF by #28

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

**Lab ID:** 24021000-23      Client Sample ID: Slater Elem Faucet by #26  
 Collection Date: 2/20/2024 5:36:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem Faucet by #26

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

**Lab ID:** 24021000-24      Client Sample ID: Slater Elem Faucet by Gym  
 Collection Date: 2/20/2024 5:29:00 AM      Collected By: CB/WP  
 Matrix: Drinking Water      Sample Location: Slater Elem Faucet by Gym

Trace Metals by EPA 200.8 ICP-MS							Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	2/27/2024	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- PRE Percent RE exceeds the Limit
- C1 Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit
- R RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original