

Consumer Notice LEAD IN DRINKING WATER

The *Rappahannock County High School* is a public water system and we are responsible for providing you with water at this location and ensuring that the drinking water we provide to you meets state and federal standards. We recently collected drinking water samples to test for lead and copper. The results of this testing are as follows:

Sample Location	Sample Date	Lead Concentration [Select one] (ppb) or (mg/L)	Optional: Copper Concentration (mg/L)
RCHS ROOM 23	08/30/2025	3.54 PPB	
RCHS ROOM 18	08/30/25	<2PPB	
RCHS ROOM 15	08/30/25	<2PPB	
RCHS ROOM C2BF	08/30/25	<2PPB	
RCHS -TECH LAB	08/30/25	<2PPB	
RCHS ROOM 25	08/30/25	<2PPB	

Definitions

Under the authority of the Safe Drinking Water Act, the U.S. Environmental Protection Agency (EPA) set the Action Level (AL) for lead in drinking water at 15 parts per billion (ppb) (or 0.015 milligrams/Liter (mg/L)). The AL for copper in drinking water is 1.3 mg/L.

Public water systems must ensure that water from the customer's tap does not exceed the AL in at least 90 percent of the locations sampled (this is referred to as the 90th percentile value). The AL is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Because lead may pose serious health risks, the EPA also set a Maximum Contaminant Level Goal (MCLG) for lead of zero. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Health Effects of Lead

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Steps You Can Take To Reduce Your Exposure to Lead in Your Water

1. **Run your water to flush out lead.** If water hasn't been used for several hours, allow the water to run at the tap for 30 seconds to 2 minutes before using it for drinking or cooking. This action flushes the lead-containing water from the pipes. The water you run from drinking water taps does not have to be wasted. You can use this water for cleaning purposes or for watering plants. You may want to keep a container of drinking water in your refrigerator, so you don't have to run water every time you need it.
2. **Use water from the cold water tap for cooking and preparing baby formula.** Do not cook with or drink water from the hot water tap; lead dissolves more easily in hot water. Do not use water from the hot water tap to make baby formula.

3. **Do not boil water to remove lead.** Boiling water will not reduce or remove lead.
4. **Consider installing a filter.** You may want to consider installing a water filter. Ensure that the filter is approved to reduce lead or contact the National Sanitation Foundation at 800-NSF-8010 or www.nsf.org for information on performance standards for these types of water filters. If you choose to install a lead removal filter, be sure to maintain and replace the filter in accordance with the manufacturer's instructions to protect water quality.
5. **Get your child tested.** Contact your local health department or healthcare provider to find out how you can get your child's blood tested for lead if you are concerned about exposure.
6. **Identify and replace any plumbing fixtures that contain lead.** Brass faucets, fittings, and valves manufactured *before January 4, 2014*, may contribute lead to drinking water, including those advertised as "lead-free." Under current law, "lead-free" means no more than 0.2% lead in solder and flux, and 0.25% lead for pipe, pipe fittings, and components. Visit the National Sanitation Foundation website at www.nsf.org to learn more about lead-containing plumbing fixtures.

[Optional:]

Copper

Copper is an essential nutrient, but some people who drink water containing copper in excess of the AL over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the AL over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

For More Information

Call us at *[Insert Waterworks Owner's Contact Phone Number]*, or *[if applicable]* visit our Website at *[insert Waterworks Website Here]*. For more information on reducing lead exposure around your home/building and the health effects of lead:

1. Visit EPA's website at <http://www.epa.gov/lead>;
2. Visit VDH's website at <http://www.vdh.virginia.gov/leadsafe/>
3. Contact your health care provider;
4. Contact the National Lead Information Center at 800-424-LEAD

This notice is brought to you by *[insert the name of your waterworks]*. State Water System ID# *[insert your water system's ID number]*. Date *[Insert the date distributed]*

Lead and Copper Results Delivery Certification

INSTRUCTIONS: Waterworks owner must

1. Complete this form.
2. Attach a copy of the consumer notice to this form.
3. Within three months from the end of the monitoring period, mail or email this form to:
Email: ODWFieldOffice#@vdh.virginia.gov or:
VDH - Office of Drinking Water
[Name] Field Office
[Field Office Address]

Waterworks Name: Rappahannock County High School PWSID: 6157380

DELIVERY METHOD – Nontransient Noncommunity Waterworks

Either of the following is acceptable consumer notification:

- ☒ Posted in all facilities in which the samples were collected within 30 days of receiving the laboratory results.
- ☐ All persons served within the facilities in which the lead and copper samples were collected were notified within 30 days of receiving the laboratory results. Notification was made by: (describe notification method) _____

Describe any additional consumer notification (ex. sent notification to parents/guardians, etc.):

Posted on District Website

I certify that persons served at the locations from where the lead and copper tap water samples were collected have been informed of the lead and copper monitoring results within 30 days of receiving the laboratory results, along with the following information: MCLGs, ALs and their definitions; a fact sheet on the health effects of lead which includes steps to reduce exposure to lead in drinking water; and contact information for the water system.

Signature: _____

Print Name: Robin Bolt

Title: Executive Director of Administrative Services Phone: 540-227-0023 Date: 09/12/2025