

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET

WASHINGTON, NEW JERSEY 07882

LABORATORY CERT# 21016

908-835-2510

Date of Report: 05/02/22**Project Name:** 208 S. Mountain Avenue**Sample Date & Time:** 04/20/22 09:37**Sampled By:** JH**208 S. Mountain Avenue, Montclair****Collection Point:** Multiple**Treatment Type:** None**First Draw Lead** (Raw Samples)

Collection Point	Parameter	Result	MCL**	Procedure	NJ Lab Cert #	Analysis Date/Time
Classroom 211	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:32
Classroom 209	Lead	1.18 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:38
Classroom 202	Lead	2.36 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:40
Classroom 200	Lead	1.42 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:42
Room 212 Left	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:44
Room 212 Right	Lead	<1.00ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:50
Room 216 Left	Lead	1.57 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:52
Room 216 Right	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:55
Room 218	Lead	1.40 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:57
Room 214	Lead	1.18 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 14:59

ALL-STATE WELL TESTING SERVICES, LLC
 11-13 BROAD STREET
 WASHINGTON, NEW JERSEY 07882
 LABORATORY CERT# 21016
 908-835-2510

Date of Report: 05/02/22
Project Name: 208 S. Mountain Avenue
Sample Date & Time: 04/20/22 09:37
Sampled By: JH

208 S. Mountain Avenue, Montclair
Collection Point: Multiple
Treatment Type: None
First Draw Lead (Raw Samples)

Collection Point	Parameter	Result	MCL**	Procedure	NJ Lab Cert #	Analysis Date/Time
Room 225	Lead	4.55 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:01
Room 226	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:07
Room 227	Lead	1.33 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:09
Room 118	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:15
Room 121 Left	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:17
Room 121 Right	Lead	<1.00ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:19
Room 112	Lead	1.14 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:21
1 st FI Staff Restroom Near Room 112	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:23
Room 114 Left	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:25
Room 114 Right	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/28/22 15:28

ALL-STATE WELL TESTING SERVICES, LLC
 11-13 BROAD STREET
 WASHINGTON, NEW JERSEY 07882
 LABORATORY CERT# 21016
 908-835-2510

Collection Point	Parameter	Result	MCL**	Procedure	NJ Lab Cert #	Analysis Date/Time
1st FI Cust. Closet	Lead	3.10 ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:00
Room 113 Left	Lead	1.30 ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:06
Room 113 Right	Lead	1.11 ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:08
1st FI Staff Restroom Near Room 113	Lead	<1.00 ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:10
Gym Office	Lead	1.51 ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:12
G FI Maintenance Office	Lead	<1.00ug/l	5 ug/l	EPA Method 200.8	03036	04/27/22 12:18

The results reported for the above property HAVE met New Jersey Drinking Water Standards.

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.



Harold Blaine
 Laboratory Manager

MCL – Maximum Contaminant Level

***Red Bold Result** - At the time of sampling this parameter does not meet NJDEP Standards for drinking water.